

OHA - Drinking Water Services - Surface Water Quality Data Form

County: Lane

Cartridge or Bag Filtration

Month/Year: January 2023

System Name: Camp White Branch Spring box system ID#: 41 WTP ID: TP-

Day	PSI Before Filter	PSI After Filter	PSID	PSID When to Change Filter	Daily Turbidity Reading [NTU]	Highest Reading of the day ¹ [NTU]
1	no campers		#VALUE!	25.00		
2	no campers		#VALUE!	25.00		
3	no campers		#VALUE!	25.00		
4	no campers		#VALUE!			
5	no campers		#VALUE!			
6	no campers		#VALUE!			
7	no campers		#VALUE!			
8	no campers		#VALUE!			
9	no campers		#VALUE!			
10	Initial Start up					
11	30.00	29.00	1.00	25.00	0.39	0.40
12	30.00	29.00	1.00	25.00	0.37	0.38
13	30.00	29.00	1.00	25.00	0.29	0.36
14	30.00	29.00	1.00	25.00	0.58	0.67
15	30.00	28.00	2.00	25.00	0.69	0.73
16	30.00	28.00	2.00	25.00	0.56	0.60
17	30.00	28.00	2.00	25.00	0.51	0.59
18	no campers		#VALUE!			
19	no campers		#VALUE!			
20	no campers		#VALUE!			
21	no campers		#VALUE!			
22	no campers		#VALUE!			
23	no campers		#VALUE!			
24	no campers		#VALUE!			
25	no campers		#VALUE!			
26	no campers		#VALUE!			
27	no campers		#VALUE!			
28	no campers		#VALUE!			
29	no campers		#VALUE!			
30	no campers		#VALUE!			
31	no campers		#VALUE!			

Cartridge & Bag Filtration	Monthly Summary (Answer Yes or No)
95% of daily turbidity readings ≤ 1 NTU? Yes	CT's met everyday? (see back) Yes
All daily turbidity readings ≤ 5 NTU? Yes	All Cl2 residual at entry point ≥ 0.2 mg/l? Yes

Notes: PSI = pounds per square inch
 PSID = pounds per square inch difference (before filter - after filter)
 PSID When to Change Filter = look in manual for manufacturer's specifications when to change the filter, at what PSID.

PRINTED NAME: Clayton Willbroad
 SIGNATURE: CWW DATE: 1/31/23
 PHONE #: (541)822-3511 CERT #:

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in Daily Turbidity Reading column may not

correspond to continuous readings' maximum.

OHA - Drinking Water Services - Surface Water Quality Data Form

WTP: :

System Name:	ID#: 41	Month/Year:	January/2023	Disinfection Giardia Log Inactiv:	1
--------------	---------	-------------	--------------	---	---

Date / Time	Minimum Cl ₂ Residual at 1st User (C) ²	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ²	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
1	no campers	26	#VALUE!	17.8		#VALUE!	#VALUE!	
2	no campers	26	#VALUE!	17.6		#VALUE!	#VALUE!	
3	no campers	26	#VALUE!	17.4		#VALUE!	#VALUE!	
4	no campers	26	#VALUE!			#VALUE!	#VALUE!	
5	no campers	26	#VALUE!			#VALUE!	#VALUE!	
6	no campers	26	#VALUE!			#VALUE!	#VALUE!	
7	no campers	26	#VALUE!			#VALUE!	#VALUE!	
8	no campers	26	#VALUE!			#VALUE!	#VALUE!	
9	no campers	26	#VALUE!			#VALUE!	#VALUE!	
10	inital start up	26	#VALUE!			#VALUE!	#VALUE!	
11	4	26	104.0	2.3	7.30	102.8	YES	
12	3.9	26	101.4	2.5	7.30	100.1	YES	
13	3.8	26	98.8	2.6	7.30	98.3	YES	
14	3.7	26	96.2	2.9	7.20	91.6	YES	
15	3.7	26	96.2	3.1	7.10	87.1	YES	
16	3.7	26	96.2	3.5	7.00	81.6	YES	
17	3.8	26	98.8	3.4	7.00	83.2	YES	
18	no campers		#VALUE!			#VALUE!	#VALUE!	
19	no campers		#VALUE!			#VALUE!	#VALUE!	
20	no campers		#VALUE!			#VALUE!	#VALUE!	
21	no campers		#VALUE!			#VALUE!	#VALUE!	
22	no campers		#VALUE!			#VALUE!	#VALUE!	
23	no campers		#VALUE!			#VALUE!	#VALUE!	
24	no campers		#VALUE!			#VALUE!	#VALUE!	
25	no campers		#VALUE!			#VALUE!	#VALUE!	
26	no campers		#VALUE!			#VALUE!	#VALUE!	
27	no campers		#VALUE!			#VALUE!	#VALUE!	
28	no campers		#VALUE!			#VALUE!	#VALUE!	
29	no campers		#VALUE!			#VALUE!	#VALUE!	
30	no campers		#VALUE!			#VALUE!	#VALUE!	
31	no campers		#VALUE!			#VALUE!	#VALUE!	

² If Cl₂ at entry point < 0.2 mg/l or CT not met, notify DWS within 24 hours.

Revised July 2018

Return by 10th of following month by email, fax, or mail to:

dwp.dmce@state.or.us; 971-673-0694; or Drinking Water Services, PO Box 14350, Portland, OR 97293-0350