

OHA - Drinking Water Services - Surface Water Quality Data Form

County: Lane

Cartridge or Bag Filtration

Month/Year: January 2024

System Name:		ID#: 41			WTP ID: TP-	
Day	PSI Before Filter	PSI After Filter	PSID	PSID When to Change Filter	Daily Turbidity Reading [NTU]	Highest Reading of the day <sup>1</sup> [NTU]
1	No Campers		#VALUE!	0.25		
2	No Campers		#VALUE!			
3	No Campers		#VALUE!			
4	0.30	0.28	0.02		0.34	0.36
5	No Campers		#VALUE!			
6	No Campers		#VALUE!			
7	No Campers		#VALUE!			
8	No Campers		#VALUE!			
9	No Campers		#VALUE!			
10	No Campers		#VALUE!			
11	0.30	0.28	0.02		0.49	0.50
12	No Campers		#VALUE!			
13	No Campers		#VALUE!			
14	No Campers		#VALUE!			
15	No Campers		#VALUE!			
16	No Campers		#VALUE!			
17	No Campers		#VALUE!			
18	0.30	0.26	0.04		0.29	0.32
19	No Campers		#VALUE!			
20	No Campers		#VALUE!			
21	No Campers		#VALUE!			
22	No Campers		#VALUE!			
23	No Campers		#VALUE!			
24	No Campers		#VALUE!			
25	No Campers		#VALUE!			
26	No Campers		#VALUE!			
27	No Campers		#VALUE!			
28	No Campers		#VALUE!			
29	No Campers		#VALUE!			
30	0.30	0.25	0.05		0.94	0.96
31	No Campers		#VALUE!			
<b>Cartridge &amp; Bag Filtration</b>					<b>Monthly Summary (Answer Yes or No)</b>	
95% of daily turbidity readings ≤ 1 NTU?				Yes	CT's met everyday? (see back)	All Cl2 residual at entry point ≥ 0.2 mg/l?
All daily turbidity readings ≤ 5 NTU?				Yes	Yes	Yes
<b>Notes: PSI = pounds per square inch</b>					<b>PRINTED NAME: Faye Strudler</b>	
<b>PSID = pounds per square inch difference (before filter - after filter)</b>					<b>SIGNATURE: Faye Strudler</b>	
<b>PSID When to Change Filter = look in manual for manufacturer's specifications when to change the filter, at what PSID.</b>					<b>DATE: 2/8/24</b>	
					<b>PHONE #: (541)822-3511</b>	
					<b>CERT #:</b>	

<sup>1</sup> Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in Daily Turbidity Reading column may not

correspond to continuous readings' maximum.

**OHA - Drinking Water Services - Surface Water Quality Data Form**

**WTP- :**

<b>System Name:</b>	<b>ID#: 41</b>	<b>Month/Year:</b>	<b>Disinfection Giardia Log Inactiv:</b>	<b>1</b>
---------------------	----------------	--------------------	--	----------

Date / Time	Minimum Cl <sub>2</sub> Residual at 1st User ( C ) <sup>2</sup>	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? <sup>2</sup>	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	<b>C X T</b>	[° C]		formula	Yes / No	[GPM]
1	No Campers	26	#VALUE!	17.8		#VALUE!	#VALUE!	
2	No Campers	26	#VALUE!	17.6		#VALUE!	#VALUE!	
3	No Campers	26	#VALUE!	17.4		#VALUE!	#VALUE!	
4	2.8	26	72.8	4.5	7.00	68.5	YES	
5	No Campers	26	#VALUE!			#VALUE!	#VALUE!	
6	No Campers	26	#VALUE!			#VALUE!	#VALUE!	
7	No Campers	26	#VALUE!			#VALUE!	#VALUE!	
8	No Campers	26	#VALUE!			#VALUE!	#VALUE!	
9	No Campers	26	#VALUE!			#VALUE!	#VALUE!	
10	No Campers	26	#VALUE!			#VALUE!	#VALUE!	
11	3.5	26	91.0	1.8	7.00	89.7	YES	
12	No Campers	26	#VALUE!			#VALUE!	#VALUE!	
13	No Campers	26	#VALUE!			#VALUE!	#VALUE!	
14	No Campers	26	#VALUE!			#VALUE!	#VALUE!	
15	No Campers	26	#VALUE!			#VALUE!	#VALUE!	
16	No Campers	26	#VALUE!			#VALUE!	#VALUE!	
17	No Campers	26	#VALUE!			#VALUE!	#VALUE!	
18	3.3	26	85.8	2.1	7.00	85.8	YES	
19	No Campers	26	#VALUE!			#VALUE!	#VALUE!	
20	No Campers	26	#VALUE!			#VALUE!	#VALUE!	
21	No Campers	26	#VALUE!			#VALUE!	#VALUE!	
22	No Campers	26	#VALUE!			#VALUE!	#VALUE!	
23	No Campers	26	#VALUE!			#VALUE!	#VALUE!	
24	No Campers	26	#VALUE!			#VALUE!	#VALUE!	
25	No Campers	26	#VALUE!			#VALUE!	#VALUE!	
26	No Campers	26	#VALUE!			#VALUE!	#VALUE!	
27	No Campers	26	#VALUE!			#VALUE!	#VALUE!	
28	No Campers	26	#VALUE!			#VALUE!	#VALUE!	
29	No Campers	26	#VALUE!			#VALUE!	#VALUE!	
30	3.3	26	85.8	3.3	7.20	85.0	YES	
31	No Campers	26	#VALUE!			#VALUE!	#VALUE!	

<sup>2</sup> If Cl<sub>2</sub> at entry point < 0.2 mg/l or CT not met, notify DWS within 24 hours.

Revised July 2018

Return by 10th of following month by email, fax, or mail to:

DWP.DMCE@odhsoha.oregon.gov; 971-673-0694; or Drinking Water Services, PO Box 14350, Portland, OR 97293-0350