

OHA - Drinking Water Services - Surface Water Quality Data Form

County: Lane

Cartridge or Bag Filtration

Month/Year: September 2022

System Name:  ID#: 41 WTP ID: TP-

| Day | PSI Before Filter | PSI After Filter | PSID    | PSID When to Change Filter | Daily Turbidity Reading [NTU] | Highest Reading of the day <sup>1</sup> [NTU] |
|-----|-------------------|------------------|---------|----------------------------|-------------------------------|---|
| 1   | No Campers        |                  | #VALUE! | 25.00                      |                               |   |
| 2   | No Campers        |                  | #VALUE! | 25.00                      |                               |   |
| 3   | No Campers        |                  | #VALUE! | 25.00                      |                               |   |
| 4   | No Campers        |                  | #VALUE! | 25.00                      |                               |   |
| 5   | No Campers        |                  | #VALUE! | 25.00                      |                               |   |
| 6   | No Campers        |                  | #VALUE! | 25.00                      |                               |   |
| 7   | No Campers        |                  | #VALUE! | 25.00                      |                               |   |
| 8   | No Campers        |                  | #VALUE! | 25.00                      |                               |   |
| 9   | No Campers        |                  | #VALUE! | 25.00                      |                               |   |
| 10  | No Campers        |                  | #VALUE! | 25.00                      |                               |   |
| 11  | No Campers        |                  | #VALUE! | 25.00                      |                               |   |
| 12  | No Campers        |                  | #VALUE! | 25.00                      |                               |   |
| 13  | No Campers        |                  | #VALUE! | 25.00                      |                               |   |
| 14  | No Campers        |                  | #VALUE! | 25.00                      |                               |   |
| 15  | No Campers        |                  | #VALUE! | 25.00                      |                               |   |
| 16  | No Campers        |                  | #VALUE! | 25.00                      |                               |   |
| 17  | No Campers        |                  | #VALUE! | 25.00                      |                               |   |
| 18  | No Campers        |                  | #VALUE! | 25.00                      |                               |   |
| 19  | No Campers        |                  | #VALUE! | 25.00                      |                               |   |
| 20  | No Campers        |                  | #VALUE! | 25.00                      |                               |   |
| 21  | No Campers        |                  | #VALUE! | 25.00                      |                               |   |
| 22  | No Campers        |                  | #VALUE! | 25.00                      |                               |   |
| 23  | No Campers        |                  | #VALUE! | 25.00                      |                               |   |
| 24  | No Campers        |                  | #VALUE! | 25.00                      |                               |   |
| 25  | No Campers        |                  | #VALUE! | 25.00                      |                               |   |
| 26  | No Campers        |                  | #VALUE! | 25.00                      |                               |   |
| 27  | No Campers        |                  | #VALUE! | 25.00                      |                               |   |
| 28  | No Campers        |                  | #VALUE! | 25.00                      |                               |   |
| 29  | No Campers        |                  | #VALUE! | 25.00                      |                               |   |
| 30  | 25.00             | 24.00            | 1.00    | 25.00                      | 0.58                          | 0.59  |
| 31  | No Campers        |                  | #VALUE! | 25.00                      |                               |   |

| Cartridge & Bag Filtration               |     | Monthly Summary (Answer Yes or No) |   |
|--|-----|------------------------------------|---|
| 95% of daily turbidity readings ≤ 1 NTU? | Yes | CT's met everyday? (see back)      | All Cl2 residual at entry point ≥ 0.2 mg/l? |
| All daily turbidity readings ≤ 5 NTU?    | Yes | Yes                                | Yes   |

|   |                                       |                     |
|---|---------------------------------------|---------------------|
| <b>Notes: PSI = pounds per square inch</b><br><b>PSID = pounds per square inch difference (before filter - after filter)</b><br><b>PSID When to Change Filter = look in manual for manufacturer's specifications when to change the filter, at what PSID.</b> | <b>PRINTED NAME: Tiffany Kingsley</b> |                     |
|   | <b>SIGNATURE: Tiffany Kingsley</b>    | <b>DATE: 4.4.24</b> |
|   | <b>PHONE #: ( 541 ) 854.0441</b>      | <b>CERT #:</b>      |

<sup>1</sup> Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in Daily Turbidity Reading column may not correspond to continuous readings' maximum.

OHA - Drinking Water Services - Surface Water Quality Data Form

WTP: -

System Name:

ID#: 41

Month/Year:

Disinfection  
Giardia Log Inactiv:

1

| Date / Time | Minimum Cl <sub>2</sub> Residual at 1st User ( C ) <sup>2</sup> | Contact Time (T) | Actual CT    | Temp  | pH   | Required CT | CT Met? <sup>2</sup> | Peak Hourly Demand Flow |
|-------------|---|------------------|--------------|-------|------|-------------|----------------------|-------------------------|
|             | [ppm or mg/L]   | [minutes]        | <b>C X T</b> | [° C] |      | formula     | Yes / No             | [GPM]                   |
| 1           | No Campers  | 26               | #VALUE!      |       |      | #VALUE!     | #VALUE!              |                         |
| 2           | No Campers  | 26               | #VALUE!      |       |      | #VALUE!     | #VALUE!              |                         |
| 3           | No Campers  | 26               | #VALUE!      |       |      | #VALUE!     | #VALUE!              |                         |
| 4           | No Campers  | 26               | #VALUE!      |       |      | #VALUE!     | #VALUE!              |                         |
| 5           | No Campers  | 26               | #VALUE!      |       |      | #VALUE!     | #VALUE!              |                         |
| 6           | No Campers  | 26               | #VALUE!      |       |      | #VALUE!     | #VALUE!              |                         |
| 7           | No Campers  | 26               | #VALUE!      |       |      | #VALUE!     | #VALUE!              |                         |
| 8           | No Campers  | 26               | #VALUE!      |       |      | #VALUE!     | #VALUE!              |                         |
| 9           | No Campers  | 26               | #VALUE!      |       |      | #VALUE!     | #VALUE!              |                         |
| 10          | No Campers  | 26               | #VALUE!      |       |      | #VALUE!     | #VALUE!              |                         |
| 11          | No Campers  | 26               | #VALUE!      |       |      | #VALUE!     | #VALUE!              |                         |
| 12          | No Campers  | 26               | #VALUE!      |       |      | #VALUE!     | #VALUE!              |                         |
| 13          | No Campers  | 26               | #VALUE!      |       |      | #VALUE!     | #VALUE!              |                         |
| 14          | No Campers  | 26               | #VALUE!      |       |      | #VALUE!     | #VALUE!              |                         |
| 15          | No Campers  | 26               | #VALUE!      |       |      | #VALUE!     | #VALUE!              |                         |
| 16          | No Campers  | 26               | #VALUE!      |       |      | #VALUE!     | #VALUE!              |                         |
| 17          | No Campers  | 26               | #VALUE!      |       |      | #VALUE!     | #VALUE!              |                         |
| 18          | No Campers  | 26               | #VALUE!      |       |      | #VALUE!     | #VALUE!              |                         |
| 19          | No Campers  | 26               | #VALUE!      |       |      | #VALUE!     | #VALUE!              |                         |
| 20          | No Campers  | 26               | #VALUE!      |       |      | #VALUE!     | #VALUE!              |                         |
| 21          | No Campers  | 26               | #VALUE!      |       |      | #VALUE!     | #VALUE!              |                         |
| 22          | No Campers  | 26               | #VALUE!      |       |      | #VALUE!     | #VALUE!              |                         |
| 23          | No Campers  | 26               | #VALUE!      |       |      | #VALUE!     | #VALUE!              |                         |
| 24          | No Campers  | 26               | #VALUE!      |       |      | #VALUE!     | #VALUE!              |                         |
| 25          | No Campers  | 26               | #VALUE!      |       |      | #VALUE!     | #VALUE!              |                         |
| 26          | No Campers  | 26               | #VALUE!      |       |      | #VALUE!     | #VALUE!              |                         |
| 27          | No Campers  | 26               | #VALUE!      |       |      | #VALUE!     | #VALUE!              |                         |
| 28          | No Campers  | 26               | #VALUE!      |       |      | #VALUE!     | #VALUE!              |                         |
| 29          | No Campers  | 26               | #VALUE!      |       |      | #VALUE!     | #VALUE!              |                         |
| 30          | 2.6   | 26               | 67.6         | 3.5   | 6.80 | 66.6        | YES                  |                         |
| 31          | No Campers  | 26               | #VALUE!      |       |      | #VALUE!     | #VALUE!              |                         |

<sup>2</sup> If Cl<sub>2</sub> at entry point < 0.2 mg/l or CT not met, notify DWS within 24 hours.

Revised July 2018

Return by 10th of following month by email, fax, or mail to:

DWP.DMCE@odhsoha.oregon.gov; 971-673-0694; or Drinking Water Services, PO Box 14350, Portland, OR 97293-0350