

OHA - Drinking Water Services - Surface Water Quality Data Form

County: Lane

Cartridge or Bag Filtration

Month/Year: July 2024

| System Name: | | WHITE BRANCH YOUTH CAMP | | ID#: | 41 | 91783 | WTP ID: | TP- |
|---|-------------------|-------------------------|---------|----------------------------|---|---|-----------------------|-----|
| Day | PSI Before Filter | PSI After Filter | PSID | PSID When to Change Filter | Daily Turbidity Reading [NTU] | Highest Reading of the day 1 [NTU] | | |
| 1 | no campers | | #VALUE! | 25.00 | | | | |
| 2 | 21.00 | 21.00 | 0.00 | 25.00 | 0.14 | 0.16 | | |
| 3 | no campers | | #VALUE! | 25.00 | | | | |
| 4 | no campers | | #VALUE! | | | | | |
| 5 | no campers | | #VALUE! | | | | | |
| 6 | no campers | | #VALUE! | | | | | |
| 7 | 21.00 | 21.00 | 0.00 | 0.19 | 0.22 | | | |
| 8 | 21.00 | 21.00 | 0.00 | 0.11 | 0.13 | | | |
| 9 | 21.00 | 21.00 | 0.00 | 0.11 | 0.13 | | | |
| 10 | 21.00 | 21.00 | 0.00 | 0.12 | 0.14 | | | |
| 11 | 21.00 | 21.00 | 0.00 | 0.08 | 0.09 | | | |
| 12 | 21.00 | 21.00 | 0.00 | 0.09 | 0.10 | | | |
| 13 | no campers | | #VALUE! | | | | | |
| 14 | 21.00 | 21.00 | 0.00 | 0.08 | 0.09 | | | |
| 15 | 21.00 | 21.00 | 0.00 | 0.08 | 0.08 | | | |
| 16 | 21.00 | 21.00 | 0.00 | 0.07 | 0.09 | | | |
| 17 | 21.00 | 21.00 | 0.00 | 0.09 | 0.10 | | | |
| 18 | 21.00 | 21.00 | 0.00 | 0.09 | 0.13 | | | |
| 19 | 21.00 | 21.00 | 0.00 | 0.07 | 0.07 | | | |
| 20 | no campers | | #VALUE! | | | | | |
| 21 | 26.00 | 25.00 | 1.00 | 0.09 | 0.10 | | | |
| 22 | 26.00 | 25.00 | 1.00 | 0.11 | 0.15 | | | |
| 23 | 26.00 | 25.00 | 1.00 | 0.09 | 0.09 | | | |
| 24 | 26.00 | 25.00 | 1.00 | 0.08 | 0.09 | | | |
| 25 | 26.00 | 25.00 | 1.00 | 0.09 | 0.11 | | | |
| 26 | 26.00 | 25.00 | 1.00 | 0.08 | 0.08 | | | |
| 27 | 26.00 | 25.00 | 1.00 | 0.12 | 0.13 | | | |
| 28 | 26.00 | 25.00 | 1.00 | 0.06 | 0.06 | | | |
| 29 | 26.00 | 25.00 | 1.00 | 0.06 | 0.07 | | | |
| 30 | 26.00 | 25.00 | 1.00 | 0.07 | 0.07 | | | |
| 31 | no campers | | #VALUE! | | | | | |
| Cartridge & Bag Filtration | | | | | Monthly Summary (Answer Yes or No) | | | |
| 95% of daily turbidity readings ≤ 1 NTU? | | | | YES | CT's met everyday? (see back) | All Cl2 residual at entry point ≥ 0.2 mg/l? | | |
| All daily turbidity readings ≤ 5 NTU? | | | | YES | YES | YES | | |
| Notes: PSI = pounds per square inch | | | | | PRINTED NAME: TIFFANY KINGSLEY | | | |
| PSID = pounds per square inch difference (before filter - after filter) | | | | | SIGNATURE: Tiffany Kingsley | | DATE: 8.1.2024 | |
| PSID When to Change Filter = look in manual for manufacturer's specifications when to change the filter, at what PSID. | | | | | PHONE #: (541) 854-0441 | | CERT #: | |

1 Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in Daily Turbidity Reading column may not correspond to continuous readings' maximum.

OHA - Drinking Water Services - Surface Water Quality Data Form

WTP- :

| | | | | |
|--------------|---------|-------------|--|---|
| System Name: | ID#: 41 | Month/Year: | Disinfection <i>Giardia</i> Log Inactiv: | 1 |
|--------------|---------|-------------|--|---|

| Date / Time | Minimum Cl2 Residual at 1st User (C) 2 | Contact Time (T) | Actual CT | Temp | pH | Required CT | CT Met? 2 | Peak Hourly Demand Flow |
|-------------|--|------------------|-----------|-------|------|-------------|-----------|-------------------------|
| | [ppm or mg/L] | [minutes] | C X T | [° C] | | formula | Yes / No | [GPM] |
| 1 | no campers | 26 | #VALUE! | | | #VALUE! | #VALUE! | |
| 2 | 1.6 | 26 | 41.6 | 14.3 | 7.60 | 38.2 | YES | |
| 3 | no campers | 26 | #VALUE! | | | #VALUE! | #VALUE! | |
| 4 | no campers | 26 | #VALUE! | | | #VALUE! | #VALUE! | |
| 5 | no campers | 26 | #VALUE! | | | #VALUE! | #VALUE! | |
| 6 | no campers | 26 | #VALUE! | | | #VALUE! | #VALUE! | |
| 7 | 2 | 26 | 52.0 | 15.9 | 7.50 | 34.6 | YES | |
| 8 | 1.5 | 26 | 39.0 | 16.1 | 7.50 | 32.3 | YES | |
| 9 | 2 | 26 | 52.0 | 16.4 | 7.70 | 36.0 | YES | |
| 10 | 2 | 26 | 52.0 | 16.7 | 7.50 | 32.8 | YES | |
| 11 | 1.8 | 26 | 46.8 | 16.8 | 7.50 | 31.9 | YES | |
| 12 | 1.8 | 26 | 46.8 | 16.6 | 7.50 | 32.3 | YES | |
| 13 | no campers | 26 | #VALUE! | | | #VALUE! | #VALUE! | |
| 14 | 1.5 | 26 | 39.0 | 16.2 | 7.50 | 32.0 | YES | |
| 15 | 1.5 | 26 | 39.0 | 16.2 | 7.50 | 32.0 | YES | |
| 16 | 1.5 | 26 | 39.0 | 16.2 | 7.50 | 32.0 | YES | |
| 17 | 1.5 | 26 | 39.0 | 16.6 | 7.50 | 31.2 | YES | |
| 18 | 1.5 | 26 | 39.0 | 16.9 | 7.50 | 30.6 | YES | |
| 19 | 2 | 26 | 52.0 | 16.2 | 7.60 | 35.2 | YES | |
| 20 | no campers | 26 | #VALUE! | | | #VALUE! | #VALUE! | |
| 21 | 2 | 26 | 52.0 | 18.1 | 7.50 | 29.9 | YES | |
| 22 | 1.5 | 26 | 39.0 | 17.2 | 7.50 | 30.0 | YES | |
| 23 | 1.5 | 26 | 39.0 | 18.9 | 7.50 | 26.8 | YES | |
| 24 | 1.5 | 26 | 39.0 | 16.8 | 7.50 | 30.8 | YES | |
| 25 | 1.5 | 26 | 39.0 | 16.5 | 7.50 | 31.4 | YES | |
| 26 | 1.5 | 26 | 39.0 | 15.8 | 7.50 | 32.9 | YES | |
| 27 | 1.5 | 26 | 39.0 | 16.2 | 7.60 | 33.2 | YES | |
| 28 | 2 | 26 | 52.0 | 15.6 | 7.60 | 36.6 | YES | |
| 29 | 1.8 | 26 | 46.8 | 16.3 | 7.50 | 32.9 | YES | |
| 30 | 2.4 | 26 | 62.4 | 15.9 | 7.50 | 36.2 | YES | |
| 31 | no campers | 26 | #VALUE! | | | #VALUE! | #VALUE! | |

2 If Cl2 at entry point < 0.2 mg/l or CT not met, notify DWS within 24 hours.

Revised July 2018

Return by 10th of following month by email, fax, or mail to:
 DWP.DMCE@odhsoha.oregon.gov; 971-673-0694; or Drinking Water Services, PO Box 14350, Portland, OR 97293-0350