

**OHA - Drinking Water Services - Turbidity Monitoring Report Form**  
**Cartridge or Bag Filtration**

County: Lane  
 Month/Year: Nov, 2022

System Name: Camp Baker BSA ID# 41-91786 WTP ID:         

DAY	PSI Before Filter	PSI After Filter	PSID	PSID When to Change Filter	Daily Turbidity Reading [NTU]	Highest Reading of the Day <sup>1</sup> [NTU]
1	34	37	(3)	25		.43
2	30	32	(2)			.40
3	31	34	(3)			.33
4	33	36	(3)			.50
5	39	42	(3)			.89
6	35	37	(2)			.04
7	36	38	(2)			.23
8	32	34	(2)			.31
9	30	32	(2)			.49
10	37	39	(2)			.40
11	34	36	(2)			.19
12	24	27	(3)			.32
13	27	30	(3)			.28
14	37	39	(2)			.19
15	36	38	(2)			.42
16	36	39	(3)			.25
17	36	39	(3)			.41
18	29	32	(3)			.35
19	36	38	(2)			.52
20	25	29	(4)			.38
21	29	32	(3)			.29
22	35	38	(3)			.44
23	35	38	(3)			.44
24	} camp closed					
25	} camp closed					
26	} camp closed					
27	35	37	(2)			.77
28	29	31	(2)			.35
29	23	27	(4)			.31
30	25	28	(3)			.29
31						

215P  
 940 A  
 430P  
 220P  
 845 A  
 1235P  
 525P  
 1040A  
 1125A  
 910A  
 1255P  
 315P  
 1125A  
 940 A  
 120P  
 220P  
 715P  
 1125A  
 220P  
 1255P  
 1015 A  
 415P  
 1025A  
  
~~105 AM~~  
 105 AM  
 1115 A  
 515P  
 4P

<b>Cartridge Filtration Monthly Summary</b>		<b>Monthly Summary (Answer Yes or No)</b>	
95% of daily turbidity readings ≤ 1 NTU? All daily turbidity readings ≤ 5 NTU?	<input checked="" type="radio"/> Yes / <input type="radio"/> No <input type="radio"/> Yes / <input checked="" type="radio"/> No	CT's met everyday? (see back) <input checked="" type="radio"/> Yes / <input type="radio"/> No	All Cl <sub>2</sub> residual at entry point ≥ 0.2 mg/l? <input checked="" type="radio"/> Yes / <input type="radio"/> No
Notes: PSI = pounds per square inch PSID = pounds per square inch difference (before filter - after filter) PSID When to Change Filter = Manufacturer's recommendation; may need to look in manual for manufacturer's specifications when to change the filter, at what PSID.		PRINTED NAME: <u>Stan Anderson</u>	
		SIGNATURE: <u>[Signature]</u>	DATE: <u>11-30-22</u>
		PHONE #: <u>(541) 997-3526</u>	CERT #: <u>N/A</u>

<sup>1</sup> Including continuous turbidity data, if applicable, for optimization recording purposes. Compliance values in "Daily Turbidity Reading" Column may not correspond to continuous readings' maximum.

# OHA - Drinking Water Program - Surface Water Quality Data Form

System Name: **Camp Baker B.S.A** ID #41: **91786** WTP: Month/Year: **Nov. 2022**

Date / Time	Minimum Cl <sub>2</sub> Residual at 1 <sup>st</sup> User (C) <sup>2</sup>	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? <sup>2</sup>	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	CXT	[°C]		Use tables	Yes / No	[GPM]
1/	2.50	45	112.50	16.6	6.2	24	y	12.1
2/	2.43		109.35	15.2	6.6	29	y	
3/	1.00		45.0	15.1	6.0	18	y	
4/	2.50		112.50	15.2	6.4	24	y	
5/	2.45		110.25	16.2	6.0	24	y	
6/	.61		27.45	15.8	5.4	17	y	
7/	.82		36.9	15.2	5.9	18	y	
8/	.60		27.0	15.0	5.9	17	y	
9/	1.50		67.5	12.9	6.0	28	y	
10/	1.27		57.15	14.8	5.7	27	y	
11/	2.03		91.35	15.2	6.4	23	y	
12/	2.50		112.50	16.5	6.2	24	y	
13/	1.58		71.10	15.0	5.9	19	y	
14/	2.22		99.9	13.1	5.9	30	y	
15/	2.10		94.5	15.0	7.0	28	y	
16/	1.44		64.8	12.9	6.7	40	y	
17/	1.02		45.9	15.4	6.9	25	y	
18/	1.65		74.25	13.5	6.2	34	y	
19/	2.26		101.7	14.3	6.2	36	y	
20/	.84		37.8	14.2	6.2	31	y	
21/	.87		39.15	13.4	6.0	26	y	
22/	2.09		94.05	12.0	6.6	42	y	
23/	2.50		112.50	12.5	5.9	31	y	
24/	} camp closed							
25/								
26/								
27/	1.65		74.25	13.8	6.8	41	y	
28/	1.57		70.65	11.7	5.9	28	y	
29/	2.50		112.50	17.3	6.2	24	y	
30/	2.50		112.50	17.1	6.3	24	y	
31/								

215P  
940A  
430P  
220P  
845A  
1235P  
525P  
1040A  
1125A  
910A  
1255P  
315P  
1125A  
940A  
120P  
220P  
715P  
1125A  
220P  
1255P  
1015A  
415P  
1025A  
  
105P  
1125A  
515P  
4P

If Cl<sub>2</sub> at entry point < 0.2 mg/l, OR CT not met, notify DWS within 24 hours. Revised October 2013  
 Download form at: [public.health.oregon.gov/HealthyEnvironments/DrinkingWater/Monitoring/Documents/turb-cartridge.pdf](http://public.health.oregon.gov/HealthyEnvironments/DrinkingWater/Monitoring/Documents/turb-cartridge.pdf)