

OHA - Drinking Water Services - Turbidity Monitoring Report Form

Cartridge or Bag Filtration

County: Lane

Month/Year: June 2025

System Name: <u>Camp Baker BSA</u>		ID# <u>41-91786</u>		WTP ID: <u> </u>		
DAY	PSI Before Filter	PSI After Filter	PSID	PSID When to Change Filter	Daily Turbidity Reading (NTU)	Highest Reading of the Day (NTU)
1	16	18	(2)	25		.22
2	16	18	(2)			.24
3	16	17	(1)			.23
4	16	17	(1)			.16
5	16	17	(1)			.20
6	17	18	(1)			.64
7	16	18	(2)			.18
8	16	18	(2)			.35
9	15	17	(2)			.17
10	17	18	(1)			.45
11	16	18	(2)			.69
12	16	18	(2)			.20
13	17	18	(1)			.24
14	17	18	(1)			.27
15	16	18	(2)			.91
16	17	18	(1)			.24
17	17	18	(1)			.55
18	16	17	(1)			.48
19	17	17	—			.31
20	17	17	—			.41
21	18	17	1			.97
22	18	17	1			.68
23	26	25	1			.41
24	17	17	—			.39
25	9	7	2			.71
26	10	8	2			.46
27	10	7	3			.75
28	10	7	3			.27
29	10	6	4			.33
30	10	7	3			.23
31						

2030 A
1145 A
335 P
11 A
1220 P
1535 A
1205 P
130 P
415 P
1115 A
515 P
1145 A
1005 A
1120 A
340 P
1120 A
1110 A
630 P
430 P
305 P
930 A
1135 A
855 A
620 P
980 A
945 A
1010 A
905 A
105 P
1125 A

Cartridge Filtration Monthly Summary		Monthly Summary (Answer Yes or No)	
95% of daily turbidity readings ≤ 1 NTU?	Yes / No	CT's met everyday? (see back)	All Cl ₂ residual at entry point ≥ 0.2 mg/l?
All daily turbidity readings ≤ 5 NTU?	Yes / No	Yes / No	Yes / No
Notes: PSI = pounds per square inch PSID = pounds per square inch difference (before filter - after filter) PSID When to Change Filter = Manufacturer's recommendation; may need to look in manual for manufacturer's specifications when to change the filter, at what PSID.		PRINTED NAME: <u>Stan Anderson</u> SIGNATURE: <u>[Signature]</u> DATE: <u>6/30/25</u> PHONE #: <u>(541) 997-3526</u> CERT #: <u>N/A</u>	

Including continuous turbidity data, if applicable, for optimization recording purposes. Compliance values in 'Daily Turbidity Reading' Column may not correspond to continuous readings' maximum.

OHA - Drinking Water Program - Surface Water Quality Data Form

System Name: **Camp Baker BSA** ID #41: **91786** WTP: Month/Year: **June 2005**

Date / Time	Minimum Cl ₂ Residual at 1 st User (C) ²	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ²	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	CXT	[°C]		Use tables	Yes / No	[GPM]
1/	2.50	45	112.50	17.5	5.8	20	y	120.1
2/	2.50		112.50	17.4	5.8	20	y	
3/	2.50		112.50	18.0	5.7	20	y	
4/	2.50		112.50	17.8	5.8	20	y	
5/	2.50		112.50	17.6	5.7	20	y	
6/	2.50		112.50	17.6	5.9	20	y	
7/	2.50		112.50	17.4	5.6	20	y	
8/	2.50		112.50	17.5	5.7	20	y	
9/	2.50		112.50	17.7	5.8	20	y	
10/	2.50		112.50	17.3	5.8	20	y	
11/	2.50		112.50	17.4	5.9	20	y	
12/	2.50		112.50	17.3	5.8	20	y	
13/	2.50		112.50	17.6	5.9	20	y	
14/	2.50		112.50	17.2	5.9	20	y	
15/	2.50		112.50	17.5	5.8	20	y	
16/	2.50		112.50	17.5	5.6	20	y	
17/	2.50		112.50	16.8	6.4	24	y	
18/	2.50		112.50	16.9	5.6	20	y	
19/	2.50		112.50	17.6	5.5	20	y	
20/	2.50		112.50	17.6	5.6	20	y	
21/	2.50		112.50	16.8	6.3	24	y	
22/	2.50		112.50	17.6	5.6	20	y	
23/	0.53		23.85	18.9	5.5	17	y	
24/	0.82		36.9	17.1	5.9	18	y	
25/	2.50		112.50	16.3	6.2	24	y	
26/	2.26		101.7	19.1	5.3	20	y	
27/	2.50		112.50	16.8	5.8	20	y	
28/	2.50		112.50	17.9	6.0	20	y	
29/	2.50		112.50	17.8	5.8	20	y	
30/	2.50		112.50	17.8	6.2	24	y	
31/								

water issue - Big leak in system

1030A
1145A
335P
11A
1220A
1035A
1205P
130P
415P
1115A
515P
1145A
1005A
1120A
340P
1120A
1110A
630P
430P
305P
930A
1135A
855A
620P
950P
245A
1010A
905A
105P
1125A

If Cl₂ at entry point < 0.2 mg/L, OR CT not met, notify DWS within 24 hours. Revised October 2013
Download form at: public.health.oregon.gov/HealthyEnvironments/DrinkingWater/Monitoring/Documents/turb-cartridge.pdf