

## Oregon DHS - Drinking Water Program – Turbidity Monitoring Report Form

System Name: Tilikum Retreat Center ID #: 41 91967 Month/Year: December 2025

DAY	12 AM (NTU)	4 AM (NTU)	8 AM (NTU)	NOON (NTU)	4 PM (NTU)	8 PM (NTU)	Highest Reading (NTU)	Peak Hourly Flow (GPM)
1							0.33	5.5
2							0.35	
3							0.45	
4							0.43	
5							0.40	
6							0.35	
7							0.31	
8							0.21	
9							0.19	
10							0.17	
11							0.20	
12							0.20	
13							0.31	
14							0.40	
15							0.41	
16							0.36	
17							0.29	
18							0.17	
19							0.22	
20							0.26	
21							0.26	
22							0.21	
23							0.26	
24							0.30	
25							0.67	
26							0.90	
27							0.60	
28							0.30	
29							0.43	
30							0.43	
31							0.44	

<b>Conventional or Direct Filtration</b>	<b>Monthly Summary (Answer Yes or No)</b>		
95% of turbidity readings ≤ 0.3 NTU? <b>Yes / No</b>	CT's met everyday? (see back) <b>Yes / No</b>	All Cl <sub>2</sub> residual at entry point ≥ 0.2 mg/l? <b>Yes / No</b>	Cl <sub>2</sub> residual measured in 95% of distribution samples? <b>Yes / No</b>
All turbidity readings < 1 NTU? <b>Yes / No</b>			
All turbidity readings < IFE triggers? <b>Yes / No</b> <sup>1</sup>			
- OR -	<b>PRINTED NAME:</b> <u>Justin Adsit</u>		
<b>Slow Sand/Cartridge/Membrane/DE Filtration</b>	<b>SIGNATURE:</b> <u>Justin Adsit</u>	<b>DATE:</b> <u>1/5/26</u>	
95% of turbidity readings ≤ 1 NTU? <b>Yes / No</b>	<b>PHONE #:</b> <u>(541) 224 2822</u>	<b>CERT #:</b>	
All turbidity readings < 5 NTU? <b>Yes / No</b>			

<sup>1</sup> IFE = Individual Filter Effluent

## Oregon DHS - Drinking Water Program – Surface Water Quality Data Form

System Name:

Tilikum Retreat Center

ID #: 41

91967

Month/Year:

December, 2025

Date / Time	Minimum Cl <sub>2</sub> Residual at 1 <sup>st</sup> User (C)	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met?
	ppm or mg/L	minutes	C X T	°C		Use tables	Yes / No
1/	1.0	210	210	8.2	7.8	72	
2/	1.0		210	8.7	7.8	72	
3/	0.8		168	7.8	7.9	70	
4/	0.8		168	9.6	7.9	70	
5/	0.8		168	10.4	8.0	53	
6/	0.8		168	10.4	7.9	53	
7/	0.8		168	9.7	7.8	70	
8/	0.8		168	11.0	7.7	53	
9/	0.8		168	11.4	7.7	53	
10/	0.8		168	11.6	7.9	53	
11/	0.8		168	10.7	7.8	53	
12/	0.8		168	9.6	7.8	70	
13/	0.8		168	9.9	7.8	70	
14/	0.8		168	10.2	7.8	53	
15/	0.8		168	10.5	7.8	53	
16/	0.8		168	10.2	7.8	53	
17/	0.8		168	10.7	7.8	53	
18/	0.8		168	10.9	7.8	53	
19/	0.8		168	9.8	7.8	70	
20/	0.8		168	9.3	7.7	70	
21/	1.0		210	8.6	7.7	72	
22/	1.0		210	8.7	7.6	72	
23/	1.0		210	8.5	7.7	72	
24/	1.0		210	8.3	7.8	72	
25/	1.0		210	8.6	7.7	72	
26/	1.0		210	9.0	7.7	72	
27/	1.0		210	6.8	7.7	72	
28/	1.0		210	6.9	7.7	72	
29/	1.0		210	5.7	7.8	72	
30/	1.0		210	5.6	7.8	72	
31/	1.0		210	5.8	7.8	72	