

Oregon DHS - Drinking Water Program – Turbidity Monitoring Report Form

System Name: Tilikum Retreat Center ID #: 41 91967 Month/Year: January / 2026

DAY	12 AM (NTU)	4 AM (NTU)	8 AM (NTU)	NOON (NTU)	4 PM (NTU)	8 PM (NTU)	Highest Reading (NTU)	Peak Hourly Flow (GPM)
1							0.34	5.5
2							0.24	
3							0.27	
4							0.31	
5							0.30	
6							0.24	
7							0.24	
8							0.25	
9							0.25	
10							0.21	
11							0.21	
12							0.22	
13							0.26	
14							0.25	
15							0.22	
16							0.23	
17							0.23	
18							0.21	
19							0.22	
20							0.23	
21							0.27	
22							0.31	
23							0.29	
24							0.28	
25							0.23	
26							0.22	
27							0.22	
28							0.20	
29							0.21	
30							0.23	
31							0.27	

Conventional or Direct Filtration	Monthly Summary (Answer Yes or No)		
95% of turbidity readings ≤ 0.3 NTU? Yes / No	CT's met everyday? (see back) Yes / No	All Cl ₂ residual at entry point ≥ 0.2 mg/l? Yes / No	Cl ₂ residual measured in 95% of distribution samples? Yes / No
All turbidity readings < 1 NTU? Yes / No			
All turbidity readings < IFE triggers? Yes / No ¹			
- OR -	PRINTED NAME: <u>Justin Adsit</u>		
Slow Sand/Cartridge/Membrane/DE Filtration	SIGNATURE: <u>Justin Adsit</u>	DATE:	
95% of turbidity readings ≤ 1 NTU? Yes / No	PHONE #: <u>(541) 224-2822</u>	CERT #:	
All turbidity readings < 5 NTU? Yes / No			

¹ IFE = Individual Filter Effluent

Oregon DHS - Drinking Water Program – Surface Water Quality Data Form

System Name: Tilikum Retreat Center

ID #: 41 9196 7

Month/Year: January / 2026

Date / Time	Minimum Cl ₂ Residual at 1 st User (C)	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met?
	ppm or mg/L	minutes	CXT	°C		Use tables	Yes / No
1/	1.2	210	252	7.1	7.7	74	
2/	1.2		252	7.6	7.8	74	
3/	1.2		252	8.1	7.8	74	
4/	1.2		252	6.5	7.9	74	
5/	1.2		252	7.2	7.8	74	
6/	1.2		252	7.3	7.7	74	
7/	1.2		252	6.9	7.7	74	
8/	1.2		252	5.2	7.8	74	
9/	1.2		252	7.0	7.7	74	
10/	1.2		252	6.9	7.7	74	
11/	1.2		252	6.8	7.7	74	
12/	1.2		252	5.3	7.7	74	
13/	1.2		252	4.5	7.7	104	
14/	1.2		252	5.8	7.8	74	
15/	1.2		252	7.5	7.8	74	
16/	1.2		252	7.6	7.8	74	
17/	1.2		252	5.7	7.8	74	
18/	1.2		252	5.2	7.8	74	
19/	1.2		252	4.6	7.8	104	
20/	1.2		252	6.2	7.8	74	
21/	1.2		252	6.8	7.8	74	
22/	1.2		252	4.6	7.8	104	
23/	1.2		252	5.7	7.8	74	
24/	1.2		252	6.2	7.8	74	
25/	1.2		252	6.4	7.8	74	
26/	1.2		252	3.6	7.8	104	
27/	1.4		294	5.1	7.8	76	
28/	1.4		294	6.3	7.8	76	
29/	1.4		294	6.4	7.8	76	
30/	1.2		252	6.7	7.8	74	
31/	1.2		252	6.2	7.8	74	