

## Oregon DHS - Drinking Water Program – Turbidity Monitoring Report Form

System Name: Tilikum Retreat Center ID #: 41 91967 Month/Year: Feb. 2026

DAY	12 AM (NTU)	4 AM (NTU)	8 AM (NTU)	NOON (NTU)	4 PM (NTU)	8 PM (NTU)	Highest Reading (NTU)	Peak Hourly Flow (GPM)
1							0.33	5.5
2							0.32	
3							0.35	
4							0.29	
5							0.29	
6							0.20	
7							0.14	
8							0.17	
9							0.21	
10							0.20	
11							0.16	
12							0.16	
13							0.18	
14							0.20	
15							0.25	
16							0.24	
17							0.22	
18							0.20	
19							0.18	
20							0.18	
21							0.21	
22							0.22	
23							0.24	
24							0.28	
25							0.26	
26							0.25	
27							0.26	
28							0.27	
29								
30								
31								

<b>Conventional or Direct Filtration</b>	<b>Monthly Summary (Answer Yes or No)</b>		
95% of turbidity readings $\leq$ 0.3 NTU? <b>Yes / No</b>	CT's met everyday? (see back) <b>Yes / No</b>	All Cl <sub>2</sub> residual at entry point $\geq$ 0.2 mg/l? <b>Yes / No</b>	Cl <sub>2</sub> residual measured in 95% of distribution samples? <b>Yes / No</b>
All turbidity readings < 1 NTU? <b>Yes / No</b>			
All turbidity readings < IFE triggers? <b>Yes / No</b> <sup>1</sup>			
<b>- OR -</b>	<b>PRINTED NAME:</b> <u>Justin Adsit</u>		
<b>Slow Sand/Cartridge/Membrane/DE Filtration</b>	<b>SIGNATURE:</b> <u>Justin Adsit</u>	<b>DATE:</b> <u>3/10/26</u>	
95% of turbidity readings $\leq$ 1 NTU? <b>Yes / No</b>	<b>PHONE #:</b> <u>(541) 224 2822</u>		<b>CERT #:</b>
All turbidity readings < 5 NTU? <b>Yes / No</b>			

<sup>1</sup> IFE = Individual Filter Effluent

## Oregon DHS - Drinking Water Program – Surface Water Quality Data Form

System Name: Tilikum Retreat Center ID #: 41 91967 Month/Year: Feb, 2026

Date / Time	Minimum Cl <sub>2</sub> Residual at 1 <sup>st</sup> User (C)	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met?
	ppm or mg/L	minutes	<b>C X T</b>	°C		Use tables	Yes / No
1/	1.4	210	294	7.2	7.8	76	Yes
2/	1.4		294	7.1	7.8	76	
3/	1.4		294	7.6	7.8	76	
4/	1.2		252	7.9	7.8	74	
5/	1.2		252	8.1	7.8	74	
6/	1.2		252	8.6	7.8	74	
7/	1.2		252	8.9	7.7	74	
8/	1.2		252	8.4	7.7	74	
9/	1.2		252	9.0	7.8	74	
10/	1.2		252	10.2	7.8	55	
11/	1.2		252	10.6	7.8	55	
12/	1.2		252	6.8	7.8	74	
13/	1.4		294	7.7	7.8	76	
14/	1.4		294	7.2	7.8	76	
15/	1.4		294	7.4	7.8	76	
16/	1.4		294	5.8	7.9	76	
17/	1.4		294	6.6	7.8	76	
18/	1.4		294	5.9	7.8	76	
19/	1.2		252	5.3	7.8	74	
20/	1.2		252	6.2	7.8	74	
21/	1.2		252	8.4	7.8	74	
22/	1.2		252	6.1	7.8	74	
23/	1.2		252	6.3	7.8	74	
24/	1.2		252	6.7	7.8	74	
25/	1.2		252	7.2	7.8	74	
26/	1.2		252	7.5	7.8	74	
27/	1.2		252	7.7	7.8	74	
28/	1.2		252	7.1	8.1	74	
29/							
30/							
31/							