

Oregon DHS - Drinking Water Program – Turbidity Monitoring Report Form

System Name: Tilikum Retreat Center **ID #:** 41 91967 **Month/Year:** March 2026

DAY	12 AM (NTU)	4 AM (NTU)	8 AM (NTU)	NOON (NTU)	4 PM (NTU)	8 PM (NTU)	Highest Reading (NTU)	Peak Hourly Flow (GPM)		
1							0.32	5.5		
2							0.33			
3							0.26			
4							0.22			
5							0.18			
6							0.23			
7							0.21			
8							0.23			
9							0.20			
10							0.20			
11							0.21			
12							0.21			
13							0.21			
14							0.21			
15							0.21			
16							0.27			
17							0.28			
18							0.30			
19							0.22			
20	<u>Offline</u>									
21							0.29			
22							0.31			
23							0.31			
24							0.38			
25							0.48			
26							0.36			
27							0.31			
28							0.32			
29							0.32			
30							0.24			
31							0.21			

Conventional or Direct Filtration	Monthly Summary (Answer Yes or No)		
95% of turbidity readings ≤ 0.3 NTU? Yes / No All turbidity readings < 1 NTU? Yes / No All turbidity readings < IFE triggers? Yes / No ¹	CT's met everyday? (see back) Yes / No	All Cl ₂ residual at entry point ≥ 0.2 mg/l? Yes / No	Cl ₂ residual measured in 95% of distribution samples? Yes / No
- OR -	PRINTED NAME: <u>Justin Adsit</u>		
Slow Sand/Cartridge/Membrane/DE Filtration	SIGNATURE: <u>Justin Adsit</u>	DATE: <u>4-10-26</u>	
95% of turbidity readings ≤ 1 NTU? Yes / No All turbidity readings < 5 NTU? Yes / No	PHONE #: <u>(541) 224 2822</u>		CERT #:

¹ IFE = Individual Filter Effluent

Oregon DHS - Drinking Water Program – Surface Water Quality Data Form

System Name: Tilikum Retreat Center ID #: 41 91967 Month/Year: March 2026

Date / Time	Minimum Cl ₂ Residual at 1 st User (C)	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met?
	ppm or mg/L	minutes	C X T	°C		Use tables	<u>Yes</u> / No
1/	1.2	210	252	8.4	7.9	74	
2/	1.2		252	8.1	7.9	74	
3/	1.2		252	9.7	7.9	74	
4/	1.2		252	12.3	7.9	55	
5/	1.2		252	9.4	7.8	74	
6/	1.2		252	9.6	7.8	74	
7/	1.2		252	9.2	7.8	74	
8/	1.2		252	7.9	7.9	74	
9/	1.2		252	8.3	7.8	74	
10/	1.2		252	8.7	7.8	74	
11/	1.2		252	9.6	7.9	74	
12/	1.2		252	7.5	7.8	74	
13/	1.2		252	8.2	7.8	74	
14/	1.2		252	8.3	7.8	74	
15/	1.2		252	9.4	7.8	74	
16/	1.2		252	11.9	7.8	55	
17/	1.0		210	13.2	7.8	54	
18/	1.0		210	14.5	7.8	54	
19/	1.0		210	13.1	7.9	54	
20/							
21/	1.0		210	9.8	7.8	72	
22/	0.8		168	9.6	7.7	70	
23/	1.0		210	9.7	7.8	72	
24/	1.0		210	9.2	7.8	72	
25/	1.0		210	8.6	7.9	72	
26/	1.0		210	10.0	7.8	54	
27/	1.0		210	10.6	7.8	54	
28/	1.0		210	11.4	7.8	54	
29/	1.0		210	11.9	7.8	54	
30/	1.0		210	10.5	7.9	54	
31/	1.0		210	10.3	7.9	54	