

# OHA - Drinking Water Program - Turbidity Monitoring Report Form County: Josephine Cartridge or Bag Filtration

System Name: **NPS OREGON CAVES NATL MON ID #: OR4191998** WTP: **WTP-A** Month/Year: **11/2022**

DAY	PSI Before Filter	PSI After Filter	PSID	PSID When to Change Filter	Daily Turbidity Reading [NTU]	Highest Reading of the Day <sup>1</sup> [NTU]
1	42	23	19	25	.072	.10
2	42	29	13	25	.039	.77
3	42	24	18	25	.043	1.0
4	42	32	10	25	.050	1.0
5	41	27	14	25	.053	.47
6	41	25	16	25	.058	.10
7	41	23	18	25	.060	1.0
8	41	20	21	25	.065	1.0
9	41	31	7	25	.040	.39
10	42	29	13	25	.054	.10
11	42	21	21	25	.067	.10
12	42	33	9	25	.039	.63
13	42	30	12	25	.042	1.0
14	42	24	18	25	.046	.10
15	42	19	23	25	.054	.10
16	42	28	14	25	.075	.10
17	42	24	18	25	.048	.10
18	42	19	23	25	.056	.10
19	42	31	8	25	.072	1.0
20	42	31	11	25	.048	.10
21	42	28	14	25	.058	.10
22	42	26	16	25	.069	.10
23	42	30	12	25	.041	.10
24	42	28	14	25	.056	1.0
25	42	28	14	25	.046	.10
26	42	30	12	25	.035	1.0
27	42	31	11	25	.058	1.0
28	42	30	12	25	.038	.10
29	42	28	14	25	.046	.10
30	42	30	12	25	.040	.10
31						

<b>Cartridge Filtration</b>	<b>Monthly Summary (Answer Yes or No)</b>	
95% of daily turbidity readings ≤ 1 NTU? All daily turbidity readings ≤ 5 NTU?	Yes / No <input checked="" type="checkbox"/> Yes / <input type="checkbox"/> No	CT's met everyday? (see back) Yes / No <input checked="" type="checkbox"/> Yes / <input type="checkbox"/> No
		All Cl <sub>2</sub> residual at entry point ≥ 0.2 mg/l? Yes / No <input checked="" type="checkbox"/> Yes / <input type="checkbox"/> No
<b>Notes:</b> PSI = pounds per square inch PSID = pounds per square inch difference (before filter - after filter) PSID When to Change Filter = Manufacturer's recommendation; may need to look in manual for manufacturer's specifications when to change the filter, at what PSID.	<b>PRINTED NAME:</b> David M. John	
	<b>SIGNATURE:</b> <i>David M. John</i>	<b>DATE:</b> 11.30.2022
	<b>PHONE #:</b> (541) 592.2100 Ext 2256	<b>CERT #:</b> D-09445

<sup>1</sup> Including continuous turbidity data, if applicable, for optimization recording purposes. Compliance values in "Daily Turbidity".

OHA - Drinking Water Program – Surface Water Quality Data Form

NPS OREGON CAVES NATL MON ID #: OR4191998 WTP-: WTP-A Month/Year: 11/2022

Date / Time	Minimum Cl <sub>2</sub> Residual at 1 <sup>st</sup> User (C) <sup>2</sup>	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? <sup>2</sup>	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	CXT	[°C]		Use tables	Yes / No	[GPM]
1/1000	1.22	43	52.46	12	7.7	28	YES	10.65
2/1000	1.25	43	53.75	12	7.7	28	YES	8.54
3/1000	1.34	43	57.62	12	7.7	28	YES	11.67
4/1000	1.19	43	51.17	12	7.7	28	YES	53.96
5/1000	1.18	43	50.74	12	7.7	28	YES	6.46
6/1000	1.15	43	49.45	12	7.7	28	YES	5.42
7/1000	1.13	43	48.59	12	7.7	28	YES	4.17
8/1000	1.12	43	48.16	12	7.7	28	YES	3.96
9/1000	1.09	43	46.87	12	7.7	28	YES	4.17
10/1000	1.01	43	43.43	12	7.7	28	YES	41.46
11/1000	.94	43	40.42	12	7.7	27	YES	30
12/1000	.89	43	38.27	12	7.7	27	YES	7.50
13/1000	.83	43	35.69	12	7.7	27	YES	10
14/1000	.88	43	37.84	12	7.7	27	YES	13.33
15/1000	.90	43	38.70	12	7.7	27	YES	12.29
16/1000	.92	43	39.56	12	7.7	27	YES	16.88
17/1000	.94	43	40.42	12	7.7	27	YES	13.55
18/1000	.97	43	41.71	12	7.7	27	YES	14.79
19/1005	.99	43	42.57	12	7.7	27	YES	9.58
20/1000	1.07	43	46.01	12	7.7	28	YES	12.50
21/1000	1.14	43	49.02	12	7.7	28	YES	11.88
22/1000	1.22	43	52.46	12	7.7	28	YES	14.38
23/1000	1.25	43	53.75	12	7.7	28	YES	10.41
24/1000	1.02	43	43.86	12	7.7	28	YES	6.25
25/1000	.90	43	38.70	12	7.7	27	YES	12.50
26/1000	.99	43	42.57	12	7.7	27	YES	7.29
27/1000	.94	43	40.42	12	7.7	27	YES	11.45
28/1000	1.02	43	43.86	12	7.7	28	YES	10.20
29/1000	.90	43	38.70	12	7.7	27	YES	30.62
30/1000	.92	43	39.56	12	7.7	27	YES	13.54
31/								

<sup>2</sup> If Cl<sub>2</sub> at entry point < 0.2 mg/l, OR CT not met, notify DWP by end of next business day.

