

OHA - Drinking Water Program - Turbidity Monitoring Report Form County: Josephine

Cartridge or Bag Filtration

System Name: NPS OREGON CAVES NATL MON ID #: OR4191998 WTP: WTP-A Month/Year: August 2024

DAY	PSI Before Filter	PSI After Filter	PSID	PSID When to Change Filter	Daily Turbidity Reading [NTU]	Highest Reading of the Day [NTU]
1	42	32	10	25	0.052	0.10
2	43	30	13	25	0.051	0.10
3	42	24	13	25	0.061	0.10
4	42	30	12	25	0.055	0.10
5	42	28	14	25	0.056	0.10
6	42	30	12	25	0.050	0.10
7	41	30	11	25	0.057	0.10
8	41	28	13	25	0.066	0.10
9	41	30	11	25	0.062	0.10
10	41	32	9	25	0.065	0.10
11	43	30	13	25	0.060	0.11
12	43	28	15	25	0.069	0.11
13	43	30	13	25	0.060	0.11
14	43	30	13	25	0.058	0.10
15	41	28	13	25	0.061	0.10
16	42	33	9	25	0.053	0.10
17	43	31	12	25	0.059	0.10
18	42	27	15	25	0.054	0.10
19	42	27	15	25	0.061	0.11
20	42	27	15	25	0.054	0.10
21	42	30	12	25	0.072	0.10
22	42	30	12	25	0.065	0.10
23	40	24	11	25	0.064	0.10
24	43	31	12	25	0.071	0.10
25	41	31	10	25	0.061	0.10
26	42	31	11	25	0.080	0.10
27	43	31	12	25	0.056	0.10
28	41	28	13	25	0.061	0.10
29	40	31	9	25	0.051	0.10
30	41	30	11	25	0.028	0.10
31	41	24	12	25	0.041	0.10

Cartridge Filtration

95% of daily turbidity readings $\leq$ 1 NTU? ☒ Yes / ☐ No
 All daily turbidity readings $\leq$ 5 NTU? ☒ Yes / ☐ No

Notes: PSI = pounds per square inch
 PSID = pounds per square inch difference (before filter - after filter)
 PSID When to Change Filter = Manufacturer's recommendation; may need to look in manual for manufacturer's specifications when to change the filter, at what PSID.

Monthly Summary (Answer Yes or No)

CT's met everyday? (see back) ☒ Yes / ☐ No
 All Cl₂ residual at entry point $\geq$ 0.2 mg/l? ☒ Yes / ☐ No

PRINTED NAME: David John

SIGNATURE: *David John*

DATE: 8.7.24

PHONE #: (541) 1592.2100
 0x2256

CERT # D-09445

Including continuous turbidity data, if applicable, for optimization recording purposes. Compliance values in "Daily Turbidity".

OHA - Drinking Water Program - Surface Water Quality Data Form

NPS OREGON CAVES NATL MON ID #: OR4191998 WTP: WTP-A Month/Year: Aug 2024

Date / Time	Minimum Cl ₂ Residual at 1 st User (C) ²	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ²	Peak Hour Demand Flow
	[ppm or mg/L]	[minutes]	CXT	[°C]		Use tables	Yes / No	[GPM]
1/	1.34	43	59.77	12	7.7	28	Yes	11.46
2/	1.35	43	58.05	12	7.7	28	Yes	11.04
3/	1.28	43	55.04	12	7.7	28	Yes	14.17
4/	1.68	43	58.91	12	7.7	29	Yes	14.79
5/	1.34	43	59.77	12	7.7	28	Yes	13.96
6/	1.68	43	72.24	12	7.7	29	Yes	11.25
7/	1.72	43	83.96	12	7.7	29	Yes	11.25
8/	1.74	43	74.82	12	7.7	29	Yes	12.30
9/	1.64	43	70.52	12	7.7	29	Yes	11.04
10/	1.63	43	70.09	12	7.7	29	Yes	11.67
11/	1.49	43	64.07	12	7.7	28	Yes	13.13
12/	1.36	43	58.48	12	7.7	28	Yes	11.67
13/	1.28	43	55.04	12	7.7	28	Yes	12.08
14/	1.26	43	54.18	12	7.7	28	Yes	15.63
15/	1.30	43	55.90	12	7.7	28	Yes	12.71
16/	1.24	43	53.32	12	7.7	28	Yes	63.56
17/	1.19	43	51.17	12	7.7	27	Yes	26.05
18/	1.30	43	55.90	12	7.7	28	Yes	14.80
19/	1.30	43	55.90	12	7.7	28	Yes	15.63
20/	1.32	43	56.76	12	7.7	28	Yes	13.12
21/	1.40	43	60.2	12	7.7	28	Yes	12.29
22/	1.48	43	63.64	12	7.7	28	Yes	15.63
23/	1.47	43	63.21	12	7.7	28	Yes	7.50
24/	1.40	43	60.20	12	7.7	28	Yes	19.79
25/	1.31	43	56.33	12	7.7	28	Yes	12.08
26/	1.12	43	48.16	12	7.7	28	Yes	12.92
27/	1.04	43	44.72	12	7.7	27	Yes	12.92
28/	1.06	43	46.58	12	7.7	27	Yes	22.09
29/	1.08	43	46.44	12	7.7	27	Yes	14.38
30/	1.19	43	51.17	12	7.7	27	Yes	13.75
31/	1.65	43	70.95	12	7.7	29	Yes	11.67

² If Cl₂ at entry point < 0.2 mg/L, OR CT not met, notify DWP by end of next business day.
Download form at: www.public.health.oregon.gov/HealthyEnvironments/DrinkingWater/Monitoring/Documents/turb-cartridge.pdf

SOURCE NAME: LAKE CREEK
 MONTH: August YEAR: 2024
 TEST LOCATION CODES:
 1. Int. Bedrock
 2. Outlet
 3. Water Fountain
 4. OCVC
 5. Chateau
 6. Guide house

ADDRESS: OREGON CAVES NATIONAL MONUMENT
 19000 CAVES HIGHWAY
 CAVE JUNCTION, OREGON 97523
 1-541-592-2100
 PSW ID#: 419 1998

DAY	INITIALS	CHLORINE		TIME	TEST LOCATION	B TANK CHLORINE ADDED	CHLORINE		METER READING	GAL USED	TURBIDITY		REMARKS
		RESIDUAL	SYS				Set	Res.			RAW	FINISHED	
1	23	1.34	2	1630	2	—	6.25	1.34	5274550	5500	0.440	0.052	CIP 7.25 → 5.75, changed #
2	23	1.35	2	1000	2	—	6.25	1.35	52800800	5300	0.450	0.051	CIP 6.75 → 6.25
3	23	1.28	2	0900	2	—	6.25	1.28	52807600	6800	0.442	0.061	Changed # 2, 4
4	23	1.37	2	1100	2	—	6.25	1.37	52814700	7100	0.045	0.055	—
5	23	1.34	2	1045	2	—	6.25	1.34	52821400	6700	0.511	0.056	—
6	23	1.67	2	0850	2	+16.21	6.25	1.67	52826800	5400	0.451	0.050	Changed # 1, added to back
7	23	1.72	2	0930	2	—	5.50	1.72	52831200	5400	0.664	0.057	Changed # 2, CIP 6.25 → 5.50
8	23	1.74	2	0800	2	—	5.50	1.74	52839100	5900	0.483	0.066	—
9	23	1.64	2	0930	2	—	5.25	1.64	52843400	5300	0.501	0.062	Changed # 2, CIP 5.5 → 5.25
10	23	1.63	2	1000	2	—	5.00	1.63	52849000	5600	0.470	0.065	CIP 5.25 → 5.00
11	23	1.49	2	1100	2	—	5.00	1.49	52853300	6300	0.411	0.060	—
12	23	1.36	2	1045	2	—	5.00	1.36	52860400	5600	0.381	0.064	—
13	23	1.28	2	0430	2	—	5.00	1.28	52866700	5600	0.278	0.060	Changed # 1
14	23	1.26	2	1130	2	—	5.25	1.26	52874200	7500	0.149	0.058	CIP 5.0 → 5.25
15	23	1.30	2	0930	2	—	5.50	1.30	52880300	6100	0.183	0.061	Changed # 2, CIP 5.25 → 5.50
16	23	1.24	2	1500	2	—	6.00	1.24	52810800	30500	0.214	0.055	Left water on for accident. Changed # CIP 5.5 → 6.00
17	23	1.14	2	1200	2	—	7.00	1.14	52923300	125000	0.165	0.054	Changed 5.50, CIP 6.0 → 7.0
18	23	1.30	2	0900	2	—	7.00	1.30	52930400	7100	0.182	0.054	(Reduced CIP tube) A
19	23	1.30	2	1000	2	—	7.00	1.30	52937400	7500	0.177	0.061	—
20	23	1.32	2	0800	2	—	7.00	1.32	52944200	6300	0.173	0.054	Changed # 2, 5
21	23	1.40	2	0400	2	—	7.00	1.40	52950200	5900	0.140	0.072	—
22	23	1.48	2	1400	2	—	5.50	1.48	52957600	7500	0.154	0.065	Changed # 1, CIP 7.0 → 6.5
23	23	1.47	2	1000	2	—	6.50	1.47	52964200	3600	0.163	0.064	—
24	23	1.40	2	1220	2	—	6.50	1.40	52970700	4500	0.233	0.071	Changed # 1, 3, 4
25	23	1.31	2	1000	2	—	6.50	1.31	52976500	5800	0.240	0.061	—
26	23	1.12	2	0930	2	—	6.50	1.31	52982200	6200	0.200	0.080	—
27	23	1.04	2	0800	2	—	7.50	1.04	52988700	6200	0.151	0.056	CIP 6.50 → 7.50
28	23	1.06	2	0920	2	—	8.00	1.06	52994500	10500	0.143	0.061	CIP 7.5 → 8.0, changed # 2
29	23	1.08	2	1100	2	+15.21	8.50	1.08	53000500	0900	0.145	0.051	CIP 8.0 → 8.5, changed # 3
30	23	1.14	2	1040	2	—	8.50	1.14	53013000	6600	0.151	0.058	—
31	23	1.65	2	1050	2	—	7.50	1.65	53018600	5600	0.180	0.041	Changed # 4, CIP 8.5 → 7.5