

OHA - Drinking Water Program - Turbidity Monitoring Report Form County: Josephine

Cartridge or Bag Filtration

System Name: **NPS OREGON CAVES NATL MON** ID #: **OR4191998** WTP: **WTP-A** Month/Year: **April 2025**

DAY	PSI Before Filter	PSI After Filter	PSID	PSID When to Change Filter	Daily Turbidity Reading [NTU]	Highest Reading of the Day [NTU]
1	45	25	20	10	0.061	0.106
2	45	25	20	10	0.060	0.160
3	45	24	21	10	0.052	0.128
4	45	22	23	10	0.065	0.147
5	45	20	25	10	0.054	0.140
6	45	20	25	10	0.053	0.157
7	45	19	26	10	0.060	0.122
8	45	17	28	10	0.049	0.113
9	45	16	29	10	0.053	0.107
10	45	15	30	10	0.053	0.073
11	45	15	30	10	0.061	0.142
12	45	26	19	10	0.059	0.111
13	45	26	19	10	0.090	0.124
14	45	25	20	10	0.048	0.132
15	45	25	20	10	0.056	0.105
16	44	30	14	10	0.054	0.095
17	45	29	16	10	0.044	0.102
18	45	24	16	10	0.047	0.101
19	45	27	18	10	0.071	0.105
20	45	27	18	10	0.060	0.140
21	45	28	17	10	0.058	0.118
22	45	28	17	10	0.057	0.125
23	45	26	19	10	0.092	0.154
24	45	23	22	10	0.046	0.081
25	45	23	22	10	0.070	0.116
26	45	22	23	10	0.044	0.099
27	45	20	25	10	0.042	0.151
28	45	20	25	10	0.072	0.132
29	45	27	18	10	0.054	0.116
30	45	27	18	10	0.068	0.108
31						

Cartridge Filtration		Monthly Summary (Answer Yes or No)	
95% of daily turbidity readings ≤ 1 NTU? Yes / No All daily turbidity readings ≤ 5 NTU? Yes / No	CT's met everyday? (see back) Yes / No	All Cl ₂ residual at entry point ≥ 0.2 mg/l? Yes / No	
Notes: PSI = pounds per square inch PSID = pounds per square inch difference (before filter - after filter) PSID When to Change Filter = Manufacturer's recommendation; may need to look in manual for manufacturer's specifications when to change the filter, at what PSID.		PRINTED NAME: <u>David John</u> SIGNATURE: <u>David John</u> DATE: <u>5.9.25</u>	
		PHONE #: <u>(541) 1592.2100x2256</u> CERT #: <u>D-09445</u>	

Including continuous turbidity data, if applicable, for optimization recording purposes. Compliance values in "Daily Turbidity"

OHA - Drinking Water Program - Surface Water Quality Data Form

NPS OREGON CAVES NATL MON ID #: OR4191998 WTP: WTP-A Month/Year: April 2025

Date / Time	Minimum Cl ₂ Residual at 1 st User (C) ²	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ²	Peak Hour Demand Flow
	[ppm or mg/L]	[minutes]	C x T	[° C]		Use tables	Yes / No	[GPM]
1/	1.61	43	69.23	11	7.8	30	Y	7.08
2/	1.59	43	68.37	11	7.8	29	Y	8.12
3/	1.60	43	68.80	11	7.8	30	Y	8.75
4/	1.58	43	67.94	11	7.8	29	Y	7.92
5/	1.62	43	69.66	11	7.8	30	Y	8.75
6/	1.65	43	70.95	11	7.8	30	Y	7.08
7/	1.66	43	71.38	11	7.8	30	Y	7.7
8/	1.69	43	72.67	11	7.8	30	Y	6.25
9/	1.68	43	72.24	11	7.8	30	Y	8.33
10/	1.70	43	73.10	11	7.8	30	Y	6.04
11/	1.59	43	68.37	11	7.8	29	Y	7.92
12/	1.85	43	79.55	11	7.8	30	Y	8.96
13/	1.88	43	80.84	11	7.8	30	Y	6.88
14/	1.92	43	82.56	11	7.8	30	Y	5.83
15/	1.97	43	84.71	11	7.8	30	Y	7.29
16/	1.95	43	83.85	11	7.8	30	Y	5.83
17/	1.91	43	82.13	11	7.8	30	Y	7.50
18/	1.80	43	77.40	11	7.8	30	Y	6.46
19/	1.61	43	69.23	11	7.8	30	Y	7.08
20/	1.48	43	63.64	11	7.8	29	Y	4.58
21/	1.44	43	61.92	11	7.8	29	Y	6.04
22/	1.39	43	59.77	11	7.8	28	Y	5.62
23/	1.32	43	56.76	11	7.8	28	Y	N/A
24/	1.35	43	58.05	11	7.8	28	Y	12.71
25/	1.38	43	58.76	11	7.8	28	Y	5.00
26/	1.44	43	61.92	11	7.8	29	Y	5.62
27/	1.51	43	64.93	11	7.8	29	Y	5.418
28/	1.59	43	68.37	11	7.8	29	Y	6.04
29/	1.70	43	73.10	11	7.8	30	Y	5.8
30/	1.64	43	70.52	11	7.8	30	Y	6.25
31/	—	—	—	—	—	—	—	—

² If Cl₂ at entry point < 0.2 mg/l, OR CT not met, notify DWP by end of next business day.
Download form at: www.public.health.oregon.gov/HealthyEnvironments/DrinkingWater/Monitoring/Documents/turb-cartridge.pdf

ADDRESS: OREGON CAVES NATIONAL MONUMENT
19000 CAVES HIGHWAY
4 CAVE JUNCTION, OREGON 97523
1-541-592-2100

DAY	INITIALS	CHLORINE		TIME	TEST LOCATION	B TANK CHLORINE ADDED	CHLORINE		METER READING	GAL USED	TURBIDITY		REMARKS
		RESIDUAL	SYS				Set	Res.			RAW	FINISHED	
1	BO	1.61	2	1000	2	—	5.5	1.61	5427449	3400	0.170	0.061	—
2	BO	1.54	2	0430	2	—	5.5	1.54	54073200	3400	0.127	0.060	—
3	BO	1.60	2	1200	2	—	5.5	1.60	54082200	3800	0.152	0.052	—
4	BO	1.58	2	1100	2	—	5.5	1.58	5406500	3800	0.114	0.065	—
5	BO	1.62	2	1100	2	—	5.5	1.62	54230900	4200	0.148	0.054	Unfiltered 45300's @ 10m
6	BO	1.65	2	1000	2	—	5.5	1.65	54254000	3400	0.185	0.053	—
7	BO	1.63	2	1000	2	—	5.5	1.66	54247800	3700	0.154	0.060	—
8	BO	1.67	2	0430	2	—	5.5	1.69	54300800	3000	0.131	0.044	—
9	BO	1.68	2	0800	2	—	5.5	1.68	54306800	4000	0.102	0.053	—
10	BO	1.70	2	0920	2	+	5.5	1.70	54307200	3400	0.118	0.053	—
11	BO	1.54	2	1245	2	+	5.5	1.53	54311500	3800	0.147	0.061	—
12	BO	1.85	2	1300	2	—	5.5	1.85	54315800	4300	0.204	0.059	Changed #3, 4
13	BO	1.88	2	1000	2	—	5.5	1.88	54314100	3300	0.164	0.046	—
14	BO	1.92	2	1100	2	—	5.5	1.92	54321400	2800	0.144	0.048	—
15	BO	1.97	2	1400	2	—	4.75	1.47	54326400	3500	0.154	0.056	—
16	BO	1.45	2	1000	2	—	4.50	1.45	54328200	2800	0.144	0.054	Changed # 1, 2
17	BO	1.91	2	1000	2	—	4.60	1.41	54331800	3600	0.185	0.044	—
18	BO	1.80	2	0930	2	—	4.50	1.80	54334200	3100	0.164	0.043	—
19	BO	1.61	2	1400	2	—	4.50	1.61	54339300	3400	0.150	0.071	—
20	BO	1.48	2	1200	2	—	4.50	1.48	54340500	2800	0.110	0.060	—
21	BO	1.44	2	0830	2	—	4.50	1.44	54343800	2900	0.108	0.058	—
22	BO	1.35	2	1000	2	—	4.00	1.34	54346100	2700	0.124	0.067	Out 4.5-7.00, Flamed water
23	BO	1.32	2	0400	2	—	6.00	1.32	54346100	0	0.154	0.042	Cleaned intake, water
24	BO	1.35	2	1000	2	—	6.00	1.35	54352200	6100	0.225	0.046	—
25	BO	1.32	2	0830	2	—	6.00	1.32	54354000	2400	0.132	0.070	—
26	BO	1.44	2	1430	2	—	6.00	1.44	54357200	2700	0.141	0.044	—
27	BO	1.51	2	0800	2	—	6.00	1.51	54359400	2500	0.184	0.042	—
28	BO	1.55	2	0800	2	—	6.00	1.55	54363800	2400	0.166	0.072	—
29	BO	1.70	2	0400	2	—	6.00	1.70	54365000	2800	0.156	0.054	Changed # 3, 4
30	BO	1.64	2	1100	2	—	6.00	1.64	54366800	3000	0.144	0.058	—
31	—	—	2	—	2	—	—	—	—	—	—	—	—