

OHA - Drinking Water Program - Turbidity Monitoring Report Form County: Josephine Cartridge or Bag Filtration

System Name: **NPS OREGON CAVES NATL MON ID #: OR4191998** WTP: **WTP-A** Month/Year: **5/17/2025**

DAY	PSI Before Filter	PSI After Filter	PSID	PSID When to Change Filter	Daily Turbidity Reading [NTU]	Highest Reading of the Day ¹ [NTU]
1	45	30	15	10	0.045	0.126
2	45	29	16	10	0.055	0.132
3	45	29	16	10	0.048	0.109
4	45	27	18	10	0.052	0.203
5	45	27	18	10	0.063	0.172
6	45	25	20	10	0.042	0.113
7	45	24	21	10	0.050	0.073
8	45	28	17	10	—	—
9	45	28	17	10	0.049	0.177
10	45	31	14	10	0.049	0.150
11	45	30	15	10	0.048	0.132
12	45	29	16	10	0.056	0.146
13	45	28	17	10	0.049	0.129
14	45	26	19	10	0.044	0.137
15	45	28	17	10	0.031	0.128
16	45	25	20	10	0.041	0.167
17	45	24	21	10	0.049	0.160
18	45	26	19	10	0.041	0.158
19	45	26	19	10	0.040	0.142
20	45	24	21	10	0.051	0.169
21	45	23	22	10	0.057	0.198
22	45	21	24	10	0.054	0.162
23	45	20	25	10	0.036	0.041
24	45	18	27	10	0.048	0.117
25	45	25	20	10	0.040	0.129
26	45	25	20	10	0.045	0.138
27	45	23	22	10	0.050	0.130
28	45	22	23	10	0.040	0.142
29	45	21	24	10	0.045	0.149
30	45	21	24	10	0.052	0.157
31	45	26	19	10	0.042	0.081

Cartridge Filtration

95% of daily turbidity readings ≤ 1 NTU? ☒ Yes / No
All daily turbidity readings ≤ 5 NTU? ☒ Yes / No

Monthly Summary (Answer Yes or No)

CT's met everyday? (see back)
☒ Yes / No

All Cl₂ residual at entry point ≥ 0.2 mg/l?
☒ Yes / No

PRINTED NAME: David John

SIGNATURE: David John

DATE: 08.08.25

PHONE #: (503) 1592-2100

CERT #: D-09445

Notes: PSI = pounds per square inch
PSID = pounds per square inch difference (before filter - after filter)
PSID When to Change Filter = Manufacturer's recommendation; may need to look in manual for manufacturer's specifications when to change the filter, at what PSID.

Including continuous turbidity data, if applicable, for optimization recording purposes. Compliance values in "Daily Turbidity"

OHA - Drinking Water Program - Surface Water Quality Data Form

NPS OREGON CAVES NATL MON ID #: OR4101098 WTP: WTP-A Month/Year: July/2025

Date / Time	Minimum Cl ₂ Residual at 1 st User (C) ²	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ²	Peak Hour Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		Use tables	Yes / No	[GPM]
1/	2.51	43	107.93	13	7.5	53	yes	8.33
2/	2.31	43	99.33	13	7.5	52	yes	6.46
3/	2.17	43	93.31	13	7.5	51	yes	6.04
4/	2.10	43	90.30	13	7.5	51	yes	7.91
5/	2.06	43	88.58	13	7.5	51	yes	6.87
6/	2.03	43	87.29	13	7.5	51	yes	7.71
7/	1.93	43	82.99	13	7.5	50	yes	6.87
8/	1.83	43	78.69	13	7.5	50	yes	—
9/	1.75	43	75.25	13	7.5	49	yes	11.04
10/	1.65	43	70.95	13	7.5	49	yes	7.29
11/	1.58	43	67.94	13	7.5	48	yes	3.54
12/	1.42	43	61.06	13	7.5	48	Y	6.25
13/	1.38	43	59.34	13	7.5	47	Y	5.62
14/	1.33	43	57.19	13	7.5	47	Y	6.04
15/	1.33	43	57.19	13	7.5	47	Y	8.54
16/	1.36	43	58.48	13	7.5	47	Y	5.00
17/	1.41	43	60.63	13	7.5	48	Y	5.62
18/	1.47	43	63.21	13	7.5	48	Y	5.41
19/	1.42	43	61.06	13	7.5	48	Y	5.00
20/	1.34	43	59.77	13	7.5	47	Y	5.41
21/	1.33	43	57.19	13	7.5	47	Y	5.21
22/	1.42	43	61.06	13	7.5	48	Y	5.21
23/	1.69	43	72.67	13	7.5	49	Y	4.79
24/	1.70	43	73.10	13	7.5	49	Y	11.46
25/	1.73	43	74.34	13	7.5	49	Y	5.41
26/	1.70	43	73.10	13	7.5	49	Y	6.25
27/	1.69	43	72.67	13	7.5	49	Y	5.83
28/	1.67	43	71.81	13	7.5	49	Y	6.46
29/	1.69	43	72.67	13	7.5	49	Y	6.87
30/	1.74	43	74.82	13	7.5	49	Y	5.62
31/	1.71	43	73.58	13	7.5	49	Y	6.66

If Cl₂ at entry point < 0.2 mg/l, OR CT not met, notify DWP by end of next business day.
 Download form at: www.public.health.oregon.gov/HealthyEnvironments/DrinkingWater/Monitoring/Documents/turb-cartridge.pdf

SOURCE NAME: LAKE CREEK

MONTH Sept YEAR 2025

TEST LOCATION CODES:

1 - INFORMATION BOOTH

2 - Chalet

3 - WATER FOUNTAIN

4 - V.C

5 - CHATEAU

6 - GUIDE HOUSE

ADDRESS: OREGON CAVES NATIONAL MONUMENT

19000 CAVES HIGHWAY

CAVE JUNCTION, OREGON 97523

1-541-592-2100

PSW ID#: 419 1998

Total: 89,500

DAY	INITIALS	CHLORINE RESIDUAL		TIME	TEST LOCATION	B TANK CHLORINE ADDED	CHLORINE		METER READING	GAL USED	TURBIDITY		REMARKS
		4	SYS				Set.	Res.			RAW	FINISHED	
1	SB	2.51	2	0700	2	—	5.0	2.51	54537400	4000	0.127	0.045	
2	SB	2.31	2	1130	2	—	5.0	2.31	54541000	3100	0.134	0.055	Changed #1
3	SB	2.17	2	1300	2	—	5.0	2.17	54543900	2906	0.156	0.048	
4	SB	2.10	2	1100	2	—	5.0	2.10	54547700	3800	0.144	0.052	
5	SB	2.06	2	0915	2	—	5.0	2.06	54551000	3300	0.109	0.063	
6	SB	2.03	2	1000	2	—	4.0	2.03	54554700	3700	0.055	0.042	Calibrated Th 5300's
7	SB	1.93	2	1100	2	—	4.0	1.93	54558000	3300	0.253	0.050	Turned Plant off to Clean Int
8	SB	1.83	2	0930	2	—	4.0	1.83	54558000	—	—	—	Turned Plant on
9	SB	1.75	2	0915	2	—	4.0	1.75	54563300	5300	0.211	0.049	
10	SB	1.68	2	0945	2	—	4.0	1.68	54566800	3500	0.220	0.044	
11	SB	1.58	2	0800	2	—	4.0	1.58	54568500	1700	0.273	0.048	
12	SB	1.42	2	1000	2	—	4.0	1.42	54571500	3000	0.215	0.056	
13	SB	1.38	2	1030	2	—	4.0	1.42	54574200	2700	0.164	0.049	
14	SB	1.33	2	1100	2	—	5.0	1.33	54577100	2400	0.161	0.044	
15	SB	1.33	2	0830	2	—	5.0	1.32	54581200	4100	0.263	0.051	Cal 405
16	SB	1.36	2	0900	2	—	5.0	1.36	54583000	2400	0.214	0.041	
17	SB	1.41	2	0900	2	—	5.0	1.41	54586300	2700	0.205	0.044	
18	SB	1.47	2	1000	2	—	5.0	1.47	54588900	2600	0.242	0.041	Changed #2
19	SB	1.42	2	1100	2	—	5.0	1.42	54591300	2400	0.157	0.046	
20	SB	1.39	2	1045	2	—	5.0	1.39	54593900	2600	0.162	0.051	
21	SB	1.33	2	0900	2	—	5.0	1.33	54596400	2500	0.168	0.057	
22	SB	1.42	2	0800	2	—	5.0	1.42	54598900	2500	0.144	0.054	
23	SB	1.69	2	0800	2	—	4.0	1.69	54601200	2300	0.179	0.056	Cal 5.0 → 4.0
24	SB	1.70	2	0945	2	—	4.0	1.70	54606700	5500	0.146	0.048	
25	SB	1.73	2	1130	2	—	4.0	1.73	54609300	2600	0.117	0.040	Changed #3, 4
26	SB	1.70	2	1100	2	—	4.0	1.70	54612300	3000	0.150	0.045	
27	SB	1.69	2	0900	2	—	4.0	1.69	54615100	2600	0.203	0.050	
28	SB	1.67	2	0800	2	—	4.0	1.67	54618200	3100	0.267	0.046	
29	SB	1.69	2	1420	2	—	4.0	1.69	54621500	3300	0.142	0.045	
30	SB	1.74	2	1330	2	—	4.0	1.74	54624200	2700	0.144	0.052	
31	SB	1.71	2	0830	2	—	4.0	1.71	54627000	3200	0.136	0.042	Changed #2