

OHA - Drinking Water Services - Surface Water Quality Data Form

County: Lincoln

Cartridge or Bag Filtration

Month/Year: Aug-24

System Name: Alesa River RV Park & Marina ID#: 41 92043 WTP ID: TP-

Day	PSI Before Filter	PSI After Filter	PSID	PSID When to Change Filter	Daily Turbidity Reading [NTU]	Highest Reading of the day ¹ [NTU]
1					0.00	
2					0.00	
3					0.00	
4					0.00	
5					0.00	
6					0.00	
7					0.00	
8					0.00	
9					0.00	
10					0.00	
11					0.00	
12					0.00	
13					0.00	
14					0.00	
15					0.00	
16					0.00	
17					0.00	
18					0.00	
19					0.00	
20					0.00	
21					0.00	
22					0.00	
23					0.00	
24					0.00	
25					0.00	
26					0.00	
27					0.00	
28					0.00	
29					0.00	
30					0.00	
31					0.00	

Cartridge & Bag Filtration		Monthly Summary (Answer Yes or No)	
95% of daily turbidity readings ≤ 1 NTU?	Yes	CT's met everyday? (see back)	All Cl2 residual at entry point ≥ 0.2 mg/l?
All daily turbidity readings ≤ 5 NTU?	Yes	Yes	Yes

Notes: PSI = pounds per square inch PSID = pounds per square inch difference (before filter - after filter) PSID When to Change Filter = look in manual for manufacturer's specifications when to change the filter, at what PSID.	PRINTED NAME: Nancy Johnston	
	SIGNATURE: <i>Nancy Johnston</i>	DATE: 9/9/24
	PHONE #: (541)563-3401	CERT #:

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in Daily Turbidity Reading column may not correspond to continuous readings' maximum.

OHA - Drinking Water Services - Surface Water Quality Data Form

WTP: : a
Disinfection Giardia Log Inactiv: 1

System Name: Alesa River RV Park & Marina ID#: 41 92043 Month/Year: Aug-24

Date / Time	Minimum Cl ₂ Residual at 1st User (C) ²	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ²	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
1	0.75	104	78.0	15.0	6.30	20.4	YES	
2	0.8	104	83.2	15.0	6.30	20.5	YES	
3	0.82	104	85.3	15.1	6.20	19.7	YES	
4	0.82	104	85.3	15.0	6.30	20.5	YES	
5	0.85	104	88.4	15.1	6.30	20.5	YES	
6	0.85	104	88.4	15.1	6.20	19.7	YES	
7	0.87	104	90.5	15.2	6.20	19.6	YES	
8	0.87	104	90.5	15.1	6.20	19.8	YES	
9	0.86	104	89.4	15.1	6.20	19.7	YES	
10	0.88	104	91.5	15.2	6.30	20.4	YES	
11	0.88	104	91.5	15.2	6.30	20.4	YES	
12	0.89	104	92.6	15.0	6.30	20.7	YES	
13	0.89	104	92.6	15.1	6.30	20.6	YES	
14	0.9	104	93.6	15.1	6.30	20.6	YES	
15	0.92	104	95.7	15.1	6.20	19.9	YES	
16	0.92	104	95.7	15.0	6.20	20.0	YES	
17	0.92	104	95.7	15.1	6.20	19.9	YES	
18	0.95	104	98.8	15.1	6.20	19.9	YES	
19	0.96	104	99.8	15.2	6.10	19.1	YES	
20	0.95	104	98.8	15.2	6.20	19.8	YES	
21	0.98	104	101.9	15.2	6.20	19.9	YES	
22	1	104	104.0	15.2	6.10	19.2	YES	
23	1	104	104.0	15.2	6.10	19.2	YES	
24	1	104	104.0	15.2	6.10	19.2	YES	
25	1.01	104	105.0	15.1	6.10	19.3	YES	
26	1.02	104	106.1	15.1	6.00	18.7	YES	
27	1.04	104	108.2	15.0	6.10	19.5	YES	
28	1.04	104	108.2	15.0	6.10	19.5	YES	
29	1.04	104	108.2	15.1	6.10	19.4	YES	
30	1.03	104	107.1	15.1	6.10	19.4	YES	
31	1.03	104	107.1	15.2	6.10	19.3	YES	

² If Cl₂ at entry point < 0.2 mg/l or CT not met, notify DWS within 24 hours. Revised November 2022
 Return by 10th of following month by email, fax, or mail to:
 dwp.dmce@oha.oregon.gov; 971-673-0694; or Drinking Water Services, PO Box 14350, Portland, OR 97293-0350