

OHA - Drinking Water Services - Surface Water Quality Data Form

County: Lincoln

Cartridge or Bag Filtration

Month/Year: Dec-24

System Name: Alesa River RV Park & Marina ID#: 41 92043 WTP ID: TP-

| Day | PSI Before Filter | PSI After Filter | PSID | PSID When to Change Filter | Daily Turbidity Reading [NTU] | Highest Reading of the day ¹ [NTU] |
|-----|-------------------|------------------|------|----------------------------|-------------------------------|---|
| 1 | | | | | 0.00 | |
| 2 | | | | | 0.00 | |
| 3 | | | | | 0.00 | |
| 4 | | | | | 0.00 | |
| 5 | | | | | 0.00 | |
| 6 | | | | | 0.00 | |
| 7 | | | | | 0.00 | |
| 8 | | | | | 0.00 | |
| 9 | | | | | 0.00 | |
| 10 | | | | | 0.00 | |
| 11 | | | | | 0.00 | |
| 12 | | | | | 0.00 | |
| 13 | | | | | 0.00 | |
| 14 | | | | | 0.00 | |
| 15 | | | | | 0.00 | |
| 16 | | | | | 0.00 | |
| 17 | | | | | 0.00 | |
| 18 | | | | | 0.00 | |
| 19 | | | | | 0.00 | |
| 20 | | | | | 0.00 | |
| 21 | | | | | 0.00 | |
| 22 | | | | | 0.00 | |
| 23 | | | | | 0.00 | |
| 24 | | | | | 0.00 | |
| 25 | | | | | 0.00 | |
| 26 | | | | | 0.00 | |
| 27 | | | | | 0.00 | |
| 28 | | | | | 0.00 | |
| 29 | | | | | 0.00 | |
| 30 | | | | | 0.00 | |
| 31 | | | | | 0.00 | |

| | | | |
|---|-----|--|---|
| Cartridge & Bag Filtration | | Monthly Summary (Answer Yes or No) | |
| 95% of daily turbidity readings ≤ 1 NTU? | Yes | CT's met everyday? (see back) | All Cl2 residual at entry point ≥ 0.2 mg/l? |
| All daily turbidity readings ≤ 5 NTU? | Yes | Yes | Yes |
| Notes: PSI = pounds per square inch PSID = pounds per square inch difference (before filter - after filter) PSID When to Change Filter = look in manual for manufacturer's specifications when to change the filter, at what PSID. | | PRINTED NAME: Nancy Johnston SIGNATURE: <i>Nancy Johnston</i> DATE: 01/10/2025 PHONE #: (541) 563-3401 CERT #: | |

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in Daily Turbidity Reading column may not correspond to continuous readings' maximum.

OHA - Drinking Water Services - Surface Water Quality Data Form

WTP- :

System Name: Alesa River RV Park & Marina ID#: 41 92043 Month/Year: Dec-24 Disinfection Giardia Log Inactiv:

| Date / Time | Minimum Cl ₂ Residual at 1st User (C) ² | Contact Time (T) | Actual CT | Temp | pH | Required CT | CT Met? ² |
|-------------|---|------------------|-----------|-------|------|-------------|----------------------|
| | [ppm or mg/L] | [minutes] | C X T | [° C] | | formula | Yes / No |
| 1 | 1.2 | 104 | 124.8 | 14.0 | 6.90 | 28.7 | YES |
| 2 | 1.2 | 104 | 124.8 | 14.0 | 6.90 | 28.7 | YES |
| 3 | 1.1 | 104 | 114.4 | 14.1 | 6.80 | 27.2 | YES |
| 4 | 1.1 | 104 | 114.4 | 14.1 | 6.80 | 27.2 | YES |
| 5 | 1.1 | 104 | 114.4 | 14.1 | 6.80 | 27.2 | YES |
| 6 | 1 | 104 | 104.0 | 14.0 | 6.80 | 27.0 | YES |
| 7 | 1 | 104 | 104.0 | 14.0 | 6.80 | 27.0 | YES |
| 8 | 1 | 104 | 104.0 | 14.0 | 6.80 | 27.0 | YES |
| 9 | 1.1 | 104 | 114.4 | 14.0 | 6.80 | 27.3 | YES |
| 10 | 1.1 | 104 | 114.4 | 14.0 | 6.70 | 26.3 | YES |
| 11 | 1 | 104 | 104.0 | 13.9 | 6.70 | 26.2 | YES |
| 12 | 1 | 104 | 104.0 | 14.0 | 6.80 | 27.0 | YES |
| 13 | 0.99 | 104 | 103.0 | 14.0 | 6.80 | 27.0 | YES |
| 14 | 0.98 | 104 | 101.9 | 13.9 | 6.80 | 27.2 | YES |
| 15 | 0.99 | 104 | 103.0 | 13.9 | 6.80 | 27.2 | YES |
| 16 | 1 | 104 | 104.0 | 13.9 | 6.90 | 28.2 | YES |
| 17 | 1 | 104 | 104.0 | 13.9 | 6.90 | 28.2 | YES |
| 18 | 1 | 104 | 104.0 | 13.9 | 6.90 | 28.2 | YES |
| 19 | 1 | 104 | 104.0 | 13.9 | 6.80 | 27.2 | YES |
| 20 | 0.99 | 104 | 103.0 | 13.8 | 6.90 | 28.4 | YES |
| 21 | 0.98 | 104 | 101.9 | 13.8 | 6.90 | 28.4 | YES |
| 22 | 0.98 | 104 | 101.9 | 13.9 | 6.90 | 28.2 | YES |
| 23 | 0.98 | 104 | 101.9 | 13.9 | 6.80 | 27.2 | YES |
| 24 | 0.97 | 104 | 100.9 | 13.9 | 6.80 | 27.1 | YES |
| 25 | 0.98 | 104 | 101.9 | 14.0 | 6.90 | 28.0 | YES |
| 26 | 0.96 | 104 | 99.8 | 13.9 | 6.90 | 28.1 | YES |
| 27 | 0.96 | 104 | 99.8 | 13.9 | 6.80 | 27.1 | YES |
| 28 | 0.97 | 104 | 100.9 | 14.0 | 6.80 | 26.9 | YES |
| 29 | 0.96 | 104 | 99.8 | 14.0 | 6.90 | 27.9 | YES |
| 30 | 0.96 | 104 | 99.8 | 13.9 | 7.00 | 29.2 | YES |
| 31 | 0.96 | 104 | 99.8 | 13.9 | 7.00 | 29.2 | YES |

² If Cl₂ at entry point < 0.2 mg/l or CT not met, notify DWS within 24 hours.

Return by 10th of following month by email, fax, or mail to:

dwp.dmce@oha.oregon.gov; 971-673-0694; or Drinking Water Services, PO Box 14350, Portland, OR 97293-0350

Revised Novem