

OHA - Drinking Water Services - Surface Water Quality Data Form


County: Lincoln

Cartridge or Bag Filtration

Month/Year: Feb-25

System Name: Alsea River RV Park & Marina		ID#: 41	92043	WTP ID: TP-		
Day	PSI Before Filter	PSI After Filter	PSID	PSID When to Change Filter	Daily Turbidity Reading [NTU]	Highest Reading of the day ¹ [NTU]
1					0.00	
2					0.00	
3					0.00	
4					0.00	
5					0.00	
6					0.00	
7					0.00	
8					0.00	
9					0.00	
10					0.00	
11					0.00	
12					0.00	
13					0.00	
14					0.00	
15					0.00	
16					0.00	
17					0.00	
18					0.00	
19					0.00	
20					0.00	
21					0.00	
22					0.00	
23					0.00	
24					0.00	
25					0.00	
26					0.00	
27					0.00	
28					0.00	
29						
30						
31						

Cartridge & Bag Filtration		Monthly Summary (Answer Yes or No)	
95% of daily turbidity readings ≤ 1 NTU?	Yes	CT's met everyday? (see back)	All Cl ₂ residual at entry point ≥ 0.2 mg/l?
All daily turbidity readings ≤ 5 NTU?	Yes	Yes	Yes

Notes: PSI = pounds per square inch		PRINTED NAME: Nancy Johnston	
PSID = pounds per square inch difference (before filter - after filter)		SIGNATURE: 	
PSID When to Change Filter = look in manual for manufacturer's specifications when to change the filter, at what PSID.		DATE: 3/10/2025	
		PHONE #: (541) 563-3401	CERT #:

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in Daily Turbidity Reading column may not

correspond to continuous readings' maximum.

OHA - Drinking Water Services - Surface Water Quality Data Form

WTP- : a

Name: Alsea River RV Park & Marina ID#: 41 92043 Month/Year: Feb-25

Disinfection
Giardia Log
Inactiv:

1

Time	Minimum Cl ₂ Residual at 1st User (C) ²	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ²	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
	1.2	104	124.8	14.1	6.90	28.5	YES	
	1.2	104	124.8	141.0	6.90	-0.8	YES	
	1.2	104	124.8	14.2	6.80	27.3	YES	
	1	104	104.0	14.2	6.80	26.7	YES	
	1.1	104	114.4	14.2	6.80	27.0	YES	
	1.1	104	114.4	14.3	6.80	26.8	YES	
	1.1	104	114.4	14.4	6.80	26.6	YES	
	0.99	104	103.0	14.4	6.70	25.3	YES	
	0.98	104	101.9	14.3	6.60	24.5	YES	
0	0.99	104	103.0	14.3	6.60	24.6	YES	
1	0.98	104	101.9	14.4	6.50	23.5	YES	
2	0.96	104	99.8	14.3	6.50	23.6	YES	
3	0.95	104	98.8	14.3	6.50	23.6	YES	
4	0.97	104	100.9	14.2	6.50	23.8	YES	
5	0.99	104	103.0	14.2	6.50	23.8	YES	
6	0.97	104	100.9	14.2	6.40	22.9	YES	
7	0.96	104	99.8	14.2	6.40	22.9	YES	
8	0.96	104	99.8	14.2	6.30	22.0	YES	
9	0.96	104	99.8	14.2	6.30	22.0	YES	
0	0.95	104	98.8	14.1	6.40	23.0	YES	
1	0.64	104	66.6	14.1	6.30	21.4	YES	
2	0.94	104	97.8	14.2	6.30	22.0	YES	
3	0.94	104	97.8	14.1	6.30	22.1	YES	
4	0.92	104	95.7	14.1	6.30	22.1	YES	
5	0.91	104	94.6	14.0	6.30	22.2	YES	
6	0.91	104	94.6	14.0	6.20	21.4	YES	
7	0.91	104	94.6	14.0	6.20	21.4	YES	
8	0.92	104	95.7	14.0	6.20	21.4	YES	
9								
0								
1								

t entry point < 0.2 mg/l or CT not met, notify DWS within 24 hours.

Revised November 2022

Return by 10th of following month by email, fax, or mail to:

dwp.dmc@oha.oregon.gov; 971-673-0694; or Drinking Water Services, PO Box 14350, Portland, OR 97293-0350