

County: Lincoln

Month/Year: Apr-25

[illegible]

inuous NTU data, if applicable, for optimization recording purposes. Compliance values in Daily Turbidity Reading column may not be continuous readings' maximum.

OHA - Drinking Water Services - Surface Water Quality Data Form

WTP: a

System Name: Alsea River RV Park & Marina	ID#: 41	92043	Month/Year: Apr-25	Disinfection Giardia Log Inactiv:	1
---	---------	-------	--------------------	---	---

Date / Time	Minimum Cl ₂ Residual at 1st User (C) ²	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ²	Peak Hour/ Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
1	1.25	104	130.0	14.0	6.50	24.9	YES	
2	1.23	104	127.9	14.0	6.50	24.8	YES	
3	1.23	104	127.9	13.9	6.50	25.0	YES	
4	1.22	104	126.9	13.9	6.60	25.9	YES	
5	1.2	104	124.8	13.9	6.50	24.9	YES	
6	1.18	104	122.7	13.9	6.50	24.8	YES	
7	1.12	104	116.5	14.0	6.50	24.5	YES	
8	1.1	104	114.4	14.0	6.50	24.5	YES	
9	0.96	104	99.8	14.0	6.40	23.2	YES	
10	0.95	104	98.8	14.0	6.40	23.2	YES	
11	0.94	104	97.8	14.1	6.40	23.0	YES	
12	0.95	104	98.8	14.1	6.40	23.0	YES	
13	0.93	104	96.7	14.0	6.40	23.1	YES	
14	0.94	104	97.8	13.9	6.50	24.2	YES	
15	0.93	104	96.7	13.9	6.50	24.1	YES	
16	0.93	104	96.7	14.0	6.50	24.0	YES	
17	0.91	104	94.6	14.2	6.50	23.6	YES	
18	0.9	104	93.6	13.9	6.60	25.0	YES	
19	0.9	104	93.6	13.9	6.60	25.0	YES	
20	0.89	104	92.6	13.9	6.60	24.9	YES	
21	0.87	104	90.5	13.8	6.60	25.1	YES	
22	0.85	104	88.4	13.9	6.70	25.8	YES	
23	0.85	104	88.4	13.8	6.60	25.0	YES	
24	0.83	104	86.3	13.8	6.70	25.9	YES	
25	0.81	104	84.2	13.8	6.70	25.8	YES	
26	0.79	104	82.2	13.8	6.70	25.8	YES	
27	0.78	104	81.1	13.8	6.80	26.7	YES	
28	0.76	104	79.0	13.9	6.80	26.5	YES	
29	0.76	104	79.0	13.8	6.80	26.7	YES	
30	0.74	104	77.0	13.8	6.80	26.6	YES	
31								

² If Cl₂ at entry point < 0.2 mg/l or CT not met, notify DWS within 24 hours.

Revised November 2022

Return by 10th of following month by email, fax, or mail to:

dwp.dmce@oha.oregon.gov; 971-673-0694; or Drinking Water Services, PO Box 14350, Portland, OR 97293-0350