

OHA - Drinking Water Services - Surface Water Quality Data Form

County: Lincoln

Cartridge or Bag Filtration

Month/Year: Sep-25

System Name:		Alsea River RV Park & Marina		ID#:	41	92043	WTP ID:	TP-
Day	PSI Before Filter	PSI After Filter	PSID	PSID When to Change Filter	Daily Turbidity Reading [NTU]	Highest Reading of the day ¹ [NTU]		
1					0.00			
2					0.00			
3					0.00			
4					0.00			
5					0.00			
6					0.00			
7					0.00			
8					0.00			
9					0.00			
10					0.00			
11					0.00			
12					0.00			
13					0.00			
14					0.00			
15					0.00			
16					0.00			
17					0.00			
18					0.00			
19					0.00			
20					0.00			
21					0.00			
22					0.00			
23					0.00			
24					0.00			
25					0.00			
26					0.00			
27					0.00			
28					0.00			
29					0.00			
30					0.00			
31								

Cartridge & Bag Filtration		Monthly Summary (Answer Yes or No)	
95% of daily turbidity readings ≤ 1 NTU?	Yes	CT's met everyday? (see back)	All Cl ₂ residual at entry point ≥ 0.2 mg/l?
All daily turbidity readings ≤ 5 NTU?	Yes	Yes	Yes

Notes: PSI = pounds per square inch PSID = pounds per square inch difference (before filter - after filter) PSID When to Change Filter = look in manual for manufacturer's specifications when to change the filter, at what PSID.	PRINTED NAME: Nancy Johnston	
	SIGNATURE: Nancy Johnston	DATE: 10/10/2025
	PHONE #: (541)563-3401	CERT #:

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in Daily Turbidity Reading column may not correspond to continuous readings' maximum.

OHA - Drinking Water Services - Surface Water Quality Data Form

WTP- :

a

System Name: Alsea River RV Park & Marina

ID#: 41

92043

Month/Year:

Sep-25

Disinfection
Giardia Log
Inactiv:

1

Date / Time	Minimum Cl ₂ Residual at 1st User (C) ²	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ²	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
1	0.97	104	100.9	15.0	6.60	23.4	YES	
2	0.98	104	101.9	14.9	6.60	23.6	YES	
3	1	104	104.0	14.9	6.70	24.5	YES	
4	1	104	104.0	14.8	6.70	24.7	YES	
5	0.99	104	103.0	14.7	6.70	24.8	YES	
6	0.98	104	101.9	14.7	6.60	23.9	YES	
7	0.97	104	100.9	14.7	6.70	24.8	YES	
8	0.97	104	100.9	14.8	6.70	24.6	YES	
9	0.95	104	98.8	14.7	6.70	24.7	YES	
10	0.95	104	98.8	14.8	6.70	24.5	YES	
11	0.97	104	100.9	14.7	6.70	24.8	YES	
12	0.95	104	98.8	14.6	6.70	24.9	YES	
13	0.97	104	100.9	14.6	6.80	25.9	YES	
14	0.96	104	99.8	14.5	6.60	24.2	YES	
15	0.96	104	99.8	14.5	6.70	25.1	YES	
16	0.94	104	97.8	14.5	6.70	25.0	YES	
17	0.94	104	97.8	14.6	6.80	25.8	YES	
18	0.94	104	97.8	14.4	6.80	26.1	YES	
19	0.93	104	96.7	14.5	6.76	25.6	YES	
20	0.91	104	94.6	14.3	6.70	25.3	YES	
21	0.92	104	95.7	14.5	6.80	25.9	YES	
22	0.94	104	97.8	14.4	6.90	27.1	YES	
23	0.93	104	96.7	14.4	6.90	27.1	YES	
24	0.93	104	96.7	14.5	6.90	26.9	YES	
25	0.93	104	96.7	14.3	6.90	27.3	YES	
26	0.92	104	95.7	14.3	7.00	28.3	YES	
27	0.92	104	95.7	14.2	7.00	28.5	YES	
28	0.92	104	95.7	14.2	7.00	28.5	YES	
29	0.92	104	95.7	14.3	7.00	28.3	YES	
30	0.92	104	95.7	14.3	7.10	29.4	YES	
31	0.9	104	93.6	14.3	7.10	29.3	YES	

² If Cl₂ at entry point < 0.2 mg/l or CT not met, notify DWS within 24 hours.

Revised November 2022

Return by 10th of following month by email, fax, or mail to:

dwp.dnce@oha.oregon.gov; 971-673-0694; or Drinking Water Services, PO Box 14350, Portland, OR 97293-0350