

OHA - Drinking Water Services - Surface Water Quality Data Form

County: Lincoln

Cartridge or Bag Filtration

Month/Year: Dec-25

System Name: Alsea River RV Park & Marina ID#: 41 92043 WTP ID: TP-

| Day | PSI Before Filter | PSI After Filter | PSID | PSID When to Change Filter | Daily Turbidity Reading [NTU] | Highest Reading of the day <sup>1</sup> [NTU] |
|-----|-------------------|------------------|------|----------------------------|-------------------------------|---|
| 1   |                   |                  |      |                            | 0.00                          |   |
| 2   |                   |                  |      |                            | 0.00                          |   |
| 3   |                   |                  |      |                            | 0.00                          |   |
| 4   |                   |                  |      |                            | 0.00                          |   |
| 5   |                   |                  |      |                            | 0.00                          |   |
| 6   |                   |                  |      |                            | 0.00                          |   |
| 7   |                   |                  |      |                            | 0.00                          |   |
| 8   |                   |                  |      |                            | 0.00                          |   |
| 9   |                   |                  |      |                            | 0.00                          |   |
| 10  |                   |                  |      |                            | 0.00                          |   |
| 11  |                   |                  |      |                            | 0.00                          |   |
| 12  |                   |                  |      |                            | 0.00                          |   |
| 13  |                   |                  |      |                            | 0.00                          |   |
| 14  |                   |                  |      |                            | 0.00                          |   |
| 15  |                   |                  |      |                            | 0.00                          |   |
| 16  |                   |                  |      |                            | 0.00                          |   |
| 17  |                   |                  |      |                            | 0.00                          |   |
| 18  |                   |                  |      |                            | 0.00                          |   |
| 19  |                   |                  |      |                            | 0.00                          |   |
| 20  |                   |                  |      |                            | 0.00                          |   |
| 21  |                   |                  |      |                            | 0.00                          |   |
| 22  |                   |                  |      |                            | 0.00                          |   |
| 23  |                   |                  |      |                            | 0.00                          |   |
| 24  |                   |                  |      |                            | 0.00                          |   |
| 25  |                   |                  |      |                            | 0.00                          |   |
| 26  |                   |                  |      |                            | 0.00                          |   |
| 27  |                   |                  |      |                            | 0.00                          |   |
| 28  |                   |                  |      |                            | 0.00                          |   |
| 29  |                   |                  |      |                            | 0.00                          |   |
| 30  |                   |                  |      |                            | 0.00                          |   |
| 31  |                   |                  |      |                            | 0.00                          |   |

|  |  |  |     |   |   |
|--|--|--|-----|---|---|
| <b>Cartridge &amp; Bag Filtration</b>    |  |  |     | <b>Monthly Summary (Answer Yes or No)</b> |   |
| 95% of daily turbidity readings ≤ 1 NTU? |  |  | Yes | CT's met everyday? (see back)             | All Cl2 residual at entry point ≥ 0.2 mg/l? |
| All daily turbidity readings ≤ 5 NTU?    |  |  | Yes | Yes                                       | Yes   |

|  |                                     |                         |
|--|-------------------------------------|-------------------------|
| Notes: PSI = pounds per square inch<br>PSID = pounds per square inch difference (before filter - after filter)<br>PSID When to Change Filter = look in manual for manufacturer's specifications when to change the filter, at what PSID. | <b>PRINTED NAME: Nancy Johnston</b> |                         |
|  | <b>SIGNATURE: Nancy Johnston</b>    | <b>DATE: 01/10/2026</b> |
|  | <b>PHONE #: ( 541 )563-3401</b>     | <b>CERT #:</b>          |

<sup>1</sup> Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in Daily Turbidity Reading column may not correspond to continuous readings' maximum.

OHA - Drinking Water Services - Surface Water Quality Data Form

WTP- : a

|   |         |       |                    |   |
|---|---------|-------|--------------------|---|
| System Name: Alesa River RV Park & Marina | ID#: 41 | 92043 | Month/Year: Dec-25 | Disinfection<br>Giardia Log<br>Inactiv: 1 |
|---|---------|-------|--------------------|---|

| Date / Time | Minimum Cl <sub>2</sub> Residual at 1st User ( C ) <sup>2</sup> | Contact Time (T) | Actual CT    | Temp  | pH   | Required CT | CT Met? <sup>2</sup> | Peak Hourly Demand Flow |
|-------------|---|------------------|--------------|-------|------|-------------|----------------------|-------------------------|
|             | [ppm or mg/L]   | [minutes]        | <b>C X T</b> | [° C] |      | formula     | Yes / No             | [GPM]                   |
| 1           | 1.91  | 104              | 198.6        | 14.2  | 6.90 | 30.7        | YES                  |                         |
| 2           | 1.92  | 104              | 199.7        | 14.3  | 6.90 | 30.5        | YES                  |                         |
| 3           | 1.99  | 104              | 207.0        | 14.2  | 6.90 | 31.0        | YES                  |                         |
| 4           | 2   | 104              | 208.0        | 14.2  | 6.80 | 29.9        | YES                  |                         |
| 5           | 2.1   | 104              | 218.4        | 14.2  | 7.00 | 32.6        | YES                  |                         |
| 6           | 2.1   | 104              | 218.4        | 14.3  | 7.00 | 32.4        | YES                  |                         |
| 7           | 2.22  | 104              | 230.9        | 14.3  | 6.90 | 31.6        | YES                  |                         |
| 8           | 2   | 104              | 208.0        | 14.2  | 6.90 | 31.0        | YES                  |                         |
| 9           | 2.1   | 104              | 218.4        | 14.2  | 6.90 | 31.4        | YES                  |                         |
| 10          | 2.15  | 104              | 223.6        | 14.1  | 6.90 | 31.8        | YES                  |                         |
| 11          | 2.3   | 104              | 239.2        | 14.1  | 6.80 | 31.2        | YES                  |                         |
| 12          | 2.25  | 104              | 234.0        | 14.1  | 6.80 | 31.0        | YES                  |                         |
| 13          | 2.2   | 104              | 228.8        | 14.1  | 6.80 | 30.8        | YES                  |                         |
| 14          | 2.23  | 104              | 231.9        | 14.2  | 6.80 | 30.7        | YES                  |                         |
| 15          | 2.1   | 104              | 218.4        | 14.2  | 6.70 | 29.1        | YES                  |                         |
| 16          | 2.2   | 104              | 228.8        | 14.2  | 6.70 | 29.5        | YES                  |                         |
| 17          | 2.23  | 104              | 231.9        | 14.3  | 6.80 | 30.5        | YES                  |                         |
| 18          | 2.09  | 104              | 217.4        | 14.2  | 6.80 | 30.2        | YES                  |                         |
| 19          | 2.15  | 104              | 223.6        | 14.3  | 6.76 | 29.8        | YES                  |                         |
| 20          | 2.18  | 104              | 226.7        | 14.2  | 6.70 | 29.4        | YES                  |                         |
| 21          | 2.15  | 104              | 223.6        | 14.1  | 6.70 | 29.5        | YES                  |                         |
| 22          | 2.21  | 104              | 229.8        | 14.1  | 6.80 | 30.8        | YES                  |                         |
| 23          | 2.23  | 104              | 231.9        | 14.0  | 6.80 | 31.1        | YES                  |                         |
| 24          | 2.25  | 104              | 234.0        | 14.0  | 6.80 | 31.2        | YES                  |                         |
| 25          | 2.2   | 104              | 228.8        | 14.0  | 6.90 | 32.2        | YES                  |                         |
| 26          | 2.25  | 104              | 234.0        | 14.1  | 6.80 | 31.0        | YES                  |                         |
| 27          | 2.3   | 104              | 239.2        | 13.9  | 6.80 | 31.6        | YES                  |                         |
| 28          | 2.28  | 104              | 237.1        | 14.0  | 6.80 | 31.3        | YES                  |                         |
| 29          | 2.26  | 104              | 235.0        | 13.9  | 6.80 | 31.4        | YES                  |                         |
| 30          | 2.3   | 104              | 239.2        | 13.8  | 6.80 | 31.8        | YES                  |                         |
| 31          | 2.26  | 104              | 235.0        | 13.8  | 6.90 | 32.8        | YES                  |                         |

<sup>2</sup> If Cl<sub>2</sub> at entry point < 0.2 mg/l or CT not met, notify DWS within 24 hours.

Revised November 2022

Return by 10th of following month by email, fax, or mail to:

[dwp.dmce@oha.oregon.gov](mailto:dwp.dmce@oha.oregon.gov); 971-673-0694; or Drinking Water Services, PO Box 14350, Portland, OR 97293-0350