

OHA - Drinking Water Services - Surface Water Quality Data Form

County: Lincoln

Cartridge or Bag Filtration

Month/Year: Jan-26

System Name: Alsea River RV Park & Marina ID#: 41 92043 WTP ID: TP-

Day	PSI Before Filter	PSI After Filter	PSID	PSID When to Change Filter	Daily Turbidity Reading [NTU]	Highest Reading of the day ¹ [NTU]
1					0.00	
2					0.00	
3					0.00	
4					0.00	
5					0.00	
6					0.00	
7					0.00	
8					0.00	
9					0.00	
10					0.00	
11					0.00	
12					0.00	
13					0.00	
14					0.00	
15					0.00	
16					0.00	
17					0.00	
18					0.00	
19					0.00	
20					0.00	
21					0.00	
22					0.00	
23					0.00	
24					0.00	
25					0.00	
26					0.00	
27					0.00	
28					0.00	
29					0.00	
30					0.00	
31					0.00	

Cartridge & Bag Filtration				Monthly Summary (Answer Yes or No)	
95% of daily turbidity readings ≤ 1 NTU?		Yes		CT's met everyday? (see back)	All Cl2 residual at entry point ≥ 0.2 mg/l?
All daily turbidity readings ≤ 5 NTU?		Yes		Yes	Yes

Notes: PSI = pounds per square inch PSID = pounds per square inch difference (before filter - after filter) PSID When to Change Filter = look in manual for manufacturer's specifications when to change the filter, at what PSID.	PRINTED NAME: Nancy Johnston	
	SIGNATURE: Nancy Johnston	DATE: 02/15/2026
	PHONE #: (541)563-3401	CERT #:

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in Daily Turbidity Reading column may not correspond to continuous readings' maximum.

OHA - Drinking Water Services - Surface Water Quality Data Form

WTP- : a

System Name: Alesa River RV Park & Marina	ID#: 41	92043	Month/Year: Jan-26	Disinfection Giardia Log Inactiv: 1
---	---------	-------	--------------------	---

Date / Time	Minimum Cl ₂ Residual at 1st User (C) ²	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ²	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
1	2.1	104	218.4	13.6	7.00	33.9	YES	
2	1.95	104	202.8	13.7	6.90	31.9	YES	
3	1.6	104	166.4	13.5	6.90	31.1	YES	
4	1.62	104	168.5	13.5	6.80	30.0	YES	
5	1.6	104	166.4	13.7	6.80	29.5	YES	
6	1.65	104	171.6	13.5	6.80	30.1	YES	
7	1.63	104	169.5	13.5	6.90	31.2	YES	
8	1.63	104	169.5	13.5	6.80	30.0	YES	
9	1.6	104	166.4	13.6	6.80	29.7	YES	
10	1.64	104	170.6	13.6	6.90	31.0	YES	
11	1.61	104	167.4	13.7	6.70	28.5	YES	
12	1.6	104	166.4	13.6	6.70	28.7	YES	
13	1.61	104	167.4	13.6	6.80	29.8	YES	
14	1.59	104	165.4	13.6	6.80	29.7	YES	
15	1.59	104	165.4	13.6	6.70	28.6	YES	
16	1.57	104	163.3	13.5	6.70	28.7	YES	
17	1.55	104	161.2	13.6	6.80	29.6	YES	
18	1.55	104	161.2	13.7	6.80	29.4	YES	
19	1.55	104	161.2	13.7	6.70	28.3	YES	
20	1.57	104	163.3	13.7	6.70	28.4	YES	
21	1.55	104	161.2	13.6	6.80	29.6	YES	
22	1.53	104	159.1	13.7	6.80	29.3	YES	
23	1.53	104	159.1	13.8	6.80	29.1	YES	
24	1.54	104	160.2	13.7	6.80	29.3	YES	
25	1.53	104	159.1	13.7	6.70	28.2	YES	
26	1.54	104	160.2	13.7	6.80	29.3	YES	
27	1.52	104	158.1	13.5	6.70	28.6	YES	
28	1.52	104	158.1	13.6	6.70	28.4	YES	
29	1.51	104	157.0	13.8	6.80	29.0	YES	
30	1.52	104	158.1	13.7	6.70	28.2	YES	
31	1.51		0.0	13.7	6.70	28.2	NO	

² If Cl₂ at entry point < 0.2 mg/l or CT not met, notify DWS within 24 hours.

Revised November 2022

Return by 10th of following month by email, fax, or mail to:

dwp.dmce@oha.oregon.gov; 971-673-0694; or Drinking Water Services, PO Box 14350, Portland, OR 97293-0350