

OHA - Drinking Water Services - Surface Water Quality Data Form

County: Lincoln

Cartridge or Bag Filtration

Month/Year: 1-2021

System Name:	Mad Dog Country Tavern			ID#:	41 92052	WTP ID:	TP- A
Day	PSI Before Filter	PSI After Filter	PSID	PSID When to Change Filter	Daily Turbidity Reading [NTU]	Highest Reading of the day ¹ [NTU]	
1					22		
2					21		
3					18		
4					16		
5					15		
6					14		
7					17		
8					18		
9					18		
10					19		
11					17		
12					16		
13					20		
14					22		
15					21		
16					22		
17					20		
18					21		
19					18		
20					19		
21					23		
22					26		
23					25		
24					20		
25					21		
26					21		
27					22		
28					24		
29					20		
30					21		
31					20		

Cartridge & Bag Filtration		Monthly Summary (Answer Yes or No)	
95% of daily turbidity readings ≤ 1 NTU?	Yes/No	CT's met everyday? (see back)	All Cl2 residual at entry point ≥ 0.2 mg/l?
All daily turbidity readings ≤ 5 NTU?	Yes/No	Yes/No	Yes/No

Notes: PSI = pounds per square inch
 PSID = pounds per square inch difference (before filter - after filter)
 PSID When to Change Filter = look in manual for manufacturer's specifications when to change the filter, at what PSID.

PRINTED NAME: T. J. WISKY
SIGNATURE: [Signature]
DATE: 2-1-21
PHONE #: (541) 265-8761
CERT #:

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in Daily Turbidity Reading column may not correspond to continuous readings' maximum.

RECEIVED
 FEB 5 2021
 PAGE 1 of 2

copy

OHA - Drinking Water Services - Surface Water Quality Data Form

A	
Disinfection Gardis Log Inactiv:	1

System Name: Mad Dog Country Tavern ID#: 41 92052 Month/Year: January 2021

Date / Time	Minimum Cl ₂ Residual at 1st User (C) ²	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ²	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[°C]		formula	Yes / No	[GPM]
1	1.16	71	116	13.1	72	34	yes	5
2	1.10	71	110	12.8	72	36	yes	5
3	1.24	71	124	12.7	72	37	yes	5
4	1.60	71	160	12.5	72	37	yes	5
5	1.79	71	179	12.7	72	38	yes	5
6	1.72	71	172	12.9	72	38	yes	5
7	1.97	71	191	13.1	72	36	yes	5
8	2.01	71	201	13.1	72	36	yes	5
9	2.13	71	213	13.2	72	36	yes	5
10	2.20	71	220	13.2	72	36	yes	5
11	2.03	71	203	12.7	72	40	yes	5
12	2.20	71	220	14.1	72	33	yes	5
13	2.20	71	220	13.6	72	36	yes	5
14	2.28	71	220	12.6	72	40	yes	5
15	2.20	71	220	13.8	72	36	yes	5
16	2.20	71	220	14.3	72	33	yes	5
17	2.20	71	220	13.5	72	36	yes	5
18	2.20	71	220	12.9	72	40	yes	5
19	2.20	71	220	13.5	72	36	yes	5
20	2.20	71	220	12.7	72	40	yes	5
21	2.20	71	220	13.2	72	36	yes	5
22	2.00	71	220	11.6	72	43	yes	5
23	2.20	71	220	10.6	72	46	yes	5
24	2.20	71	220	10.9	72	46	yes	5
25	2.20	71	220	11.2	72	43	yes	5
26	2.20	71	220	11.3	72	43	yes	5
27	2.20	71	220	11.6	72	43	yes	5
28	2.20	71	220	11.8	72	43	yes	5
29	2.20	71	220	11.4	72	43	yes	5
30	2.20	71	220	11.5	72	43	yes	5
31	2.20	71	220	11.7	72	43	yes	5

² If Cl₂ at entry point < 0.2 mg/l or CT not met, notify DWS within 24 hours.