

OHA - Drinking Water Services - Surface Water Quality Data Form

County: Lincoln

Month/Year: 5-2021

Cartridge or Bag Filtration

System Name: Mad Dog Country Tavern ID#: 41 92052 WTP ID: TP- A

Day	PSI Before Filter	PSI After Filter	PSID	PSID When to Change Filter	Daily Turbidity Reading (NTU)	Highest Reading of the day <sup>1</sup> (NTU)
1					.28	
2					.21	
3					.23	
4					.20	
5					.19	
6					.21	
7					.23	
8					.22	
9					.24	
10					.22	
11					.21	
12					.23	
13					.25	
14					.24	
15					.21	
16					.20	
17					.24	
18					.22	
19					.19	
20					.21	
21					.25	
22					.23	
23					.23	
24					.20	
25					.21	
26					.18	
27					.24	
28					.20	
29					.18	
30					.19	
31					.21	

RECEIVED  
 JUN 03 2021  
 Data Mgmt. & Compliance  
 Drinking Water Program

<b>Cartridge &amp; Bag Filtration</b> 95% of daily turbidity readings ≤ 1 NTU? <input checked="" type="radio"/> Yes / <input type="radio"/> No All daily turbidity readings ≤ 5 NTU? <input checked="" type="radio"/> Yes / <input type="radio"/> No		<b>Monthly Summary (Answer Yes or No)</b> CTe not everyday? (see back) <input checked="" type="radio"/> Yes / <input type="radio"/> No All Cl2 residual at entry point ≥ 0.2 mg/l? <input checked="" type="radio"/> Yes / <input type="radio"/> No	
Notes: PSI = pounds per square inch PSID = pounds per square inch difference (before filter - after filter) PSID When to Change Filter = look in manual for manufacturer's specifications when to change the filter, at what PSID.		PRINTED NAME: TJ WISKY SIGNATURE: <i>TJ Wisky</i> PHONE #: (541) 265-8761 DATE: 5-31-21 CERT #:	

<sup>1</sup> Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in Daily Turbidity Reading column may not correspond to continuous readings' maximum.

Copy

OHA - Drinking Water Services - Surface Water Quality Data Form

<b>System Name:</b> Mad Dog Country Tavern	<b>ID#:</b> 41	<b>92052</b>	<b>Month/Year:</b> May 2021	<b>A</b>	<b>Disinfection</b> <b>Giardia Log</b> <b>Inactiv:</b>	<b>1</b>
--	----------------	--------------	-----------------------------	----------	--	----------

Date / Time	Minimum Cl <sub>2</sub> Residual at 1st User (C) <sup>2</sup>	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? <sup>2</sup>	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
1	1.06	71	106	18.5	72	23	yes	5
2	1.94	71	194	18.5	72	26	yes	5
3	1.87	71	187	18.2	72	26	yes	5
4	2.20	71	220	17.9	72	27	yes	5
5	2.20	71	220	17.0	72	27	yes	5
6	2.20	71	220	17.8	72	27	yes	5
7	2.20	71	220	17.1	72	27	yes	5
8	2.20	71	220	17.0	72	27	yes	5
9	2.20	71	220	18.0	72	26	yes	5
10	2.20	71	220	18.2	72	26	yes	5
11	2.20	71	220	17.5	72	27	yes	5
12	2.20	71	220	18.0	72	26	yes	5
13	2.01	71	201	18.0	72	26	yes	5
14	1.86	71	186	18.1	72	26	yes	5
15	1.42	71	142	17.7	72	26	yes	5
16	1.08	71	108	18.5	72	23	yes	5
17	1.47	71	147	17.8	72	26	yes	5
18	1.35	71	185	17.8	72	27	yes	5
19	1.32	71	132	16.9	72	26	yes	5
20	1.57	71	157	16.2	72	27	yes	5
21	1.94	71	194	17.2	72	27	yes	5
22	2.18	71	218	17.6	72	27	yes	5
23	2.20	71	220	17.9	72	27	yes	5
24	2.02	71	202	17.5	72	27	yes	5
25	2.01	71	201	18.7	72	26	yes	5
26	1.83	71	183	17.9	72	27	yes	5
27	1.46	71	146	18.1	72	24	yes	5
28	1.34	71	134	18.5	72	24	yes	5
29	1.75	71	174	18.4	72	26	yes	5
30	1.72	71	172	18.4	72	26	yes	5
31	1.65	71	165	18.5	72	26	yes	5

<sup>2</sup> If Cl<sub>2</sub> at entry point < 0.2 mg/l or CT not met, notify DWS within 24 hours.