

OHA - Drinking Water Services - Surface Water Quality Data Form

County: Lincoln

Cartridge or Bag Filtration

Month/Year: 6-2021

System Name:	Mad Dog Country Tavern		ID#:	41 92052	WTP ID:	TP- A
Day	PSI Before Filter	PSI After Filter	PSID	PSID When to Change Filter	Daily Turbidity Reading [NTU]	Highest Reading of the day ¹ [NTU]
1					23	
2					24	
3					26	
4					24	
5					21	
6					20	
7					18	
8					19	
9					17	
10					19	
11					23	
12					20	
13					20	
14					24	
15					22	
16					25	
17					21	
18					20	
19					22	
20					24	
21					20	
22					22	
23					23	
24					25	
25					22	
26					21	
27					24	
28					25	
29					21	
30					23	
31						

Cartridge & Bag Filtration		Monthly Summary (Answer Yes or No)	
95% of daily turbidity readings ≤ 1 NTU?	<input checked="" type="radio"/> Yes / <input type="radio"/> No	CT's met everyday? (see back)	All Cl2 residual at entry point ≥ 0.2 mg/l?
All daily turbidity readings ≤ 5 NTU?	<input checked="" type="radio"/> Yes / <input type="radio"/> No	<input checked="" type="radio"/> Yes / <input type="radio"/> No	<input checked="" type="radio"/> Yes / <input type="radio"/> No

Notes: PSI = pounds per square inch
 PSID = pounds per square inch difference (before filter - after filter)
 PSID When to Change Filter = look in manual for manufacturer's specifications when to change the filter, at what PSID.
¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in Daily Turbidity Reading column may not correspond to continuous readings' maximum.

PRINTED NAME: TJ WISKY
 SIGNATURE: *TJ Wisky* DATE: 6-30-21
 PHONE #: (541) 265-5761 CERT #:

copy

OHA - Drinking Water Services - Surface Water Quality Data Form

System Name: Mad Dog Country Tavern	ID#: 41	92052	Month/Year: June 2021	A	Disinfection Giardia Log Inactiv:	1
--	----------------	--------------	------------------------------	----------	--	----------

Date / Time	Minimum Cl ₂ Residual at 1st User (C) ²	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ²	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		formula	Yes / No	[GPM]
1	2.18	71	218	20.2	72	23	yes	5
2	1.78	71	178	20.5	72	23	yes	5
3	1.53	71	153	21.2	72	20	yes	5
4	2.20	71	220	20.1	72	23	yes	5
5	2.20	71	220	19.8	72	24	yes	5
6	2.20	71	220	19.4	72	24	yes	5
7	1.55	71	155	19.5	72	23	yes	5
8	1.79	71	179	18.3	72	25	yes	5
9	2.20	71	220	18.0	72	26	yes	5
10	2.20	71	220	18.7	72	26	yes	5
11	2.15	71	215	19.1	72	24	yes	5
12	1.69	71	169	19.8	72	24	yes	5
13	1.39	71	139	21.1	72	19	yes	5
14	1.27	71	127	19.9	72	22	yes	5
15	1.62	71	162	20.2	72	22	yes	5
16	2.20	71	220	19.4	72	24	yes	5
17	2.20	71	220	19.7	72	24	yes	5
18	2.20	71	220	20.0	72	23	yes	5
19	2.20	71	220	19.0	72	24	yes	5
20	2.20	71	220	19.7	72	24	yes	5
21	2.20	71	220	20.4	72	23	yes	5
22	2.20	71	220	20.1	72	23	yes	5
23	2.00	71	200	20.1	72	23	yes	5
24	1.53	71	153	19.9	72	23	yes	5
25	1.32	71	132	20.3	72	21	yes	5
26	0.93	71	93	21.0	72	19	yes	5
27	1.84	71	184	22.3	72	20	yes	5
28	2.02	71	202	21.6	72	21	yes	5
29	2.20	71	220	21.0	72	21	yes	5
30	2.20	71	220	21.0	72	21	yes	5
31								

² If Cl₂ at entry point < 0.2 mg/l or CT not met, notify DWS within 24 hours.