

OHA - Drinking Water Services - Surface Water Quality Data Form

County: Lincoln

Cartridge or Bag Filtration

Month/Year: 7-2021

System Name:	Mad Dog Country Tavern			ID#:	41	92052	WTP ID:	TP-	A
Day	PSI Before Filter	PSI After Filter	PSID	PSID When to Change Filter	Daily Turbidity Reading [NTU]	Highest Reading of the day <sup>1</sup> [NTU]			
1					23				
2					19				
3					20				
4					18				
5					21				
6					20				
7					22				
8					24				
9					23				
10					21				
11					21				
12					20				
13					23				
14					25				
15					23				
16					20				
17					21				
18					22				
19					21				
20					20				
21					19				
22					22				
23					20				
24					24				
25					23				
26					21				
27					22				
28					23				
29					25				
30					21				
31					23				

<b>Cartridge &amp; Bag Filtration</b>		<b>Monthly Summary (Answer Yes or No)</b>	
95% of daily turbidity readings ≤ 1 NTU?	Yes / No	CT's met everyday? (see back)	All Cl2 residual at entry point ≥ 0.2 mg/l?
All daily turbidity readings ≤ 5 NTU?	Yes / No	Yes / No	Yes / No

Notes: PSI = pounds per square inch  
 PSID = pounds per square inch difference (before filter - after filter)  
 PSID When to Change Filter = look in manual for manufacturer's specifications when to change the filter at what PSID.

PRINTED NAME: TJ. Wisker
SIGNATURE: [Signature]
PHONE #: (811) 265-8761
DATE: 8-1-21
CERT #:

<sup>1</sup> Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in Daily Turbidity Reading column may not correspond to continuous readings' maximum.



copy

OHA - Drinking Water Services - Surface Water Quality Data Form

A
Disinfection Giardia Log Inactiv:
1

System Name: Mad Dog Country Tavern ID#: 41 92052 Month/Year: July 2021

Date / Time	Minimum Cl <sub>2</sub> Residual at 1st User (C) <sup>2</sup>	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? <sup>2</sup>	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C x T	[°C]		formula	Yes / No	[GPM]
1	2.00	71	200	21.8	72	21	yes	5
2	1.92	71	192	20.9	72	24	yes	5
3	1.28	71	128	21.8	72	19	yes	5
4	.79	71	79	22.2	72	17	yes	5
5	.96	71	96	21.4	72	19	yes	5
6	.94	71	94	21.1	72	19	yes	5
7	1.01	71	101	21.0	72	19	yes	5
8	.86	71	86	20.4	72	20	yes	5
9	.79	71	79	20.4	72	20	yes	5
10	1.13	71	113	20.9	72	21	yes	5
11	1.23	71	123	20.8	72	21	yes	5
12	1.36	71	136	20.1	72	21	yes	5
13	1.36	71	136	19.8	72	22	yes	5
14	1.31	71	131	19.9	72	22	yes	5
15	1.29	71	129	20.2	72	21	yes	5
16	1.28	71	128	20.4	72	21	yes	5
17	1.36	71	136	20.3	72	22	yes	5
18	1.48	71	148	20.7	72	22	yes	5
19	1.49	71	149	20.1	72	22	yes	3
20	1.29	71	129	21.6	72	19	yes	5
21	1.13	71	113	20.5	72	21	yes	5
22	.95	71	95	19.9	72	22	yes	5
23	.83	71	83	20.2	72	21	yes	5
24	.67	71	67	21.0	72	18	yes	5
25	.62	71	62	20.1	72	20	yes	5
26	.87	71	87	20.3	72	21	yes	5
27	1.11	71	111	20.1	72	21	yes	5
28	1.67	71	167	19.3	72	23	yes	5
29	2.08	71	208	21.1	72	21	yes	5
30	2.20	71	220	21.5	72	21	yes	5
31	2.20	71	220	21.7	72	21	yes	5

<sup>2</sup> If Cl<sub>2</sub> at entry point < 0.2 mg/l or CT not met, notify DWS within 24 hours.

Revised October 2013