

**OHA - Drinking Water Program – Turbidity Monitoring Report Form County:
Cartridge or Bag Filtration**

System Name: Mad Dog Country Tavern ID #: 084192052 WTP-: WTP-A Month/Year: 9-2021

DAY	PSI Before Filter	PSI After Filter	PSID	PSID When to Change Filter	Daily Turbidity Reading [NTU]	Highest Reading of the Day ¹ [NTU]
1					.24	
2					.21	
3					.20	
4					.22	
5					.23	
6					.25	
7					.23	
8					.24	
9					.22	
10					.20	
11					.22	
12					.24	
13					.21	
14					.23	
15					.23	
16					.24	
17					.26	
18					.27	
19					.29	
20					.26	
21					.24	
22					.23	
23					.25	
24					.27	
25					.23	
26					.20	
27					.21	
28					.20	
29					.23	
30					.22	
31						

Cartridge Filtration		Monthly Summary (Answer Yes or No)	
95% of daily turbidity readings ≤ 1 NTU? All daily turbidity readings ≤ 5 NTU?	<input checked="" type="radio"/> Yes / <input type="radio"/> No <input checked="" type="radio"/> Yes / <input type="radio"/> No	CT's met everyday? (see back) <input checked="" type="radio"/> Yes / <input type="radio"/> No	All Cl ₂ residual at entry point ≥ 0.2 mg/l? <input checked="" type="radio"/> Yes / <input type="radio"/> No
Notes: PSI = pounds per square inch PSID = pounds per square inch difference (before filter – after filter) PSID When to Change Filter = Manufacturer's recommendation; may need to look in manual for manufacturer's specifications when to change the filter, at what PSID.		PRINTED NAME: Anthony Ulsky SIGNATURE: <i>Anthony Ulsky</i> DATE: 9-30-21	
OCT 04 2021 Data Mgmt & Compliance Drinking Water Program		PHONE #: (541) 265-8761	CERT #:

Including continuous turbidity data, if applicable, for optimization recording purposes. Compliance values in "Daily Turbidity Reading" Column may not correspond to continuous readings' maximum.

OHA - Drinking Water Program – Surface Water Quality Data Form

System Name: Mad Dog Country Tavern

ID #: OR-4192052

WTP: WTP-A Month/Year: September 2021

Date / Time	Minimum Cl ₂ Residual at 1 st User (C) ²	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ²	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[°C]		Use tables	Yes / No	[GPM]
11	1.63	71	163	15.2	72	29	yes	5
21	1.17	71	117	18.7	72	23	yes	5
31	1.01	71	101	18.5	72	23	yes	5
41	1.62	71	162	19.3	72	23	yes	5
51	2.20	71	220	19.7	72	24	yes	5
61	2.20	71	220	19.9	72	24	yes	5
71	2.20	71	220	19.9	72	24	yes	5
81	1.69	71	169	19.7	72	23	yes	5
91	.94	71	94	19.1	72	22	yes	5
101	.44	71	44	17.1	72	23	yes	5
111	.62	71	62	19.7	72	21	yes	5
121	.68	71	68	19.6	72	21	yes	5
131	.83	71	83	19.4	72	22	yes	5
141	1.12	71	112	18.5	72	23	yes	5
151	2.12	71	212	20.2	72	23	yes	5
161	2.20	71	220	18.3	72	26	yes	5
171	2.20	71	220	18.3	72	26	yes	5
181	1.83	71	183	19.5	72	24	yes	5
191	2.20	71	220	19.0	72	24	yes	5
201	2.20	71	220	19.0	72	24	yes	5
211	1.04	71	104	19.4	72	22	yes	5
221	.97	71	97	19.4	72	22	yes	5
231	1.01	71	101	18.6	72	23	yes	5
241	.92	71	92	18.7	72	23	yes	5
251	.64	71	64	18.9	72	22	yes	5
261	.41	71	41	19.4	72	21	yes	5
271	1.26	71	126	19.7	72	22	yes	5
281	.96	71	96	18.1	72	23	yes	5
291	1.10	71	110	18.1	72	23	yes	5
301	1.28	71	128	19.1	72	22	yes	5
311								

If Cl₂ at entry point < 0.2 mg/l, OR CT not met, notify DWP by end of next business day.

Revised February 2012

Download form at: public.health.oregon.gov/HealthyEnvironments/DrinkingWater/Monitoring/Documents/turb-cartridge.pdf