

**OHA - Drinking Water Program - Turbidity Monitoring Report Form County:
Cartridge or Bag Filtration**

System Name: Mad Dog Country Tavern ID #: 084192052 WTP: WTP-A Month/Year: November 2021

DAY	PSI Before Filter	PSI After Filter	PSID	PSID When to Change Filter	Daily Turbidity Reading [NTU]	Highest Reading of the Day ¹ [NTU]
1					.24	
2					.32	
3					.34	
4					.31	
5					.30	
6					.25	
7					.24	
8					.26	
9					.27	
10					.23	
11					.24	
12					.27	
13					.25	
14					.29	
15					.30	
16					.31	
17					.32	
18					.30	
19					.28	
20					.25	
21					.31	
22					.30	
23					.29	
24					.34	
25					.36	
26					.35	
27					.30	
28					.32	
29					.30	
30					.28	
31						

Cartridge Filtration		Monthly Summary (Answer Yes or No)	
95% of daily turbidity readings ≤ 1 NTU? All daily turbidity readings ≤ 5 NTU?	<input checked="" type="radio"/> Yes / <input type="radio"/> No <input checked="" type="radio"/> Yes / <input type="radio"/> No	CT's met everyday? (see back) <input checked="" type="radio"/> Yes / <input type="radio"/> No	All Cl ₂ residual at entry point ≥ 0.2 mg/l? <input checked="" type="radio"/> Yes / <input type="radio"/> No
Notes: PSI = pounds per square inch PSID = pounds per square inch difference (before filter - after filter) PSID When to Change Filter = Manufacturer's recommendation; may need to look in manual for manufacturer's specifications when to change the filter, at what PSID.		PRINTED NAME: <u>T.J. WISKY</u>	
		SIGNATURE: <u>T.J. Wisky</u>	
		DATE: <u>11-30-2021</u>	
		PHONE #: <u>(841) 265-8761</u>	CERT #:

Including continuous turbidity data, if applicable, for optimization recording purposes. Compliance values in "Daily Turbidity Reading" Column may not correspond to continuous readings' maximum.
PAGE 1 of 2

OHA - Drinking Water Program - Surface Water Quality Data Form

System Name: Mad Dog Country Tavern

ID #: OR4192052

WTP: WTP-A Month/Year: November 2021

Date / Time	Minimum Cl ₂ Residual at 1 st User (C) ²	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ²	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	CXT	[° C]		Use tables	Yes / No	[GPM]
1/	2.20	71	220	17.9	72	27	yes	5
2/	2.20	71	220	18.4	72	26	yes	5
3/	2.20	71	220	19.1	72	24	yes	5
4/	2.20	71	220	19.6	72	24	yes	5
5/	2.20	71	220	19.0	72	24	yes	5
6/	2.20	71	220	17.7	72	27	yes	5
7/	2.20	71	220	16.5	72	29	yes	5
8/	2.20	71	220	16.4	72	29	yes	5
9/	2.20	71	220	16.1	72	29	yes	5
10/	2.20	71	220	16.6	72	29	yes	5
11/	2.11	71	211	17.8	72	27	yes	5
12/	2.04	71	204	19.7	72	24	yes	5
13/	2.05	71	205	19.4	72	24	yes	5
14/	2.05	71	205	19.3	72	24	yes	5
15/	2.06	71	206	19.0	72	24	yes	5
16/	1.63	71	163	17.7	72	26	yes	5
17/	2.20	71	220	16.5	72	29	yes	5
18/	2.20	71	220	16.9	72	29	yes	5
19/	2.20	71	220	17.1	72	27	yes	5
20/	2.20	71	220	15.7	72	30	yes	5
21/	2.20	71	220	15.3	72	30	yes	5
22/	2.20	71	220	14.9	72	33	yes	5
23/	2.20	71	220	15.7	72	30	yes	5
24/	2.20	71	220	15.0	72	30	yes	5
25/	2.20	71	220	15.3	72	30	yes	5
26/	2.20	71	220	16.9	72	29	yes	5
27/	2.20	71	220	16.6	72	29	yes	5
28/	2.20	71	220	18.5	72	26	yes	5
29/	2.20	71	220	17.7	72	27	yes	5
30/	2.20	71	220	16.4	72	29	yes	5
31/								

² If Cl₂ at entry point < 0.2 mg/l, OR CT not met, notify DWP by end of next business day.

Revised February 2012

Download form at: public.health.oregon.gov/HealthyEnvironments/DrinkingWater/Monitoring/Documents/turb-cartridge.pdf