

OHA - Drinking Water Program - Turbidity Monitoring Report Form County:  
Cartridge or Bag Filtration

System Name: Mad Dog Country Tavern ID #: 084194052 WTP: WTP-A Month/Year: December 2021

DAY	PSI Before Filter	PSI After Filter	PSID	PSID When to Change Filter	Daily Turbidity Reading [NTU]	Highest Reading of the Day <sup>1</sup> [NTU]
1					.31	
2					.28	
3					.24	
4					.22	
5					.23	
6					.23	
7					.19	
8					.20	
9					.21	
10					.24	
11					.21	
12					.25	
13					.20	
14					.22	
15					.24	
16					.26	
17					.21	
18					.19	
19					.21	
20					.23	
21					.22	
22					.27	
23					.26	
24					.23	
25					.25	
26					.20	
27					.19	
28					.22	
29					.24	
30					.23	
31					.20	

<b>Cartridge Filtration</b>		<b>Monthly Summary (Answer Yes or No)</b>	
95% of daily turbidity readings ≤ 1 NTU? All daily turbidity readings ≤ 5 NTU?	<input checked="" type="radio"/> Yes / <input type="radio"/> No <input checked="" type="radio"/> Yes / <input type="radio"/> No	CT's met everyday? (see back) <input checked="" type="radio"/> Yes / <input type="radio"/> No	All Cl <sub>2</sub> residual at entry point ≥ 0.2 mg/l? <input checked="" type="radio"/> Yes / <input type="radio"/> No
Notes: PSI = pounds per square inch PSID = pounds per square inch difference (before filter - after filter) PSID When to Change Filter = Manufacturer's recommendation; may need to look in manual for manufacturer's specifications when to change the filter, at what PSID.		PRINTED NAME: <b>TA WISKY</b> SIGNATURE: <i>TJ Wisky</i> DATE: <b>12-31-21</b>	
JAN 06 2021 Data Mgmt & Compliance Drinking Water Program		PHONE #: (541) 265-8761 CERT #:	

Including continuous turbidity data, if applicable, for optimization recording purposes. Compliance values in "Daily Turbidity Reading" Column may not correspond to continuous readings' maximum.



# OHA - Drinking Water Program – Surface Water Quality Data Form

System Name: Mad Dog Country Tavern

ID #: OR4192052

WTP: WTP-A Month/Year: December 2021

Date / Time	Minimum Cl <sub>2</sub> Residual at 1 <sup>st</sup> User (C) <sup>2</sup>	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? <sup>2</sup>	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	CXT	[° C]		Use tables	Yes / No	[GPM]
11	2.20	71	220	14.5	72	33	yes	5
21	2.20	71	220	17.9	72	27	yes	5
31	1.95	71	195	16.2	72	29	yes	5
41	1.62	71	162	15.1	72	29	yes	5
51	1.23	71	123	15.3	72	28	yes	5
61	1.02	71	102	15.4	72	28	yes	5
71	.99	71	99	15.7	72	27	yes	5
81	.77	71	77	16.7	72	25	yes	5
91	1.01	71	101	16.1	72	26	yes	5
101	1.19	71	119	14.8	72	30	yes	5
111	1.78	71	178	15.2	72	29	yes	5
121	2.20	71	220	15.3	72	30	yes	5
131	2.20	71	220	14.8	72	33	yes	5
141	2.20	71	220	14.3	72	33	yes	5
151	2.20	71	220	13.7	72	36	yes	5
161	2.19	71	219	14.2	72	33	yes	5
171	2.20	71	220	15.0	72	30	yes	5
181	2.20	71	220	15.9	72	30	yes	5
191	1.32	71	132	15.6	72	28	yes	5
201	2.03	71	203	14.9	72	33	yes	5
211	2.16	71	216	15.2	72	30	yes	5
221	2.20	71	220	16.8	72	29	yes	5
231	2.20	71	220	15.3	72	30	yes	5
241	2.20	71	220	15.3	72	30	yes	5
251	2.20	71	220	14.7	72	33	yes	5
261	2.20	71	220	12.5	72	40	yes	5
271	1.92	71	192	12.7	72	39	yes	5
281	1.63	71	163	12.9	72	38	yes	5
291	1.52	71	152	13.7	72	34	yes	5
301	1.56	71	156	14.4	72	31	yes	5
311	1.83	71	183	13.7	72	36	yes	5

If Cl<sub>2</sub> at entry point < 0.2 mg/l, OR CT not met, notify DWP by end of next business day.

Revised February 2012

Download form at: [public.health.oregon.gov/HealthyEnvironments/DrinkingWater/Monitoring/Documents/turb-cartridge.pdf](http://public.health.oregon.gov/HealthyEnvironments/DrinkingWater/Monitoring/Documents/turb-cartridge.pdf)

