

OHA - Drinking Water Services - Surface Water Quality Data Form

County: Lincoln

Cartridge or Bag Filtration January/2022 Month/Year: 1-2022

System Name: Mad Dog Country Tavern ID#: 41 92052 WTP ID: TP- A

Day	PSI Before Filter	PSI After Filter	PSID	PSID When to Change Filter	Daily Turbidity Reading [NTU]	Highest Reading of the day ¹ [NTU]
1					.22	
2					.24	
3					.20	
4					.21	
5					.23	
6					.25	
7					.23	
8					.21	
9					.20	
10					.22	
11					.20	
12					.19	
13					.18	
14					.19	
15					.23	
16					.21	
17					.24	
18					.22	
19					.25	
20					.22	
21					.22	
22					.23	
23					.24	
24					.21	
25					.21	
26					.23	
27					.20	
28					.18	
29					.19	
30					.23	
31					.24	

Cartridge & Bag Filtration		Monthly Summary (Answer Yes or No)	
95% of daily turbidity readings ≤ 1 NTU?	<input checked="" type="radio"/> Yes / <input type="radio"/> No	CT's met everyday? (see back)	<input checked="" type="radio"/> Yes / <input type="radio"/> No
All daily turbidity readings ≤ 5 NTU?	<input checked="" type="radio"/> Yes / <input type="radio"/> No	All Cl2 residual at entry point ≥ 0.2 mg/l?	<input checked="" type="radio"/> Yes / <input type="radio"/> No

Notes: PSI = pounds per square inch
 PSID = pounds per square inch difference (before filter - after filter)
 PSID When to Change Filter = look in manual for manufacturer's specifications when to change the filter, at what PSID.

PRINTED NAME: TJ UISKY
 SIGNATURE: [Signature] DATE: _____
 PHONE #: (541) 265-8261 CERT #: _____

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in Daily Turbidity Reading column may not correspond to continuous readings' maximum.

copy

OHA - Drinking Water Services - Surface Water Quality Data Form

System Name: Mad Dog Country Tavern	ID#: 41	92052	Month/Year: January 2022	A
				Disinfection Gardis Log Inactiv: 1

Date / Time	Minimum Cl ₂ Residual at 1st User (C) ²	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ²	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	CXT	[°C]		formula	Yes / No	[GPM]
1	2.20	71	220	13.8	72	36	yes	5
2	2.20	71	220	12.8	72	40	yes	5
3	2.20	71	220	13.4	72	36	yes	5
4	2.20	71	220	13.6	72	36	yes	5
5	2.20	71	220	15.0	72	30	yes	5
6	2.20	71	220	17.4	72	27	yes	5
7	2.20	71	220	14.9	72	33	yes	5
8	2.20	71	220	13.7	72	36	yes	5
9	2.02	71	202	14.2	72	33	yes	5
10	1.75	71	175	14.1	72	32	yes	5
11	1.59	71	159	16.9	72	27	yes	5
12	1.51	71	151	16.4	72	27	yes	5
13	1.51	71	151	16.8	72	27	yes	5
14	2.13	71	213	16.3	72	29	yes	5
15	2.20	71	220	13.5	72	36	yes	5
16	2.20	71	220	14.8	72	33	yes	5
17	2.20	71	220	14.7	72	33	yes	5
18	2.20	71	220	15.3	72	30	yes	5
19	2.20	71	220	16.4	72	29	yes	5
20	2.20	71	220	16.3	72	29	yes	5
21	1.95	71	195	15.7	72	30	yes	5
22	1.78	71	178	13.5	72	35	yes	5
23	1.66	71	166	14.4	72	32	yes	5
24	1.27	71	127	13.7	72	34	yes	5
25	1.05	71	105	14.4	72	30	yes	5
26	1.02	71	102	14.9	72	30	yes	5
27	0.76	71	76	13.4	72	32	yes	5
28	0.77	71	77	13.2	72	32	yes	5
29	1.21	71	121	13.2	72	34	yes	5
30	1.76	71	176	14.6	72	32	yes	5
31	2.20	71	220	13.9	72	36	yes	5

² If Cl₂ at entry point < 0.2 mg/l or CT not met, notify DWS within 24 hours.

Revised October 2013

RECEIVED
FEB 04 2022

Data Mgmt & Compliance
Drinking Water Program

RECEIVED
FEB 04 2022