

**OHA - Drinking Water Program - Turbidity Monitoring Report Form County:
Cartridge or Bag Filtration**

System Name: Mad Dog Country Tavern ID #: OR4194052 WTP-: WTP-A Month/Year: February 2022

DAY	PSI Before Filter	PSI After Filter	PSID	PSID When to Change Filter	Daily Turbidity Reading [NTU]	Highest Reading of the Day ¹ [NTU]
1					.20	
2					.22	
3					.21	
4					.25	
5					.23	
6					.22	
7					.22	
8					.26	
9					.25	
10					.22	
11					.23	
12					.27	
13					.24	
14					.25	
15					.26	
16					.28	
17					.25	
18					.27	
19					.24	
20					.23	
21					.26	
22					.23	
23					.25	
24					.26	
25					.27	
26					.25	
27					.22	
28					.23	
29						
30						
31						

Cartridge Filtration		Monthly Summary (Answer Yes or No)	
95% of daily turbidity readings ≤ 1 NTU? All daily turbidity readings ≤ 5 NTU?	<input checked="" type="radio"/> Yes / <input type="radio"/> No <input checked="" type="radio"/> Yes / <input type="radio"/> No	CT's met everyday? (see back) <input checked="" type="radio"/> Yes / <input type="radio"/> No	All Cl ₂ residual at entry point ≥ 0.2 mg/l? <input checked="" type="radio"/> Yes / <input type="radio"/> No
Notes: PSI = pounds per square inch PSID = pounds per square inch difference (before filter - after filter) PSID When to Change Filter = Manufacturer's recommendation; may need to look in manual for manufacturer's specifications when to change the filter, at what PSID.		PRINTED NAME: <u>TJ. Ulsky</u> SIGNATURE: <u>TJ Ulsky</u> DATE: <u>3-1-2022</u>	
MAR 07 2022 Data Mgmt & Compliance Drinking Water Program		PHONE #: <u>(541) 265-8761</u> CERT #:	

Including continuous turbidity data, if applicable, for optimization recording purposes. Compliance values in "Daily Turbidity Reading" Column may not correspond to continuous readings' maximum.

OHA - Drinking Water Program - Surface Water Quality Data Form

System Name: Mad Dog Country Tavern

ID #: OR4192052

WTP: WTP-A Month/Year: February 2022

Date / Time	Minimum Cl ₂ Residual at 1 st User (C) ²	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ²	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	CXT	[° C]		Use tables	Yes / No	[GPM]
1/	2.20	71	220	14.4	72	33	yes	5
2/	2.20	71	220	14.6	72	33	yes	5
3/	2.20	71	220	14.6	72	33	yes	5
4/	2.20	71	220	14.7	72	33	yes	5
5/	2.20	71	220	15.6	72	30	yes	5
6/	2.20	71	220	14.2	72	33	yes	5
7/	2.20	71	220	14.8	72	33	yes	5
8/	2.20	71	220	14.8	72	33	yes	5
9/	2.20	71	220	14.2	72	33	yes	5
10/	2.03	71	203	14.3	72	33	yes	5
11/	1.88	71	188	14.3	72	33	yes	5
12/	1.56	71	156	16.0	72	27	yes	5
13/	.99	71	99	15.3	72	27	yes	5
14/	.67	71	67	14.7	72	29	yes	5
15/	.64	71	64	14.7	72	29	yes	5
16/	.60	71	60	14.8	72	29	yes	5
17/	.77	71	77	15.2	72	26	yes	5
18/	1.10	71	110	14.5	72	30	yes	5
19/	1.89	71	189	13.5	72	36	yes	5
20/	2.20	71	220	14.7	72	33	yes	5
21/	2.20	71	220	14.2	72	33	yes	5
22/	2.20	71	220	12.8	72	40	yes	5
23/	2.20	71	220	12.6	72	40	yes	5
24/	2.20	71	220	10.9	72	46	yes	5
25/	2.20	71	220	13.5	72	36	yes	5
26/	2.20	71	220	13.5	72	36	yes	5
27/	2.03	71	203	15.4	72	30	yes	5
28/	1.63	71	163	15.3	72	29	yes	5
29/								
30/								
31/								

If Cl₂ at entry point < 0.2 mg/l, OR CT not met, notify DWP by end of next business day.

Revised February 2012

Download form at: public.health.oregon.gov/HealthyEnvironments/DrinkingWater/Monitoring/Documents/turb-cartridge.pdf