

OHA - Drinking Water Program - Turbidity Monitoring Report Form County:
Cartridge or Bag Filtration

System Name: Mad Dog Country Tavern ID #: 084192052 WTP: WTP-A Month/Year: 4-2022

DAY	PSI Before Filter	PSI After Filter	PSID	PSID When to Change Filter	Daily Turbidity Reading [NTU]	Highest Reading of the Day ¹ [NTU]
1					.23	
2					.20	
3					.21	
4					.24	
5					.26	
6					.26	
7					.23	
8					.20	
9					.21	
10					.24	
11					.23	
12					.24	
13					.25	
14					.22	
15					.24	
16					.25	
17					.26	
18					.25	
19					.27	
20					.24	
21					.21	
22					.22	
23					.24	
24					.22	
25					.25	
26					.23	
27					.25	
28					.26	
29					.21	
30					.20	
31						

Cartridge Filtration		Monthly Summary (Answer Yes or No)	
95% of daily turbidity readings ≤ 1 NTU? <input checked="" type="checkbox"/> Yes / No	CT's met everyday? (see back) <input checked="" type="checkbox"/> Yes / No	All Cl ₂ residual at entry point ≥ 0.2 mg/l? <input checked="" type="checkbox"/> Yes / No	
All daily turbidity readings ≤ 5 NTU? <input checked="" type="checkbox"/> Yes / No			
Notes: PSI = pounds per square inch PSID = pounds per square inch difference (before filter - after filter) PSID When to Change Filter = Manufacturer's recommendation; may need to look in manual for manufacturer's specifications when to change the filter, at what PSID.	PRINTED NAME: TJ WISKY		
	SIGNATURE: <i>TJ Wisky</i>	DATE: 4-30-2022	
	PHONE #: (541) 265-8761	CERT #:	

MAY 04 2022
Data Mgmt & Compliance

Including continuous turbidity data, if applicable, for optimization recording purposes. Compliance values in "Daily Turbidity Reading" Column may not correspond to continuous readings' maximum.

OHA - Drinking Water Program – Surface Water Quality Data Form

System Name: Mad Dog Country Tavern

ID #: CR4192052

WTP: WTP-A Month/Year: April 2022

Date / Time	Minimum Cl ₂ Residual at 1 st User (C) ²	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ²	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	CXT	[°C]		Use tables	Yes / No	[GPM]
1/	2.02	71	202	15.3	72	30	yes	5
2/	1.89	71	189	15.3	72	30	yes	5
3/	1.79	71	179	15.6	72	30	yes	5
4/	1.58	71	158	15.7	72	30	yes	5
5/	1.24	71	124	15.3	72	28	yes	5
6/	1.04	71	104	14.1	72	30	yes	5
7/	.82	71	82	16.9	72	26	yes	5
8/	.52	71	52	17.6	72	23	yes	5
9/	.47	71	47	16.9	72	25	yes	5
10/	.43	71	43	15.2	72	26	yes	5
11/	.46	71	46	14.8	72	29	yes	5
12/	.48	71	48	14.9	72	29	yes	5
13/	.71	71	71	14.1	72	29	yes	5
14/	1.01	71	101	14.0	72	30	yes	5
15/	1.12	71	112	13.9	72	34	yes	5
16/	1.92	71	192	14.2	72	33	yes	5
17/	2.20	71	220	14.4	72	33	yes	5
18/	2.20	71	220	13.4	72	36	yes	5
19/	2.20	71	220	15.3	72	30	yes	5
20/	2.20	71	220	16.0	72	29	yes	5
21/	2.20	71	220	15.6	72	30	yes	5
22/	2.20	71	220	13.8	72	36	yes	5
23/	1.88	71	188	14.9	72	33	yes	5
24/	1.66	71	166	16.4	72	28	yes	5
25/	1.31	71	131	17.0	72	25	yes	5
26/	1.06	71	106	16.2	72	26	yes	5
27/	.73	71	73	16.3	72	26	yes	5
28/	.69	71	69	16.3	72	26	yes	5
29/	.75	71	75	16.5	72	26	yes	5
30/	.87	71	87	16.8	72	26	yes	5
31/								

If Cl₂ at entry point < 0.2 mg/l, OR CT not met, notify DWP by end of next business day.

Revised February 2012

Download form at: public.health.oregon.gov/HealthyEnvironments/DrinkingWater/Monitoring/Documents/turb-cartridge.pdf