

**OHA - Drinking Water Program – Turbidity Monitoring Report Form County:  
Cartridge or Bag Filtration**

System Name: Mad Dog Country Tavern ID #: 084191052 WTP: WTP-A Month/Year: May 2022

DAY	PSI Before Filter	PSI After Filter	PSID	PSID When to Change Filter	Daily Turbidity Reading [NTU]	Highest Reading of the Day <sup>1</sup> [NTU]
1					23	
2					25	
3					21	
4					23	
5					23	
6					22	
7					20	
8					19	
9					18	
10					20	
11					22	
12					24	
13					25	
14					27	
15					20	
16					24	
17					27	
18					23	
19					21	
20					22	
21					24	
22					25	
23					26	
24					23	
25					23	
26					22	
27					25	
28					27	
29					28	
30					25	
31					26	

<b>Cartridge Filtration</b>		<b>Monthly Summary (Answer Yes or No)</b>	
95% of daily turbidity readings ≤ 1 NTU? All daily turbidity readings ≤ 5 NTU?	<input checked="" type="radio"/> Yes / <input type="radio"/> No <input checked="" type="radio"/> Yes / <input type="radio"/> No	CT's met everyday? (see back) <input checked="" type="radio"/> Yes / <input type="radio"/> No	All Cl <sub>2</sub> residual at entry point ≥ 0.2 mg/l? <input checked="" type="radio"/> Yes / <input type="radio"/> No
Notes: PSI = pounds per square inch PSID = pounds per square inch difference (before filter – after filter) PSID When to Change Filter = Manufacturer's recommendation; may need to look in manual for manufacturer's specifications when to change the filter, at what PSID.		PRINTED NAME: <u>TJ WISKY</u> SIGNATURE: <u>[Signature]</u> DATE: <u>6-1-2022</u>	
JUN 06 2022 Data Mgmt & Compliance Drinking Water Program		PHONE #: <u>(541) 265-8761</u> CERT #:	

<sup>1</sup> Including continuous turbidity data, if applicable, for optimization recording purposes. Compliance values in "Daily Turbidity Reading" Column may not correspond to continuous readings' maximum.  
PAGE 1 of 2

# OHA - Drinking Water Program – Surface Water Quality Data Form

System Name: Mad Dog Country Tavern

ID #: OR4192052

WTP: WTP-A Month/Year: **MA 4**  
**2022**

Date / Time	Minimum Cl <sub>2</sub> Residual at 1 <sup>st</sup> User (C) <sup>2</sup>	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? <sup>2</sup>	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	CXT	[°C]		Use tables	Yes / No	[GPM]
11	1.04	71	104	16.7	72	26	yes	5
21	1.28	71	128	16.2	72	27	yes	5
31	1.40	71	140	16.7	72	27	yes	5
41	1.79	71	179	16.3	72	28	yes	5
51	2.04	71	204	16.3	72	29	yes	5
61	2.00	71	200	16.5	72	29	yes	5
71	1.97	71	197	16.2	72	29	yes	5
81	1.91	71	191	16.1	72	29	yes	5
91	1.63	71	163	15.5	72	29	yes	5
101	1.54	71	154	15.3	72	29	yes	5
111	1.20	71	120	15.0	72	27	yes	5
121	.91	71	91	16.1	72	26	yes	5
131	.72	71	72	15.3	72	26	yes	5
141	1.54	71	54	17.0	72	23	yes	5
151	.41	71	41	16.3	72	25	yes	5
161	.45	71	45	17.6	72	23	yes	5
171	.47	71	47	16.3	72	26	yes	5
181	.54	71	54	17.4	72	23	yes	5
191	.57	71	57	17.6	72	23	yes	5
201	.68	71	68	17.3	72	24	yes	5
211	.83	71	83	16.5	72	26	yes	5
221	1.25	71	125	17.6	72	26	yes	5
231	1.89	71	129	18.3	72	24	yes	5
241	1.50	71	150	18.2	72	24	yes	5
251	1.53	71	153	18.2	72	24	yes	5
261	1.69	71	169	19.6	72	23	yes	5
271	1.40	71	140	19.8	72	22	yes	5
281	2.20	71	220	18.6	72	26	yes	5
291	2.20	71	220	18.0	72	26	yes	5
301	1.99	71	199	17.7	72	27	yes	5
311	2.20	71	220	18.2	72	26	yes	5

If Cl<sub>2</sub> at entry point < 0.2 mg/l, OR CT not met, notify DWP by end of next business day.

Revised February 2012

Download form at: [public.health.oregon.gov/HealthyEnvironments/DrinkingWater/Monitoring/Documents/turb-cartridge.pdf](http://public.health.oregon.gov/HealthyEnvironments/DrinkingWater/Monitoring/Documents/turb-cartridge.pdf)