

OHA - Drinking Water Program – Turbidity Monitoring Report Form County: Cartridge or Bag Filtration

System Name: Mad Dog Country Tavern ID #: CR419A052WTP-WTP-A Month/Year: JUNE 2022

DAY	PSI Before Filter	PSI After Filter	PSID	PSID When to Change Filter	Daily Turbidity Reading [NTU]	Highest Reading of the Day ¹ [NTU]
1					23	
2					21	
3					22	
4					24	
5					19	
6					22	
7					25	
8					23	
9					23	
10					20	
11					22	
12					24	
13					25	
14					27	
15					22	
16					24	
17					21	
18					23	
19					22	
20					19	
21					21	
22					23	
23					24	
24					21	
25					20	
26					24	
27					23	
28					22	
29					26	
30					23	
31						

Cartridge Filtration		Monthly Summary (Answer Yes or No)	
95% of daily turbidity readings ≤ 1 NTU? All daily turbidity readings ≤ 5 NTU?	<input checked="" type="radio"/> Yes / <input type="radio"/> No <input checked="" type="radio"/> Yes / <input type="radio"/> No	CT's met everyday? (see back) <input checked="" type="radio"/> Yes / <input type="radio"/> No	All Cl ₂ residual at entry point ≥ 0.2 mg/l? <input checked="" type="radio"/> Yes / <input type="radio"/> No
Notes: PSI = pounds per square inch PSID = pounds per square inch difference (before filter – after filter) PSID When to Change Filter = Manufacturer's recommendation; may need to look in manual for manufacturer's specifications when to change the filter, at what PSID.		PRINTED NAME: <u>TJ WISKY</u>	DATE: <u>7-1-2022</u>
Data Mgmt & Compliance Drinking Water Program JUL 06 2022		PHONE #: <u>(541) 265-8761</u>	CERT #:

Including continuous turbidity data, if applicable, for optimization recording purposes. Compliance values in "Daily Turbidity Reading" Column may not correspond to continuous readings' maximum.

OHA - Drinking Water Program – Surface Water Quality Data Form

System Name: Mad Dog Country Tavern

ID #: CR4192052

WTP: WTP-A

Month/Year: JUNE 2022

Date / Time	Minimum Cl ₂ Residual at 1 st User (C) ²	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ²	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		Use tables	Yes / No	[GPM]
1/	2.20	71	220	19.2	72	24	yes	5
2/	1.84	71	184	19.5	72	24	yes	5
3/	1.72	71	172	19.5	72	24	yes	5
4/	1.31	71	131	19.3	72	22	yes	5
5/	.91	71	91	19.7	72	22	yes	5
6/	.61	71	61	19.4	72	21	yes	5
7/	.43	71	43	17.9	72	23	yes	5
8/	.47	71	47	19.4	72	21	yes	5
9/	.54	71	54	19.8	72	21	yes	5
10/	.56	71	56	20.9	72	19	yes	5
11/	.53	71	53	19.9	72	21	yes	5
12/	.58	71	58	19.9	72	21	yes	5
13/	.63	71	63	19.2	72	21	yes	5
14/	.60	71	60	17.9	72	23	yes	5
15/	.57	71	57	19.1	72	21	yes	5
16/	.62	71	62	19.2	72	21	yes	5
17/	.69	71	69	19.3	72	21	yes	5
18/	.87	71	87	19.8	72	22	yes	5
19/	1.22	71	122	19.3	72	22	yes	5
20/	1.40	71	140	19.5	72	22	yes	5
21/	1.45	71	145	19.8	72	23	yes	5
22/	1.64	71	164	21.0	72	21	yes	5
23/	1.64	71	164	17.4	72	26	yes	5
24/	1.71	71	171	19.4	72	23	yes	5
25/	1.78	71	178	21.0	72	21	yes	5
26/	1.83	71	183	21.5	72	21	yes	5
27/	1.92	71	192	21.6	72	21	yes	5
28/	1.80	71	180	21.3	72	21	yes	5
29/	1.73	71	173	20.9	72	22	yes	5
30/	1.65	71	165	19.3	72	23	yes	5
31/								

If Cl₂ at entry point < 0.2 mg/l, OR CT not met, notify DWP by end of next business day.

Revised February 2012

Download form at: public.health.oregon.gov/HealthyEnvironments/DrinkingWater/Monitoring/Documents/turb-cartridge.pdf