

**OHA - Drinking Water Program - Turbidity Monitoring Report Form County:  
Cartridge or Bag Filtration**

System Name: Mad Dog Country Tavern ID #: 084192052 WTP: WTP-A Month/Year: August 2022

DAY	PSI Before Filter	PSI After Filter	PSID	PSID When to Change Filter	Daily Turbidity Reading [NTU]	Highest Reading of the Day <sup>1</sup> [NTU]
1					.21	
2					.20	
3					.19	
4					.17	
5					.18	
6					.19	
7					.21	
8					.20	
9					.23	
10					.20	
11					.20	
12					.25	
13					.23	
14					.25	
15					.26	
16					.24	
17					.20	
18					.22	
19					.25	
20					.26	
21					.23	
22					.27	
23					.22	
24					.27	
25					.25	
26					.26	
27					.28	
28					.23	
29					.25	
30					.20	
31					.22	

RECEIVED  
SEP 06 2022

<b>Cartridge Filtration</b>		<b>Monthly Summary (Answer Yes or No)</b>	
95% of daily turbidity readings ≤ 1 NTU? <input checked="" type="radio"/> Yes / <input type="radio"/> No	CT's met everyday? (see back) <input checked="" type="radio"/> Yes / <input type="radio"/> No	All Cl <sub>2</sub> residual at entry point ≥ 0.2 mg/l? <input checked="" type="radio"/> Yes / <input type="radio"/> No	
Notes: PSI = pounds per square inch PSID = pounds per square inch difference (before filter - after filter) PSID When to Change Filter = Manufacturer's recommendation; may need to look in manual for manufacturer's specifications when to change the filter, at what PSID.		PRINTED NAME: <u>T.J. UISKY</u>	DATE: <u>9-1-2022</u>
		SIGNATURE: <u>T.J. Uisky</u>	CERT #:
		PHONE #: <u>(541) 265-8761</u>	

<sup>1</sup> Including continuous turbidity data, if applicable, for optimization recording purposes. Compliance values in "Daily Turbidity Reading" Column may not correspond to continuous readings' maximum.

# OHA - Drinking Water Program - Surface Water Quality Data Form

System Name: Mad Dog Country Tavern

ID #: CR4192052

WTP: WTP-A

Month/Year: August 2022

Date / Time	Minimum Cl <sub>2</sub> Residual at 1 <sup>st</sup> User (C) <sup>2</sup>	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? <sup>2</sup>	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		Use tables	Yes / No	[GPM]
11	1.37	71	137	20.1	74	21	yes	5
21	1.21	71	121	21.0	72	19	yes	5
31	1.01	71	101	21.3	72	19	yes	5
41	.86	71	86	21.4	72	19	yes	5
51	.74	71	74	20.6	74	20	yes	5
61	.61	71	61	20.0	72	20	yes	5
71	.71	71	71	20.2	72	20	yes	5
81	.46	71	46	20.1	72	19	yes	5
91	.42	71	42	21.0	72	19	yes	5
101	.49	71	49	20.6	72	20	yes	5
111	.54	71	54	21.3	72	19	yes	5
121	.48	71	48	21.3	72	19	yes	5
131	.42	71	42	21.5	72	19	yes	5
141	.47	71	47	20.4	72	20	yes	5
151	1.54	71	154	21.2	72	20	yes	5
161	2.20	71	220	21.3	72	21	yes	5
171	2.20	71	220	21.7	72	21	yes	5
181	2.20	71	220	21.3	72	21	yes	5
191	2.20	71	220	21.5	72	21	yes	5
201	2.20	71	220	22.1	72	20	yes	5
211	.98	71	98	22.6	72	17	yes	5
221	.49	71	49	22.4	72	17	yes	5
231	.47	71	47	21.9	72	18	yes	5
241	.44	71	44	21.5	72	18	yes	5
251	.42	71	42	22.0	72	17	yes	5
261	.82	71	82	22.7	72	17	yes	5
271	1.64	71	164	21.6	72	21	yes	5
281	2.20	71	220	20.8	72	23	yes	5
291	1.38	71	138	21.1	72	19	yes	5
301	2.20	71	220	20.5	72	23	yes	5
311	2.20	71	220	20.6	72	23	yes	5

<sup>2</sup> If Cl<sub>2</sub> at entry point < 0.2 mg/l, OR CT not met, notify DWP by end of next business day.

Revised February 2012

Download form at: [public.health.oregon.gov/HealthyEnvironments/DrinkingWater/Monitoring/Documents/turb-cartridge.pdf](http://public.health.oregon.gov/HealthyEnvironments/DrinkingWater/Monitoring/Documents/turb-cartridge.pdf)