

OHA - Drinking Water Program - Turbidity Monitoring Report Form County: Cartridge or Bag Filtration

System Name: Mad Dog Country Tavern ID #: 084192052 WTP - WTP-A Month/Year: September 2022

DAY	PSI Before Filter	PSI After Filter	PSID	PSID When to Change Filter	Daily Turbidity Reading [NTU]	Highest Reading of the Day ¹ [NTU]
1					25	
2					22	
3					21	
4					23	
5					24	
6					20	
7					23	
8					23	
9					26	
10					24	
11					22	
12					25	
13					24	
14					27	
15					26	
16					23	
17					22	
18					23	
19					21	
20					20	
21					25	
22					27	
23					26	
24					23	
25					21	
26					23	
27					25	
28					24	
29					27	
30					23	
31						

Cartridge Filtration		Monthly Summary (Answer Yes or No)	
95% of daily turbidity readings ≤ 1 NTU? <input checked="" type="radio"/> Yes / <input type="radio"/> No	All daily turbidity readings ≤ 5 NTU? <input checked="" type="radio"/> Yes / <input type="radio"/> No	CT's met everyday? (see back) <input checked="" type="radio"/> Yes / <input type="radio"/> No	All Cl ₂ residual at entry point ≥ 0.2 mg/l? <input checked="" type="radio"/> Yes / <input type="radio"/> No
Notes: PSI = pounds per square inch PSID = pounds per square inch difference (before filter - after filter) PSID When to Change Filter = Manufacturer's recommendation; may need to look in manual for manufacturer's specifications when to change the filter, at what PSID.		PRINTED NAME: T J WISKY	
		SIGNATURE: <i>TJ Wisky</i>	
		DATE: 9-30-2022	
		PHONE #: (541) 265-8761	CERT #:

RECEIVED

OCT 03 2022

Data Mgmt & Compliance

Including continuous turbidity data, if applicable, for optimization recording purposes. Compliance values in "Daily Turbidity Reading" Column may not correspond to continuous readings' maximum.

OHA - Drinking Water Program – Surface Water Quality Data Form

System Name: Mad Dog Country Tavern

ID #: OR4192052

WTP: WTP-A Month/Year: September 2022

Date / Time	Minimum Cl ₂ Residual at 1 st User (C) ²	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ²	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		Use tables	Yes / No	[GPM]
11	2.20	71	220	21.0	72	21	yes	5
21	2.20	71	220	20.4	72	23	yes	5
31	2.20	71	220	21.1	72	21	yes	5
41	1.22	71	122	20.7	72	21	yes	5
51	1.13	71	113	19.8	72	22	yes	5
61	1.00	71	100	20.2	72	20	yes	5
71	.65	71	65	19.8	72	21	yes	5
81	.54	71	54	18.3	72	22	yes	5
91	.50	71	50	19.5	72	21	yes	5
101	.68	71	68	24.0	72	14	yes	5
111	1.90	71	190	23.3	72	18	yes	5
121	2.20	71	220	21.3	72	21	yes	5
131	2.20	71	220	20.9	72	23	yes	5
141	2.20	71	220	20.4	72	23	yes	5
151	2.20	71	220	20.4	72	23	yes	5
161	2.20	71	220	19.3	72	24	yes	5
171	2.20	71	220	19.1	72	24	yes	5
181	2.20	71	220	19.4	72	24	yes	5
191	1.68	71	168	19.5	72	23	yes	5
201	1.27	71	127	19.7	72	22	yes	5
211	.80	71	80	19.8	72	21	yes	5
221	.53	71	53	20.6	72	19	yes	5
231	.40	71	40	19.9	72	20	yes	5
241	.95	71	95	19.8	72	22	yes	5
251	1.55	71	155	19.5	72	23	yes	5
261	2.20	71	220	18.2	72	26	yes	5
271	2.20	71	220	19.3	72	24	yes	5
281	2.10	71	210	19.7	72	24	yes	5
291	2.20	71	220	20.1	72	23	yes	5
301	2.20	71	220	19.7	72	24	yes	5
311								

² If Cl₂ at entry point < 0.2 mg/l, OR CT not met, notify DWP by end of next business day.

Revised February 2012

Download form at: public.health.oregon.gov/HealthyEnvironments/DrinkingWater/Monitoring/Documents/turb-cartridge.pdf