

OHA - Drinking Water Program - Turbidity Monitoring Report Form County: Cartridge or Bag Filtration

System Name: Mad Dog Country Tavern ID #: OR4192052 WTP: WTP-A Month/Year: October 2022

DAY	PSI Before Filter	PSI After Filter	PSID	PSID When to Change Filter	Daily Turbidity Reading [NTU]	Highest Reading of the Day [NTU]
1					.88	
2					.90	
3					.87	
4					.93	
5					1.01	
6					1.01	
7					.87	
8					.32	
9					.30	
10					.34	
11					.29	
12					.25	
13					.28	
14					.33	
15					.35	
16					.35	
17					.38	
18					.48	
19					.52	
20					.49	
21					.44	
22					.46	
23					.41	
24					.40	
25					.32	
26					.29	
27					.30	
28					.25	
29					.27	
30					.33	
31					.31	

Monthly Summary (Answer Yes or No)

Cartridge Filtration 95% of daily turbidity readings ≤ 1 NTU? <input checked="" type="radio"/> Yes / <input type="radio"/> No All daily turbidity readings ≤ 5 NTU? <input checked="" type="radio"/> Yes / <input type="radio"/> No	CT's met everyday? (see back) <input checked="" type="radio"/> Yes / <input type="radio"/> No	All Cl ₂ residual at entry point ≥ 0.2 mg/l? <input checked="" type="radio"/> Yes / <input type="radio"/> No
--	---	---

Notes: PSI = pounds per square inch
 PSID = pounds per square inch difference (before filter - after filter)
 PSID When to Change Filter = Manufacturer's recommendation; may need to look in manual for manufacturer's specifications when to change the filter, at what PSID.

PRINTED NAME: TJ WISKY

SIGNATURE: [Signature] DATE: 10-31-2022

PHONE #: (541) 265-8761 CERT #:

Data Mgmt & Compliance
Drinking Water Program

Including continuous turbidity data, if applicable, for optimization recording purposes. Compliance values in "Daily Turbidity Reading" Column may not correspond to continuous readings' maximum.

OHA - Drinking Water Program - Surface Water Quality Data Form

System Name: Mad Dog Country Tavern

ID #: OR4192052

WTP: WTP-A Month/Year: October 2022

Date / Time	Minimum Cl ₂ Residual at 1 st User (C) ²	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ²	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		Use tables	Yes / No	[GPM]
1/	1.74	71	174	21.0	72	21	yes	5
2/	1.53	71	153	21.1	72	20	yes	5
3/	1.02	71	102	19.9	72	22	yes	5
4/	.87	71	87	19.1	72	22	yes	5
5/	.84	71	84	19.0	72	22	yes	5
6/	.91	71	91	19.2	72	22	yes	5
7/	.99	71	99	19.4	72	22	yes	5
8/	1.53	71	153	19.3	72	23	yes	5
9/	1.87	71	187	19.0	72	24	yes	5
10/	1.90	71	190	18.8	72	26	yes	5
11/	1.72	71	172	18.6	72	25	yes	5
12/	1.38	71	138	17.6	72	27	yes	5
13/	1.39	71	139	18.4	72	24	yes	5
14/	2.20	71	220	18.1	72	26	yes	5
15/	2.20	71	220	18.3	72	26	yes	5
16/	2.20	71	220	19.2	72	24	yes	5
17/	2.17	71	217	19.5	72	24	yes	5
18/	2.13	71	213	18.7	72	26	yes	5
19/	1.75	71	175	18.2	72	26	yes	5
20/	1.41	71	141	18.4	72	25	yes	5
21/	1.06	71	106	18.2	72	25	yes	5
22/	.87	71	87	18.3	72	23	yes	5
23/	.78	71	78	17.9	72	23	yes	5
24/	.42	71	42	18.2	72	22	yes	5
25/	.46	71	46	18.0	72	22	yes	5
26/	.48	71	48	18.2	72	22	yes	5
27/	.49	71	49	16.7	72	25	yes	5
28/	.44	71	44	17.7	72	23	yes	5
29/	.52	71	52	18.9	72	22	yes	5
30/	1.33	71	133	18.3	72	24	yes	5
31/	1.48	71	148	18.0	72	24	yes	5

If Cl₂ at entry point < 0.2 mg/l, OR CT not met, notify DWP by end of next business day.

Revised February 2012