

**OHA - Drinking Water Program - Turbidity Monitoring Report Form County:  
Cartridge or Bag Filtration**

System Name: \_\_\_\_\_ ID #: \_\_\_\_\_ WTP: \_\_\_\_\_ Month/Year: December 2022

DAY	PSI Before Filter	PSI After Filter	PSID	PSID When to Change Filter	Daily Turbidity Reading [NTU]	Highest Reading of the Day <sup>1</sup> [NTU]
1					.30	
2					.25	
3					.27	
4					.30	
5					.31	
6					.34	
7					.28	
8					.30	
9					.33	
10					.30	
11					.29	
12					.27	
13					.31	
14					.29	
15					.25	
16					.23	
17					.21	
18					.22	
19					.26	
20					.25	
21					.27	
22					.24	
23					.25	
24					.22	
25					.24	
26					.26	
27					.21	
28					.24	
29					.23	
30					.25	
31					.27	

<b>Cartridge Filtration</b>		<b>Monthly Summary (Answer Yes or No)</b>	
95% of daily turbidity readings ≤ 1 NTU? <input checked="" type="radio"/> Yes / <input type="radio"/> No	All daily turbidity readings ≤ 5 NTU? <input checked="" type="radio"/> Yes / <input type="radio"/> No	CT's met everyday? (see back) <input checked="" type="radio"/> Yes / <input type="radio"/> No	All Cl <sub>2</sub> residual at entry point ≥ 0.2 mg/l? <input checked="" type="radio"/> Yes / <input type="radio"/> No
<b>Notes:</b> PSI = pounds per square inch PSID = pounds per square inch difference (before filter - after filter) PSID When to Change Filter = Manufacturer's recommendation; may need to look in manual for manufacturer's specifications when to change the filter, at what PSID.		<b>PRINTED NAME:</b> TJ WISKY	
		<b>SIGNATURE:</b> <i>TJ Wisky</i>	<b>DATE:</b> 12-31-22
		<b>PHONE #:</b> (541) 265-8761	<b>CERT #:</b>



OHA - Drinking Water Program – Surface Water Quality Data Form

System Name: Mad Dog Country Tavern

ID #: OR4192052

WTP: WTP-A

Month/Year: December 2022

Certification  
Oregon Health Services

Date / Time	Minimum Cl <sub>2</sub> Residual at 1 <sup>st</sup> User (C) <sup>2</sup>	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? <sup>2</sup>	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		Use tables	Yes / No	[GPM]
11	1.80	71	180	13.0	72	35	yes	5
21	1.82	71	182	12.6	72	39	yes	5
31	2.20	71	220	13.7	72	36	yes	5
41	2.20	71	220	13.7	72	36	yes	5
51	2.20	71	220	13.6	72	36	yes	5
61	2.20	71	220	14.0	72	33	yes	5
71	2.20	71	220	13.8	72	36	yes	5
81	2.20	71	220	14.8	72	33	yes	5
91	2.20	71	220	13.9	72	36	yes	5
101	2.20	71	220	15.3	72	30	yes	5
111	2.20	71	220	14.6	72	33	yes	5
121	2.20	71	220	14.3	72	33	yes	5
131	2.20	71	220	14.0	72	33	yes	5
141	2.20	71	220	13.0	72	36	yes	5
151	2.20	71	220	12.4	72	40	yes	5
161	2.20	71	220	12.5	72	40	yes	5
171	2.20	71	220	12.6	72	40	yes	5
181	2.20	71	220	13.9	72	36	yes	5
191	2.20	71	220	13.5	72	36	yes	5
201	2.13	71	213	15.5	72	30	yes	5
211	1.84	71	184	14.5	72	33	yes	5
221	1.68	71	168	11.5	72	41	yes	5
231	1.52	71	152	12.4	72	37	yes	5
241	1.55	71	155	16.3	72	27	yes	5
251	1.55	71	155	16.4	72	27	yes	5
261	1.37	71	137	16.1	72	27	yes	5
271	1.34	71	134	16.7	72	27	yes	5
281	1.35	71	135	15.2	72	28	yes	5
291	1.33	71	133	15.5	72	28	yes	5
301	1.41	71	141	16.7	72	27	yes	5
311	1.90	71	190	16.0	72	29	yes	5

If Cl<sub>2</sub> at entry point < 0.2 mg/l, OR CT not met, notify DWP by end of next business day.

Revised February 2012

Download form at: [public.health.oregon.gov/HealthyEnvironments/DrinkingWater/Monitoring/Documents/turb-cartridge.pdf](http://public.health.oregon.gov/HealthyEnvironments/DrinkingWater/Monitoring/Documents/turb-cartridge.pdf)