

**OHA - Drinking Water Program – Turbidity Monitoring Report Form County:
Cartridge or Bag Filtration**

System Name: ID #: WTP-: Month/Year: **January 2023**

DAY	PSI Before Filter	PSI After Filter	PSID	PSID When to Change Filter	Daily Turbidity Reading [NTU]	Highest Reading of the Day ¹ [NTU]
1					.25	
2					.26	
3					.27	
4					.29	
5					.28	
6					.25	
7					.26	
8					.28	
9					.29	
10					.30	
11					.33	
12					.31	
13					.34	
14					.30	
15					.32	
16					.31	
17					.12	
18					.13	
19					.13	
20					.11	
21					.21	
22					.19	
23					.15	
24					.17	
25					.15	
26					.16	
27					.14	
28					.15	
29					.17	
30					.17	
31					.16	

RECEIVED

FEB 09 2023

Certification
Drinking Water Services

Cartridge Filtration		Monthly Summary (Answer Yes or No)	
95% of daily turbidity readings ≤ 1 NTU? <input checked="" type="radio"/> Yes / <input type="radio"/> No	All daily turbidity readings ≤ 5 NTU? <input checked="" type="radio"/> Yes / <input type="radio"/> No	CT's met everyday? (see back) <input checked="" type="radio"/> Yes / <input type="radio"/> No	All Cl ₂ residual at entry point ≥ 0.2 mg/l? <input checked="" type="radio"/> Yes / <input type="radio"/> No
Notes: PSI = pounds per square inch PSID = pounds per square inch difference (before filter – after filter) PSID When to Change Filter = Manufacturer's recommendation; may need to look in manual for manufacturer's specifications when to change the filter, at what PSID.		PRINTED NAME: TJ WISKY	DATE: 1-31-2023
PHONE #: (541) 265-8761		CERT #:	

Including continuous turbidity data, if applicable, for optimization recording purposes. Compliance values in "Daily Turbidity Reading" Column may not correspond to continuous readings' maximum.

OHA - Drinking Water Program - Surface Water Quality Data Form

FEB 09 2023

System Name: Mad Dog Country Tavern

ID #: CR4192052

WTP: WTP-A Month/Year: Feb 2023

Drinking Water Services

Date / Time	Minimum Cl ₂ Residual at 1 st User (C) ²	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ²	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	CXT	[° C]		Use tables	Yes / No	[GPM]
11	2.20	71	220	15.6	72	30	yes	5
21	2.20	71	220	14.6	72	33	yes	5
31	2.20	71	220	14.8	72	33	yes	5
41	2.20	71	220	14.9	72	33	yes	5
51	2.20	71	220	15.7	72	30	yes	5
61	2.20	71	220	16.7	72	29	yes	5
71	2.20	71	220	16.9	72	29	yes	5
81	2.20	71	220	17.0	72	27	yes	5
91	1.75	71	175	15.5	72	29	yes	5
101	1.71	71	177	15.0	72	29	yes	5
111	1.43	71	143	16.2	72	27	yes	5
121	1.32	71	132	16.7	72	27	yes	5
131	1.07	71	107	17.5	72	25	yes	5
141	1.16	71	116	17.3	72	25	yes	5
151	1.26	71	126	16.4	72	26	yes	5
161	.98	71	98	15.3	72	27	yes	5
171	.94	71	94	15.6	72	27	yes	5
181	.73	71	73	15.8	72	27	yes	5
191	.64	71	64	14.5	72	29	yes	5
201	1.54	71	54	14.2	72	29	yes	5
211	.45	71	45	13.1	72	31	yes	5
221	.40	71	40	14.1	72	28	yes	5
231	.45	71	45	13.3	72	31	yes	5
241	1.12	71	112	12.8	72	36	yes	5
251	2.20	71	220	11.8	72	43	yes	5
261	2.20	71	220	12.8	72	40	yes	5
271	2.20	71	220	14.0	72	33	yes	5
281	2.20	71	220	15.0	72	30	yes	5
291	2.20	71	220	13.0	72	36	yes	5
301	2.20	71	220	11.2	72	43	yes	5
311	2.20	71	220	11.7	72	43	yes	5

If Cl₂ at entry point < 0.2 mg/l, OR CT not met, notify DWP by end of next business day.

Revised February 2012

Download form at: public.health.oregon.gov/HealthyEnvironments/DrinkingWater/Monitoring/Documents/turb-cartridge.pdf