

OHA - Drinking Water Program - Turbidity Monitoring Report Form County: Lincoln
 Cartridge or Bag Filtration

System Name: SAWYERS LANDING RV PARK ID #: OR4192061 WTP: WTP-A Month/Year: March 2021

DAY	PSI Before Filter	PSI After Filter	PSID	PSID When to Change Filter	Daily Turbidity Reading [NTU]	Highest Reading of the Day [NTU]
1	51	42	9	25		.20
2	51	42	9	25		.09
3	51	42	9	25		.11
4	51	42	9	25		.08
5	51	42	9	25		.17
6	51	42	9	25		.15
7	51	42	9	25		.16
8	51	42	9	25		.14
9	51	42	9	25		.16
10	51	42	9	25		.17
11	51	42	9	25		.16
12	51	42	9	25		.13
13	51	42	9	25		.14
14	52	42	10	25		.17
15	52	42	10	25		.11
16	52	42	10	25		.09
17	52	42	10	25		.10
18	52	42	10	25		.11
19	52	42	10	25		.11
20	53	42	11	25		.14
21	53	42	11	25		.07
22	53	42	11	25		.17
23	53	42	11	25		.19
24	53	42	11	25		.14
25	53	43	10	25		.16
26	53	43	10	25		.14
27	53	43	10	25		.11
28	53	43	10	25		.07
29	53	43	10	25		.09
30	53	43	10	25		.19
31	53	43	10	25		.13

Cartridge Filtration

Monthly Summary (Answer Yes or No)

95% of daily turbidity readings \leq 1 NTU? Yes / No
 All daily turbidity readings \leq 5 NTU? Yes / No

CT's met everyday? (see back) Yes / No

All Cl₂ residual at entry point \geq 0.2 mg/l? Yes / No

Notes: PSI = pounds per square inch
 PSID = pounds per square inch difference (before filter - after filter)
 PSID When to Change Filter = Manufacturer's recommendation; may need to look in manual for manufacturer's specifications when to change the filter, at what PSID.

PRINTED NAME: John Gaye

SIGNATURE: *[Signature]*

DATE: 4-1-21

PHONE #: (541) 265-3907

CERT #:

Including continuous turbidity data, if applicable, for optimization recording purposes. Compliance values in "Daily Turbidity Reading" Column may not correspond to continuous readings' maximum.

OHA - Drinking Water Program - Surface Water Quality Data Form

SAWYERS LANDING RV PARK ID #: OR4192061 WTP: WTP-A Month/Year:

Date / Time	Minimum Cl ₂ Residual at 1 st User (C) ²	Contact Time (T)	Actual CT	Temp ↓	pH ↑	Required CT	CT Met? ²	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	CKT	[°C]		Use tables	Yes / No	[GPM]
1/	1.5	80	120	8.7	7.4	64	Y	710
2/	1.6	80	129	8.5	7.4	64	Y	910
3/	1.6	80	128	8.6	7.4	64	Y	460
4/	1.7	80	136	8.4	7.4	65	Y	590
5/	1.5	80	120	8.2	7.4	64	Y	460
6/	1.6	80	126	8.4	7.4	64	X	490
7/	1.6	80	128	8.6	7.4	64	Y	360
8/	1.7	80	136	8.3	7.4	65	Y	2010 P.M.
9/	1.7	80	136	8.7	7.4	65	Y	1000
10/	2.0	80	160	8.9	7.4	67	Y	650
11/	2.1	80	160	8.8	7.4	68	Y	900
12/	2.2	80	176	9.0	7.4	68	Y	840
13/	2.1	80	160	8.4	7.4	68	Y	780
14/	2.0	80	160	8.5	7.4	67	Y	690
15/	1.8	80	144	8.1	7.4	65	Y	890
16/	2.0	80	160	8.3	7.4	67	Y	1060
17/	2.0	80	160	8.6	7.4	67	Y	880
18/	1.9	80	152	8.5	7.4	67	X	1100
19/	1.9	80	152	9.1	7.5	81	Y	900
20/	2.0	80	160	9.3	7.5	81	Y	1040
21/	1.8	80	144	9.2	7.5	79	Y	760
22/	1.9	80	152	9.4	7.5	81	Y	690
23/	2.0	80	160	9.9	7.5	81	Y	910
24/	1.8	80	144	9.7	7.5	79	Y	530
25/	1.7	80	136	9.9	7.5	79	Y	500
26/	1.7	80	136	9.8	7.5	79	Y	1060
27/	1.9	80	152	9.9	7.5	81	Y	1350
28/	1.6	80	126	9.6	7.5	77	Y	1010
29/	1.5	80	120	9.4	7.5	76	Y	600
30/	1.6	80	126	9.9	7.5	77	Y	700
31/	1.7	80	136	9.8	7.5	79	Y	700

² If Cl₂ at entry point < 0.2 mg/l, OR CT not met, notify DWP by end of next business day.

Download form at: www.public.health.oregon.gov/Health/Environments/DrinkingWater/Monitoring/Documents/turb-cartridge.pdf