

OHA - Drinking Water Program - Turbidity Monitoring Report Form County: Lincoln  
 Cartridge or Bag Filtration

System Name: SAWYERS LANDING RV PARK ID #: OR4192061 WTP: WTP-A Month/Year: June 2021

DAY	PSI Before Filter	PSI After Filter	PSID	PSID When to Change Filter	Daily Turbidity Reading [NTU]	Highest Reading of the Day [NTU]
1	59	44	10	25		.14
2	59	44	11	25		.19
3	59	44	11	25		.17
4	59	44	11	25		.14
5	59	49	10	25		.11
6	60	49	11	25		.14
7	60	49	11	25		.11
8	60	49	11	25		.109
9	60	50	10	25		.19
10	60	50	10	25		.109
11	60	50	10	25		.18
12	60	50	10	25		.13
13	61	51	10	25		.15
14	61	51	10	25		.17
15	61	51	10	25		.109
16	62	51	11	25		.14
17	62	51	11	25		.11
18	62	52	10	25		.17
19	62	52	10	25		.13
20	62	52	10	25		.14
21	63	52	11	25		.11
22	63	52	11	25		.109
23	63	52	11	25		.15
24	63	52	11	25		.10
25	63	52	11	25		.19
26	64	54	10	25		.13
27	64	54	10	25		.109
28	64	54	10	25		.110
29	65	54	11	25		.18
30	65	54	11	25		.14
31	65	54	11	25		.10

Cartridge Filtration		Monthly Summary (Answer Yes or No)	
95% of daily turbidity readings $\leq$ 1 NTU? All daily turbidity readings $\leq$ 5 NTU?	<input checked="" type="radio"/> Yes / <input type="radio"/> No <input type="radio"/> Yes / <input checked="" type="radio"/> No	CT's met everyday? (see back) <input checked="" type="radio"/> Yes / <input type="radio"/> No	All Cl <sub>2</sub> residual at entry point $\geq$ 0.2 mg/l? <input checked="" type="radio"/> Yes / <input type="radio"/> No
Notes: PSI = pounds per square inch PSID = pounds per square inch difference (before filter -- after filter) PSID When to Change Filter = Manufacturer's recommendation; may need to look in manual for manufacturer's specifications when to change the filter, at what PSID.		PRINTED NAME: <u>John Gage</u>	DATE: <u>6-1-21</u>
		SIGNATURE: <u>[Signature]</u>	CERT #:
		PHONE #: <u>(541) 265-3907</u>	

Including continuous turbidity data, if applicable, for optimization recording purposes. Compliance values in "Daily Turbidity Reading" Column may not correspond to continuous readings' maximum.

## 179 OHA - Drinking Water Program - Surface Water Quality Data Form

SAWYERS LANDING RV PARK ID #: OR4192061 WTP-: WTP-A Month/Year:

May 2021

Date / Time	Minimum Cl <sub>2</sub> Residual at 1 <sup>st</sup> User (C) <sup>2</sup>	Contact Time (T)	Actual CT	Temp ↓	pH ↑	Required CT	CT Met? <sup>2</sup>	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		Use tables	Yes / No	[GPM]
1/	1.4	80	112	13.6	7.6	57	Y	1360
2/	1.6	80	128	13.9	7.6	58	Y	1220
3/	1.6	80	128	14.2	7.6	58	Y	1070
4/	1.8	80	144	14.3	7.6	58	Y	440
5/	1.7	80	136	14.5	7.6	58	Y	1100
6/	1.6	80	128	14.1	7.6	58	Y	650
7/	1.7	80	136	14.5	7.6	58	Y	1100
8/	1.9	180	152	14.7	7.6	60	Y	780
9/	2.1	80	168	14.6	7.6	61	Y	1610
10/	2.2	80	176	14.4	7.6	62	Y	1200
11/	1.8	80	144	14.8	7.6	60	Y	940
12/	1.5	80	120	14.1	7.6	58	Y	440
13/	1.6	80	128	14.3	7.6	58	Y	1840
14/	1.4	80	112	14.6	7.6	57	Y	850
15/	1.6	80	128	14.7	7.6	58	Y	970
16/	1.7	80	136	14.2	7.6	58	Y	1650
17/	1.8	80	144	14.5	7.6	58	Y	1630
18/	2.1	80	168	14.7	7.6	61	Y	590
19/	2.0	80	160	14.3	7.6	61	Y	1040
20/	1.7	80	136	14.8	7.6	58	Y	1030
21/	1.8	80	144	14.8	7.6	58	Y	1420
22/	1.8	80	144	14.6	7.6	58	Y	1370
23/	2.1	80	168	14.6	7.6	61	Y	1090
24/	2.0	80	160	14.3	7.6	61	Y	1200
25/	2.0	80	160	14.7	7.6	61	Y	1000
26/	2.1	80	168	14.9	7.6	61	Y	870
27/	2.0	80	160	15.1	7.6	41	Y	1090
28/	2.2	80	176	15.3	7.6	41	Y	1270
29/	1.7	80	136	15.8	7.6	40	Y	1780
30/	1.7	80	136	15.3	7.6	40	Y	2110
31/	1.5	80	120	15.7	7.6	40	Y	1390

<sup>2</sup> If Cl<sub>2</sub> at entry point < 0.2 mg/l, OR CT not met, notify DWP by end of next business day.Download form at: [www.public.health.oregon.gov/HealthvEnvironments/DrinkingWater/Monitoring/Documents/turb-cartridge.pdf](http://www.public.health.oregon.gov/HealthvEnvironments/DrinkingWater/Monitoring/Documents/turb-cartridge.pdf)