

OHA - Drinking Water Program - Turbidity Monitoring Report Form County: Lincoln
Cartridge or Bag Filtration

System Name: SAWYERS LANDING RV PARK ID #: OR4192061 **WTP:** WTP-A **Month/Year:** Nov. 2021

DAY	PSI Before Filter	PSI After Filter	Change if more PSID than 25 -	PSID When to Change Filter	Daily Turbidity Reading [NTU]	Highest Reading of the Day [NTU]
1	85	52	33	25		.11
2	85	53	32	25		.12
3	85	53	32	25		.09
4	19	18	1	25		.14
5	19	18	1	25		.13
6	19	18	1	25		.10
7	19	18	1	25		.11
8	19	18	1	25		.09
9	20	19	1	25		.14
10	20	19	1	25		.10
11	20	19	1	25		.12
12	20	19	1	25		.20
13	20	19	1	25		.11
14	20	19	1	25		.10
15	20	19	1	25		.08
16	21	20	1	25		.09
17	21	20	1	25		.11
18	21	20	1	25		.17
19	21	20	1	25		.16
20	21	20	1	25		.11
21	21	20	1	25		.14
22	22	20	2	25		.18
23	22	20	2	25		.13
24	22	20	2	25		.21
25	22	20	2	25		.17
26	22	20	2	25		.11
27	23	21	2	25		.09
28	23	21	2	25		.14
29	23	21	2	25		.18
30	23	21	2	25		.20
31						

Cartridge Filtration		Monthly Summary (Answer Yes or No)	
95% of daily turbidity readings ≤ 1 NTU? All daily turbidity readings ≤ 5 NTU?	Yes/No Yes/No	CT's met everyday? (see back) Yes/No	All Cl ₂ residual at entry point ≥ 0.2 mg/l? Yes/No
Notes: PSI = pounds per square inch PSID = pounds per square inch difference (before filter - after filter) PSID When to Change Filter = Manufacturer's recommendation; may need to look in manual for manufacturer's specifications when to change the filter, at what PSID.		PRINTED NAME: John Gage	DATE: 11-30-21
		SIGNATURE: [Signature]	CERT #:
		PHONE #: (541) 265-3902	

Including continuous turbidity data, if applicable, for optimization recording purposes. Compliance values in "Daily Turbidity Reading" Column may not correspond to continuous readings' maximum.

OHA - Drinking Water Program - Surface Water Quality Data Form

SAWYERS LANDING RV PARK ID #: OR4192061 WTP-: WTP-A Month/Year: Nov. 2021

Date / Time	Minimum Cl ₂ Residual at 1 st User (C) ²	Contact Time (T)	Actual CT	Temp ↓	pH ↑	Required CT	CT Met? ²	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[° C]		Use tables	Yes / No	[GPM]
1/	1.6	80	128	13.1	7.6	58	Y	1080
2/	1.5	80	120	13.5	7.6	58	Y	440
3/	1.6	80	128	13.2	7.6	58	Y	910
4/	1.7	80	136	13.5	7.6	60	Y	450
5/	1.8	80	144	13.1	7.6	60	Y	1100
6/	1.9	80	152	12.9	7.6	61	Y	770
7/	1.3	80	104	12.7	7.6	57	Y	960
8/	1.5	80	120	12.9	7.6	58	Y	560
9/	1.4	80	112	11.7	7.6	57	Y	700
10/	1.2	80	96	11.9	7.6	56	Y	340
11/	1.5	80	120	12.4	7.6	58	Y	850
12/	1.8	80	144	12.6	7.6	60	Y	610
13/	1.9	80	152	12.8	7.6	61	Y	1080
14/	2.0	80	160	12.4	7.6	61	Y	660
15/	1.9	80	152	12.3	7.6	61	Y	820
16/	2.1	80	168	12.9	7.6	61	Y	900
17/	2.0	80	160	12.5	7.6	61	Y	730
18/	1.9	80	152	12.7	7.6	61	Y	780
19/	1.7	80	136	13.0	7.6	60	Y	720
20/	2.0	80	160	12.8	7.6	61	Y	850
21/	2.1	80	168	12.6	7.6	61	Y	940
22/	1.9	80	152	12.4	7.6	61	Y	1560
23/	1.9	80	152	12.8	7.6	61	Y	700
24/	2.5	80	200	9.8	7.6	86	Y	490
25/	2.4	80	192	9.7	7.7	84	Y	1190
26/	2.3	80	184	9.9	7.7	83	Y	1090
27/	2.2	80	176	10.7	7.7	62	Y	1130
28/	2.3	80	184	10.9	7.7	62	Y	1010
29/	2.4	80	192	10.4	7.7	63	Y	650
30/	2.5	80	200	11.9	7.7	63	Y	560
31/	/							

² If Cl₂ at entry point < 0.2 mg/l, OR CT not met, notify DWP by end of next business day.Download form at: www.public.health.oregon.gov/HealthyEnvironments/DrinkingWater/Monitoring/Documents/turb-cartridge.pdf