

**OHA - Drinking Water Program - Turbidity Monitoring Report Form County: Lincoln**  
**Cartridge or Bag Filtration**

System Name: **SAWYERS LANDING RV PARK** ID #: **OR4192061** WTP: **WTP-A** Month/Year: **May 2023**

| DAY | PSI Before Filter | PSI After Filter | PSID | PSID When to Change Filter | Daily Turbidity Reading [NTU] | Highest Reading of the Day [NTU] |
|-----|-------------------|------------------|------|----------------------------|-------------------------------|----------------------------------|
| 1   | 34                | 36               | 2    | 25                         |                               | 114                              |
| 2   | 36                | 36               | 2    | 25                         |                               | 112                              |
| 3   | 34                | 38               | 2    | 25                         |                               | 111                              |
| 4   | 38                | 36               | 2    | 25                         |                               | 116                              |
| 5   | 34                | 32               | 2    | 25                         |                               | 113                              |
| 6   | 34                | 36               | 2    | 25                         |                               | 111                              |
| 7   | 34                | 36               | 2    | 25                         |                               | 109                              |
| 8   | 39                | 36               | 3    | 25                         |                               | 117                              |
| 9   | 39                | 36               | 3    | 25                         |                               | 116                              |
| 10  | 39                | 36               | 3    | 25                         |                               | 111                              |
| 11  | 39                | 36               | 3    | 25                         |                               | 109                              |
| 12  | 39                | 36               | 3    | 25                         |                               | 115                              |
| 13  | 39                | 37               | 2    | 25                         |                               | 116                              |
| 14  | 39                | 37               | 2    | 25                         |                               | 112                              |
| 15  | 39                | 37               | 2    | 25                         |                               | 109                              |
| 16  | 39                | 37               | 2    | 25                         |                               | 114                              |
| 17  | 39                | 37               | 2    | 25                         |                               | 111                              |
| 18  | 39                | 37               | 2    | 25                         |                               | 116                              |
| 19  | 39                | 37               | 2    | 25                         |                               | 109                              |
| 20  | 39                | 37               | 2    | 25                         |                               | 114                              |
| 21  | 39                | 37               | 2    | 25                         |                               | 112                              |
| 22  | 40                | 37               | 3    | 25                         |                               | 113                              |
| 23  | 40                | 37               | 3    | 25                         |                               | 116                              |
| 24  | 40                | 37               | 3    | 25                         |                               | 112                              |
| 25  | 40                | 37               | 3    | 25                         |                               | 117                              |
| 26  | 40                | 37               | 3    | 25                         |                               | 111                              |
| 27  | 40                | 37               | 3    | 25                         |                               | 114                              |
| 28  | 40                | 37               | 3    | 25                         |                               | 109                              |
| 29  | 40                | 37               | 3    | 25                         |                               | 112                              |
| 30  | 40                | 36               | 2    | 25                         |                               | 111                              |
| 31  | 40                | 34               | 2    | 25                         |                               | 116                              |

|   |   |   |   |
|---|---|---|---|
| <b>Cartridge Filtration</b>   |   | <b>Monthly Summary (Answer Yes or No)</b>   |   |
| 95% of daily turbidity readings ≤ 1 NTU? <input checked="" type="radio"/> Yes <input type="radio"/> No  | All daily turbidity readings ≤ 5 NTU? <input checked="" type="radio"/> Yes <input type="radio"/> No | CT's met everyday? (see back) <input checked="" type="radio"/> Yes <input type="radio"/> No | All Cl <sub>2</sub> residual at entry point ≥ 0.2 mg/l? <input checked="" type="radio"/> Yes <input type="radio"/> No |
| Notes: PSI = pounds per square inch<br>PSID = pounds per square inch difference (before filter - after filter)<br>PSID When to Change Filter = Manufacturer's recommendation; may need to look in manual for manufacturer's specifications when to change the filter, at what PSID. |   | PRINTED NAME: <b>John Gage</b>  | DATE: <b>5-1-23</b>   |
|   |   | SIGNATURE: <i>[Signature]</i>   | CERT #:   |
|   |   | PHONE #: <b>(541) 265-3907</b>  |   |

Including continuous turbidity data, if applicable, for optimization recording purposes. Compliance values in "Daily Turbidity Reading" Column may not correspond to continuous readings' maximum.

## OHA - Drinking Water Program - Surface Water Quality Data Form

SAWYERS LANDING RV PARK ID #: OR4192061 WTP: WTP-A Month/Year: May 2023

| Date / Time | Minimum Cl <sub>2</sub> Residual at 1 <sup>st</sup> User (C) <sup>2</sup> | Contact Time (T) | Actual CT | Temp ↓ | pH ↑ | Required CT | CT Met? <sup>2</sup> | Peak Hourly Demand Flow |
|-------------|---|------------------|-----------|--------|------|-------------|----------------------|-------------------------|
|             | [ppm or mg/L]   | [minutes]        | CXT       | [°C]   |      | Use tables  | Yes / No             | [GPM]                   |
| 1/          | 2.0   | 80               | 160       | 10.9   | 7.6  | 61          | Y                    | 890                     |
| 2/          | 1.7   | 80               | 136       | 11.7   | 7.6  | 60          | Y                    | 820                     |
| 3/          | 1.6   | 80               | 128       | 12.3   | 7.6  | 59          | Y                    | 440                     |
| 4/          | 1.8   | 80               | 144       | 11.9   | 7.6  | 60          | Y                    | 440                     |
| 5/          | 1.9   | 80               | 152       | 11.4   | 7.6  | 61          | Y                    | 840                     |
| 6/          | 1.8   | 80               | 144       | 11.7   | 7.6  | 60          | Y                    | 890                     |
| 7/          | 2.0   | 80               | 160       | 12.0   | 7.6  | 61          | Y                    | 640                     |
| 8/          | 1.7   | 80               | 136       | 11.8   | 7.6  | 60          | Y                    | 1040                    |
| 9/          | 1.8   | 80               | 144       | 12.1   | 7.6  | 60          | Y                    | 880                     |
| 10/         | 2.0   | 80               | 160       | 12.3   | 7.6  | 61          | Y                    | 630                     |
| 11/         | 2.1   | 80               | 168       | 13.1   | 7.6  | 62          | Y                    | 960                     |
| 12/         | 2.2   | 80               | 176       | 13.2   | 7.6  | 62          | Y                    | 770                     |
| 13/         | 2.0   | 80               | 160       | 13.6   | 7.6  | 61          | Y                    | 1020                    |
| 14/         | 1.8   | 80               | 144       | 14.1   | 7.6  | 60          | Y                    | 1080                    |
| 15/         | 1.7   | 80               | 136       | 13.4   | 7.6  | 60          | Y                    | 1380                    |
| 16/         | 1.9   | 80               | 152       | 13.1   | 7.6  | 61          | Y                    | 660                     |
| 17/         | 2.0   | 80               | 160       | 13.6   | 7.6  | 61          | Y                    | 910                     |
| 18/         | 1.9   | 80               | 152       | 13.2   | 7.6  | 61          | Y                    | 1190                    |
| 19/         | 2.0   | 80               | 160       | 13.1   | 7.6  | 61          | Y                    | 1160                    |
| 20/         | 2.1   | 80               | 168       | 13.4   | 7.6  | 61          | Y                    | 850                     |
| 21/         | 2.0   | 80               | 160       | 13.5   | 7.6  | 61          | Y                    | 1020                    |
| 22/         | 1.7   | 80               | 136       | 13.1   | 7.6  | 60          | Y                    | 940                     |
| 23/         | 1.6   | 80               | 128       | 14.5   | 7.6  | 59          | Y                    | 720                     |
| 24/         | 1.7   | 80               | 136       | 14.6   | 7.6  | 60          | Y                    | 790                     |
| 25/         | 1.8   | 80               | 144       | 15.3   | 7.6  | 40          | Y                    | 740                     |
| 26/         | 1.7   | 80               | 136       | 15.5   | 7.6  | 40          | Y                    | 830                     |
| 27/         | 1.6   | 80               | 128       | 16.1   | 7.6  | 39          | Y                    | 1090                    |
| 28/         | 1.8   | 80               | 144       | 16.0   | 7.6  | 40          | Y                    | 1330                    |
| 29/         | 1.7   | 80               | 136       | 16.6   | 7.6  | 40          | Y                    | 1470                    |
| 30/         | 1.9   | 80               | 152       | 16.7   | 7.6  | 41          | Y                    | 1100                    |
| 31/         | 2.0   | 80               | 160       | 16.5   | 7.6  | 41          | Y                    | 1180                    |

<sup>2</sup> If Cl<sub>2</sub> at entry point < 0.2 mg/l, OR CT not met, notify DWP by end of next business day.Download form at: [www.public.health.oregon.gov/HealthvEnvironments/DrinkingWater/Monitoring/Documents/turb-cartridge.pdf](http://www.public.health.oregon.gov/HealthvEnvironments/DrinkingWater/Monitoring/Documents/turb-cartridge.pdf)