

OHA - Drinking Water Program - Turbidity Monitoring Report Form County: Lincoln
 Cartridge or Bag Filtration

System Name: SAWYERS LANDING RV PARK ID #: OR4192061 WTP: WTP-A Month/Year: Dec 2023

DAY	PSI Before Filter	PSI After Filter	PSID	PSID When to Change Filter	Daily Turbidity Reading [NTU]	Highest Reading of the Day ¹ [NTU]
1	67	63	4	25		.14
2	67	63	4	25		.15
3	68	63	5	25		.11
4	68	63	5	25		.14
5	68	63	5	25		.10
6	68	63	5	25		.12
7	68	63	5	25		.16
8	68	64	4	25		.14
9	68	64	4	25		.17
10	68	64	4	25		.13
11	68	64	4	25		.16
12	69	64	5	25		.17
13	69	64	5	25		.13
14	69	64	5	25		.16
15	69	64	5	25		.11
16	69	64	5	25		.13
17	69	65	4	25		.17
18	70	65	5	25		.13
19	70	65	5	25		.11
20	70	65	5	25		.15
21	70	65	5	25		.12
22	70	65	5	25		.11
23	70	65	5	25		.09
24	70	65	5	25		.16
25	70	65	5	25		.14
26	70	66	4	25		.11
27	70	68	4	25		.17
28	71	66	5	25		.14
29	71	66	5	25		.13
30	71	66	5	25		.12
31	71	66	5	25		.09

Cartridge Filtration

Monthly Summary (Answer Yes or No)

95% of daily turbidity readings ≤ 1 NTU? Yes / No
 All daily turbidity readings ≤ 5 NTU? Yes / No

CT's met everyday? (see back) Yes / No

All Cl₂ residual at entry point ≥ 0.2 mg/l? Yes / No

Notes: PSI = pounds per square inch
 PSID = pounds per square inch difference (before filter - after filter)
 PSID When to Change Filter = Manufacturer's recommendation; may need to look in manual for manufacturer's specifications when to change the filter, at what PSID.

PRINTED NAME: John Grogg

SIGNATURE: *[Signature]*

DATE: 12/31/23

PHONE #: (541) 265-3907

CERT #:

Including continuous turbidity data, if applicable, for optimization recording purposes. Compliance values in "Daily Turbidity Reading" Column may not correspond to continuous readings' maximum.

OHA - Drinking Water Program -- Surface Water Quality Data Form

SAWYERS LANDING RV PARK ID #: OR4192061 WTP-: WTP-A Month/Year: Dec 2023

Date / Time	Minimum Cl ₂ Residual at 1 st User (C) ² [ppm or mg/L]	Contact Time (T) [minutes]	Actual CT CXT	Temp [°C]	pH↑	Required CT	CT Met? ² Yes / No	Peak Hourly Demand Flow [GPM]
						Use tables		
1/	1.8	80	144	9.3	7.7	60	Y	710
2/	1.5	80	120	9.8	7.7	58	Y	710
3/	1.4	80	112	9.6	7.7	57	Y	780
4/	1.6	80	128	9.9	7.7	58	Y	810
5/	1.5	80	120	11.2	7.7	38	Y	1430
6/	1.4	80	112	12.1	7.7	57	Y	1010
7/	1.5	80	120	11.6	7.7	58	Y	810
8/	1.6	80	128	10.1	7.7	58	Y	990
9/	1.5	80	120	11.3	7.7	58	Y	1250
10/	1.7	80	136	10.8	7.7	60	Y	1100
11/	1.6	80	128	11.8	7.7	58	Y	1350
12/	1.5	80	120	12.1	7.7	38	Y	1030
13/	1.7	80	136	12.0	7.7	60	Y	1680
14/	1.8	80	144	12.3	7.7	60	Y	1080
15/	1.8	80	144	12.1	7.7	60	Y	740
16/	1.9	80	152	11.9	7.7	61	Y	730
17/	2.1	80	168	12.3	7.7	62	Y	920
18/	2.2	80	176	12.4	7.7	61	Y	440
19/	2.3	80	184	12.6	7.7	62	Y	270
20/	2.2	80	176	12.3	7.7	61	Y	780
21/	2.0	80	160	12.0	7.7	60	Y	550
22/	2.2	80	176	11.7	7.7	62	Y	940
23/	2.3	80	184	10.7	7.7	63	Y	760
24/	2.3	80	184	11.7	7.7	63	Y	180
25/	2.4	80	192	12.3	7.7	63	Y	660
26/	2.3	80	184	12.4	7.7	63	Y	710
27/	2.4	80	192	12.2	7.7	63	Y	660
28/	2.2	80	176	11.8	7.7	61	Y	540
29/	2.1	80	168	12.1	7.7	60	Y	330
30/	2.0	80	160	12.3	7.7	60	Y	960
31/	2.1	80	168	11.9	7.7	60	Y	840

² If Cl₂ at entry point < 0.2 mg/l, OR CT not met, notify DWP by end of next business day.Download form at: www.public.health.oregon.gov/HealthEnvironments/DrinkingWater/Monitoring/Documents/turb-cartridge.pdf