

OHA - Drinking Water Program - Turbidity Monitoring Report Form County: Lincoln
Cartridge or Bag Filtration

System Name: **SAWYERS LANDING RV PARK** ID #: **OR4192061** WTP: **WTP-A** Month/Year:

DAY	PSI Before Filter	PSI After Filter	PSID	PSID When to Change Filter	Daily Turbidity Reading [NTU]	Highest Reading of the Day ¹ [NTU]
1	83	79	5	25		.11
2	83	79	5	25		.14
3	83	79	5	25		.13
4	83	79	4	25		.17
5	83	79	4	25		.11
6	83	79	4	25		.16
7	84	79	5	25		.13
8	84	79	5	25		.14
9	84	79	5	25		.17
10	84	79	5	25		.11
11	84	79	5	25		.15
12	20	19	1	25		.13
13	20	19	1	25		.11
14	20	19	1	25		.14
15	20	19	1	25		.16
16	20	19	1	25		.10
17	20	19	1	25		.13
18	20	19	1	25		.14
19	20	19	1	25		.16
20	20	19	1	25		.13
21	22	19	3	25		.15
22	22	19	3	25		.10
23	22	19	3	25		.14
24	22	19	3	25		.11
25	22	19	3	25		.14
26	22	19	3	25		.16
27	24	20	4	25		.17
28	24	20	4	25		.13
29	24	20	4	25		.14
30	24	20	4	25		.11
31	25	20	5	25		.12

Filter Change

Cartridge Filtration

Monthly Summary (Answer Yes or No)

95% of daily turbidity readings ≤ 1 NTU? Yes / No
 All daily turbidity readings ≤ 5 NTU? Yes / No

CT's met everyday? (see back) Yes / No

All Cl₂ residual at entry point ≥ 0.2 mg/l? Yes / No

Notes: PSI = pounds per square inch
 PSID = pounds per square inch difference (before filter - after filter)
 PSID When to Change Filter = Manufacturer's recommendation; may need to look in manual for manufacturer's specifications when to change the filter, at what PSID.

PRINTED NAME: **John Gage**

SIGNATURE: *[Signature]*

DATE: **11-1-24**

PHONE #: **(541) 265-3907**

CERT #:

Including continuous turbidity data, if applicable, for optimization recording purposes. Compliance values in "Daily Turbidity Reading" Column may not correspond to continuous readings' maximum.

OHA - Drinking Water Program - Surface Water Quality Data Form

SAWYERS LANDING RV PARK ID #: OR4192061 WTP-: WTP-A Month/Year: OCT 2024

Date / Time	Minimum Cl ₂ Residual at 1 st User (C) ²	Contact Time (T)	Actual CT	Temp ↓	pH ↑	Required CT	CT Met? ²	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[°C]		Use tables	Yes / No	[GPM]
1/	1.8	80	144	18.1	7.2	41	Y	910
2/	1.7	80	136	17.5	7.2	40	Y	450
3/	1.8	80	144	18.1	7.1	41	X	590
4/	1.6	80	128	16.9	7.1	39	Y	360
5/	1.5	80	120	16.4	7.1	39	Y	580
6/	1.6	80	128	16.6	7.1	39	Y	660
7/	1.5	80	120	17.9	7.1	39	X	540
8/	1.3	80	104	17.4	7.1	38	Y	670
9/	1.3	80	104	17.2	7.1	38	Y	930
10/	1.5	80	120	17.5	7.1	39	Y	730
11/	1.6	80	128	16.9	7.1	39	Y	720
12/	1.8	80	144	17.0	7.1	41	Y	940
13/	2.0	80	160	16.8	7.1	41	Y	870
14/	2.3	80	184	17.4	7.1	42	Y	460
15/	2.2	80	176	17.0	7.1	41	Y	400
16/	2.1	80	168	17.3	7.1	41	Y	440
17/	2.0	80	160	16.9	7.1	41	Y	410
18/	2.0	80	160	17.5	7.1	41	Y	340
19/	1.9	80	152	17.6	7.1	41	Y	690
20/	2.1	80	168	17.3	7.1	41	Y	900
21/	1.9	80	152	16.0	7.0	41	Y	510
22/	1.7	80	136	15.4	7.0	40	Y	540
23/	1.8	80	144	12.1	7.0	40	Y	640
24/	1.7	80	136	11.6	7.0	40	Y	260
25/	1.5	80	128	12.9	7.0	39	Y	420
26/	1.7	80	136	11.3	7.0	40	X	440
27/	1.5	80	120	11.4	7.0	39	Y	310
28/	1.4	80	112	12.1	7.0	38	Y	250
29/	1.5	80	120	12.3	7.0	39	Y	120
30/	1.6	80	128	12.1	7.0	39	Y	520
31/	1.5	80	120	11.2	7.0	39	Y	300

² If Cl₂ at entry point < 0.2 mg/l, OR CT not met, notify DWP by end of next business day.