

OHA - Drinking Water Program - Surface Water Quality Data Form

SAWYERS LANDING RV PARK ID #: OR4192061 WTP-: WTP-A Month/Year: NOV 2024

Date / Time	Minimum Cl ₂ Residual at 1 st User (C) ²	Contact Time (T)	Actual CT	Temp ↓	pH ↑	Required CT	CT Met? ²	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[°C]		Use tables	Yes / No	[GPM]
1/	1.4	80	112	11.1	7.0	38	Y	760
2/	1.4	80	112	10.7	7.0	38	Y	570
3/	1.3	80	104	10.4	7.0	38	Y	750
4/	1.5	80	120	10.0	7.0	39	Y	520
5/	1.3	80	104	10.4	7.0	38	Y	450
6/	1.4	80	112	9.7	7.0	57	Y	320
7/	1.3	80	104	10.9	7.0	38	Y	420
8/	1.5	80	120	10.6	7.0	39	Y	420
9/	1.6	80	128	11.1	7.0	39	Y	280
10/	1.5	80	120	11.3	7.0	39	Y	380
11/	1.8	80	144	10.8	7.0	40	Y	410
12/	1.7	80	136	10.3	7.0	40	Y	390
13/	2.0	80	160	10.2	7.0	40	Y	260
14/	1.9	80	152	10.6	7.0	41	Y	380
15/	1.5	80	120	10.3	6.9	39	Y	460
16/	1.6	80	128	10.2	6.9	39	Y	210
17/	1.7	80	136	10.3	6.9	40	Y	120
18/	1.6	80	128	11.0	6.9	39	Y	330
19/	1.7	80	136	10.2	6.9	40	Y	450
20/	1.5	80	120	10.0	6.9	39	Y	360
21/	1.4	90	112	10.6	6.9	38	Y	410
22/	1.6	80	128	10.2	6.9	39	Y	220
23/	1.4	80	112	9.4	6.9	57	Y	300
24/	1.5	80	120	9.7	6.9	58	Y	450
25/	1.7	80	136	9.9	6.9	60	Y	410
26/	1.6	80	128	9.3	6.9	59	Y	360
27/	1.5	80	120	9.4	6.9	58	Y	360
28/	1.7	80	136	9.6	6.9	60	Y	640
29/	1.6	80	128	9.1	6.9	58	Y	740
30/	1.7	80	136	9.9	6.9	60	Y	250
31/								

² If Cl₂ at entry point < 0.2 mg/l, OR CT not met, notify DWP by end of next business day.