

# CWA - Drinking Water Program - Turbidity Monitoring Report Form County: Lincoln

## Cartridge or Bag Filtration

System Name: SAWYERS LANDING RV PARK ID #: CR4192061 WTP: WTP-A Month/Year: July 2025

| DAY | PSI Before Filter | PSI After Filter | PSID | PSID When to Change Filter | Daily Turbidity Reading [NTU] | Highest Reading of the Day [NTU] |
|-----|-------------------|------------------|------|----------------------------|-------------------------------|----------------------------------|
| 1   | 65                | 49               | 17   | 25                         |                               | .11                              |
| 2   | 66                | 49               | 17   | 25                         |                               | .10                              |
| 3   | 66                | 49               | 17   | 25                         |                               | .13                              |
| 4   | 66                | 49               | 17   | 25                         |                               | .16                              |
| 5   | 67                | 49               | 18   | 25                         |                               | .14                              |
| 6   | 67                | 49               | 18   | 25                         |                               | .13                              |
| 7   | 67                | 50               | 17   | 25                         |                               | .17                              |
| 8   | 68                | 50               | 18   | 25                         |                               | .14                              |
| 9   | 68                | 50               | 18   | 25                         |                               | .09                              |
| 10  | 68                | 50               | 18   | 25                         |                               | .11                              |
| 11  | 69                | 51               | 17   | 25                         |                               | .15                              |
| 12  | 69                | 51               | 18   | 25                         |                               | .11                              |
| 13  | 72                | 52               | 20   | 25                         |                               | .09                              |
| 14  | 72                | 52               | 20   | 25                         |                               | .13                              |
| 15  | 73                | 52               | 21   | 25                         |                               | .16                              |
| 16  | 73                | 53               | 20   | 25                         |                               | .11                              |
| 17  | 82                | 59               | 23   | 25                         |                               | .13                              |
| 18  | 82                | 57               | 25   | 25                         |                               | .16                              |
| 19  | 84                | 58               | 26   | 25                         |                               | .12                              |
| 20  | 85                | 58               | 27   | 25                         |                               | .10                              |
| 21  | 85                | 58               | 27   | 25                         |                               | .14                              |
| 22  | 86                | 58               | 28   | 25                         |                               | .13                              |
| 23  | 88                | 59               | 29   | 25                         |                               | .11                              |
| 24  | 89                | 59               | 30   | 25                         |                               | .14                              |
| 25  | 90                | 61               | 29   | 25                         |                               | .13                              |
| 26  | 90                | 61               | 29   | 25                         |                               | .11                              |
| 27  | 91                | 61               | 30   | 25                         |                               | .14                              |
| 28  | 91                | 62               | 29   | 25                         |                               | .16                              |
| 29  | 91                | 63               | 28   | 25                         |                               | .13                              |
| 30  | 91                | 63               | 28   | 25                         |                               | .11                              |
| 31  | 91                | 63               | 28   | 25                         |                               | .17                              |

### Cartridge Filtration

95% of daily turbidity readings  $\leq$  1 NTU?  
All daily turbidity readings  $\leq$  5 NTU?

Yes / No  
☒ Yes ☐ No

CT's met everyday? (see back)  
☒ Yes ☐ No

### Monthly Summary (Answer Yes or No)

All Cl<sub>2</sub> residual at entry point  $\geq$  0.2 mg/l?  
☒ Yes ☐ No

Notes: PSI = pounds per square inch

PSID = pounds per square inch difference (before filter - after filter)

PSID When to Change Filter = Manufacturer's recommendation; may need to look in manual for manufacturer's specifications when to change the filter, at what PSID.

PRINTED NAME:

John Gage

SIGNATURE:

*[Signature]*

DATE:

8/1/25

PHONE #:

(541) 265-3407

CERT #:

Including continuous turbidity data, if applicable, for optimization recording purposes. Compliance values in "Daily Turbidity Reading" Column may not correspond to continuous readings' maximum.

## DMA - Drinking Water Program - Surface Water Quality Data Form

SAWYERS LANDING RV PARK ID #: CR4192061 WTP: WTP-A Month/Year:

July 2023

| Date / Time | Minimum Cl <sub>2</sub> Residual at 1 <sup>st</sup> User (C) <sup>2</sup> | Contact Time (T) | Actual CT | Temp | pH  | Required CT | CT Met? <sup>2</sup> | Peak Hourly Demand Flow |
|-------------|---------------------------------------------------------------------------|------------------|-----------|------|-----|-------------|----------------------|-------------------------|
|             | [ppm or mg/L]                                                             | [minutes]        | CKT       | [°C] |     | Use tables  | Yes / No             | [GPM]                   |
| 1/          | 1.6                                                                       | 80               | 128       | 17.5 | 6.6 | 39          | Y                    | 680                     |
| 2/          | 1.4                                                                       | 80               | 112       | 17.9 | 6.7 | 38          | Y                    | 1120                    |
| 3/          | 1.5                                                                       | 80               | 120       | 17.1 | 6.7 | 39          | Y                    | 1170                    |
| 4/          | 1.7                                                                       | 80               | 136       | 16.7 | 6.7 | 40          | Y                    | 1150                    |
| 5/          | 1.9                                                                       | 80               | 152       | 18.5 | 6.8 | 40          | Y                    | 1890                    |
| 6/          | 1.8                                                                       | 80               | 144       | 18.6 | 6.8 | 40          | Y                    | 1280                    |
| 7/          | 2.0                                                                       | 80               | 160       | 14.4 | 6.8 | 41          | Y                    | 1290                    |
| 8/          | 1.9                                                                       | 80               | 152       | 14.1 | 6.8 | 40          | Y                    | 1360                    |
| 9/          | 1.7                                                                       | 80               | 136       | 14.3 | 6.8 | 40          | Y                    | 980                     |
| 10/         | 1.8                                                                       | 80               | 144       | 14.5 | 6.8 | 40          | Y                    | 1110                    |
| 11/         | 1.7                                                                       | 80               | 136       | 14.4 | 6.8 | 40          | Y                    | 1320                    |
| 12/         | 1.6                                                                       | 80               | 128       | 14.5 | 6.9 | 39          | Y                    | 930                     |
| 13/         | 1.4                                                                       | 80               | 112       | 19.7 | 6.9 | 38          | Y                    | 1060                    |
| 14/         | 1.5                                                                       | 80               | 120       | 19.4 | 6.9 | 39          | Y                    | 1100                    |
| 15/         | 1.4                                                                       | 80               | 112       | 19.5 | 6.9 | 39          | Y                    | 990                     |
| 16/         | 1.6                                                                       | 80               | 128       | 19.2 | 6.9 | 39          | Y                    | 840                     |
| 17/         | 1.5                                                                       | 80               | 120       | 19.1 | 6.9 | 39          | Y                    | 990                     |
| 18/         | 1.7                                                                       | 80               | 136       | 18.4 | 6.9 | 40          | Y                    | 970                     |
| 19/         | 1.9                                                                       | 80               | 152       | 19.2 | 6.9 | 38          | Y                    | 1620                    |
| 20/         | 1.5                                                                       | 80               | 120       | 19.7 | 6.9 | 39          | Y                    | 890                     |
| 21/         | 1.7                                                                       | 80               | 136       | 18.9 | 6.8 | 40          | Y                    | 1080                    |
| 22/         | 1.5                                                                       | 80               | 120       | 19.4 | 6.8 | 39          | Y                    | 1390                    |
| 23/         | 1.8                                                                       | 80               | 128       | 19.6 | 6.8 | 39          | Y                    | 1790                    |
| 24/         | 1.7                                                                       | 80               | 136       | 19.7 | 6.8 | 40          | Y                    | 1220                    |
| 25/         | 1.6                                                                       | 80               | 128       | 19.8 | 6.8 | 39          | Y                    | 2150                    |
| 26/         | 1.5                                                                       | 80               | 120       | 19.7 | 6.8 | 39          | Y                    | 950                     |
| 27/         | 1.5                                                                       | 80               | 120       | 19.4 | 6.8 | 39          | Y                    | 2240                    |
| 28/         | 1.6                                                                       | 80               | 128       | 19.1 | 6.8 | 39          | Y                    | 1120                    |
| 29/         | 1.5                                                                       | 80               | 120       | 19.7 | 6.8 | 39          | Y                    | 1880                    |
| 30/         | 1.6                                                                       | 80               | 128       | 19.4 | 6.8 | 39          | Y                    | 1430                    |
| 31/         | 1.7                                                                       | 80               | 136       | 19.7 | 6.8 | 40          | Y                    | 1870                    |

<sup>2</sup> If Cl<sub>2</sub> at entry point < 0.2 mg/l, OR CT not met, notify DWP by end of next business day.Download form at: [www.public.health.oregon.gov/HealthyEnvironments/DrinkingWater/Monitoring/Documents/turb-cartridge.pdf](http://www.public.health.oregon.gov/HealthyEnvironments/DrinkingWater/Monitoring/Documents/turb-cartridge.pdf)