

CWA - Drinking Water Program - Turbidity Monitoring Report Form County: Lincoln

Cartridge or Bag Filtration

System Name: SAWYERS LANDING RV PARK ID #: OR4192061 WTP: WTP-A Month/Year:

DAY	PSI Before Filter	PSI After Filter	PSID	PSID When to Change Filter	Daily Turbidity Reading [NTU]	Highest Reading of the Day ¹ [NTU]
1	91	63	28	25		
2	91	64	27	25		.14
3	91	64	27	25		.13
4	92	64	28	25		.16
5	92	64	28	25		.12
6	92	64	28	25		.11
7	19	12	7	25		.15
8	19	12	7	25		.13
9	19	12	7	25		.16
10	19	12	7	25		.11
11	19	12	7	25		.13
12	20	12	8	25		.15
13	22	12	10	25		.16
14	22	12	10	25		.14
15	24	13	11	25		.13
16	24	13	11	25		.11
17	24	14	10	25		.09
18	25	14	11	25		.14
19	25	14	11	25		.16
20	27	14	13	25		.11
21	27	14	13	25		.13
22	27	14	13	25		.12
23	27	14	13	25		.17
24	28	14	14	25		.13
25	28	15	13	25		.14
26	28	15	13	25		.11
27	28	15	13	25		.10
28	29	15	14	25		.13
29	29	15	14	25		.14
30	29	16	13	25		.13
31	29	16	13	25		.09

Cartridge Filtration

95% of daily turbidity readings $\leq$ 1 NTU? ☒ Yes ☐ No
 All daily turbidity readings $\leq$ 5 NTU? ☒ Yes ☐ No

Monthly Summary (Answer Yes or No)

CT's met everyday? (see back) ☒ Yes ☐ No
 All Cl₂ residual at entry point $\geq$ 0.2 mg/l? ☒ Yes ☐ No

Notes: PSI = pounds per square inch

PSID = pounds per square inch difference (before filter - after filter)

PSID When to Change Filter = Manufacturer's recommendation; may need to look in manual for manufacturer's specifications when to change the filter, at what PSID.

PRINTED NAME: John Gage

SIGNATURE: *[Signature]*

DATE: 9-1-25

PHONE #: 541 265-3407

CERT #:

Including continuous turbidity data, if applicable, for optimization recording purposes. Compliance values in "Daily Turbidity Reading" Column may not correspond to continuous readings' maximum.

CHA - Drinking Water Program - Surface Water Quality Data Form

SAVIYERS LANDING RV PARK ID #: CR4192061 WTP: WTP-A Month/Year:

Aug 2025

Date / Time	Minimum Cl ₂ Residual at 1 st User (C) ²	Contact Time (T)	Actual CT	Temp ↓	pH ↑	Required CT	CT Met? ²	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C x T	[°C]		Use tables	Yes / No	[GPM]
1 /	1.6	80	128	19.2	6.8	39	Y	600
2 /	1.8	80	144	19.4	6.8	40	Y	1930
3 /	1.9	80	152	20.0	6.8	41	Y	1400
4 /	2.0	80	160	20.5	6.9	41	Y	1750
5 /	2.1	80	168	19.8	7.0	41	Y	1110
6 /	1.7	80	136	19.1	7.0	40	Y	1330
7 /	1.6	80	128	19.3	7.0	39	Y	1070
8 /	1.7	80	136	19.7	7.0	40	Y	890
9 /	1.5	80	120	19.8	6.9	39	Y	780
10 /	1.3	80	104	20.6	6.9	38	Y	310
11 /	1.3	80	104	20.9	6.9	38	Y	1890
12 /	1.2	80	96	19.8	6.9	37	Y	1110
13 /	1.3	80	104	19.3	6.9	40	Y	1120
14 /	1.8	80	144	19.8	6.9	40	Y	890
15 /	1.6	80	128	19.1	6.9	39	Y	790
16 /	1.5	80	120	19.5	6.9	39	Y	890
17 /	1.6	80	128	19.6	6.9	39	Y	900
18 /	1.7	80	136	19.2	6.9	40	Y	890
19 /	1.5	80	120	19.9	6.9	39	Y	1670
20 /	1.4	80	112	19.6	6.9	38	Y	1180
21 /	1.6	80	128	20.3	6.9	39	Y	1220
22 /	1.5	80	120	20.1	6.9	39	Y	1140
23 /	1.4	80	112	19.8	6.9	38	Y	1500
24 /	1.6	80	128	19.7	6.9	39	Y	1950
25 /	1.5	80	120	20.1	6.9	39	Y	1310
26 /	1.4	80	112	19.4	6.9	38	Y	960
27 /	1.3	80	104	19.2	6.9	38	Y	840
28 /	1.4	80	112	19.3	6.9	38	Y	1040
29 /	1.4	80	112	19.8	6.9	38	Y	1120
30 /	1.6	80	128	19.0	6.9	39	Y	960
31 /	1.5	80	120	19.6	6.9	39	Y	1230

² If Cl₂ at entry point < 0.2 mg/L, OR CT not met, notify DWP by end of next business day.Download form at: www.public.health.oregon.gov/HealthvEnvironments/DrinkingWater/Monitoring/Documents/turb-cartridge.pdf