

OHA - Drinking Water Services — Turbidity Monitoring Report Form

County:

Lincoln

Cartridge or Bag Filtration

Month/Year:

02/2026

System Name: Sawyer's Landing R.V. Park

4192061

WTP ID:

DAY	PSI Before Filter	PSI After Filter	PSID	PSID When to Change Filter	Daily Turbidity Reading	Highest Reading of the Day ¹ NT
1	25	15	10	25		.15
2	25	15	10	25		.11
3	26	15	11	25		.10
4	26	15	11	25		.15
5	26	16	10	25		.11
6	27	16	11	25		.13
7	27	16	11	25		.10
8	28	17	11	25		.10
9	28	17	11	25		.15
10	28	17	11	25		.11
11	29	17	12	25		.09
12	29	17	12	25		.10
13	30	18	12	25		.14
14	30	17	13	25		.12
15	30	17	13	25		.11
	Changed all	System Filters				
16	16	16	0	25		.11
17	16	16	0	25		.13
18	16	16	0	25		.09
19	16	16	0	25		.11
20	17	16	1	25		.13
21	17	16	1	25		.14
22	17	16	1	25		.10
23	17	16	1	25		.12
24	17	16	1	25		.11
25	17	16	1	25		.13
26	18	16	2	25		.15
27	18	16	2	25		.11
28	18	16	2	25		.09
29				25		
30				25		
31				25		

Cartridge Filtration

Monthly Summary (Answer Yes or No)

Month Summary

95% of daily turbidity readings < 1 NTU? Yes / No
 All daily turbidity readings < 5 NTU? Yes / No

CTS met everyday? Yes / No
 (see back)

All C12 residual at entry point 2 0.2 mg/l? Yes / No

Notes: PSI = pounds per square inch
 PSID = pounds per square inch difference (before

PRINTED NAME: John Gage

SIGNATURE: 

DATE: 1/31/2026

filter — after filter) PSID When to Change Filter = Manufacturer's recommendation; may need to look in manual for manufacturer's specifications when to change the filter, at what PSID.	CERT PHONE (541-265-3907)
---	----------------------------------

Including continuous turbidity data, if applicable, for optimization recording purposes. Compliance values in "Daily Turbidity Reading" Column may not correspond to continuous readings' maximum of 2

— Data Form

OHA - Drinking Water Services Surface Water Quality

Month Year: 02/2026

System Name: 41								
Date / Time	Mtnmum C12 Residual at 1 st User C 2	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ²	Peak Hourly Demand Flow
	(ppm or mg/L)	[minutes]	C XT			Use tables	Yes ! No	[GPM]
1/	1.6	80	128	10.4	7.0	77	Y	540
2 /	1.7	80	136	10.1	7.0	79	Y	790
3 /	1.5	80	120	10.5	7.0	76	Y	730
4 /	1.7	80	136	10.0	7.0	79	Y	410
5 /	1.6	80	128	10.6	7.0	77	Y	790
6 /	1.5	80	120	10.4	7.0	77	Y	510
7 /	1.7	80	136	9.7	7.0	76	Y	370
8 /	1.7	80	136	10.0	7.0	79	Y	480
9 /	1.6	80	128	9.6	7.0	77	Y	710
10 /	1.5	80	120	10.4	7.0	76	Y	450
11/	1.4	80	112	9.9	7.0	76	Y	570
12 /	1.5	80	120	10.3	7.0	76	Y	560
13 /	1.5	80	120	10.1	7.0	76	Y	410
14 /	1.4	80	112	10.6	7.0	76	Y	390
15 /	1.6	80	128	10.4	7.0	77	Y	660
16 /	1.6	80	128	9.7	7.0	77	Y	370
17 /	1.7	80	136	9.6	7.0	79	Y	390
18 /	1.6	80	128	9.7	7.0	77	Y	390
19 /	1.7	80	136	9.1	7.0	79	Y	450
20 /	1.5	80	120	9.3	7.0	76	Y	540
21 /	1.6	80	128	10.0	7.0	77	Y	630
22 /	1.6	80	128	9.6	7.0	77	Y	340
23 /	1.7	80	136	9.4	7.0	79	Y	420
24 /	1.5	80	120	9.3	7.0	76	Y	490
25 /	1.7	80	136	9.7	7.0	79	Y	460
26 /	1.6	80	128	9.9	7.0	77	Y	610

27 /	1.5	80	120	10.1	7.1	76	Y	270
28 /	1.4	80	112	10.0	7.1	76	Y	1000
29 /		80						
30 /		80						
31 /		80						

2 If C12 at entry point at: public.health.oregon.gov/HealthvEnvironments/DrinkingWater/Monitoring/Documents/!urb-cartridge.pdf < 0.2 mg/l, OR CT not met, notify DWS within 24 hours. Revised November 2022 Download form

Return by 10th of following month by email, fax or mail to:
dwp.dmce@oha.oregon.gov; Fax 971-673-0694; or Drinking Water Services, PO Box 14350, Portland, OR
97293-0350