

OHA - Drinking Water Services – Turbidity Monitoring Report Form County: Douglas Slow Sand, Membrane, Diatomaceous Earth Filtration or Unfiltered Systems

System Name: Fir Point Bible Conference ID #:OR4192108 WTP:-WTP-A Month/Year: 3-2021

DAY	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day ¹ [NTU]
1	off	off	.05	off	off	off	.05
2			Sys	Tem off			
3							
4							
5							
6							
7							
8							
9							
10							
11							
12							
13							
14							
15							
16							
17							
18							
19							
20	off	off	.01	off	off	off	.01
21	off	off	.02	off	off	off	.02
22	off	off	.02	off	off	off	.02
23			System	off			
24							
25							
26							
27							
28							
29	off	off	.01	off	off	off	.01
30	off	off	.02	off	off	off	.02
31	off	off	.02	off	off	off	.02

RECEIVED
APR 05 2021
Data Mgmt & Compliance
Drinking Water Program

Slow Sand/Membrane/DE Filtration/Unfiltered	Monthly Summary (Answer Yes or No)	
95% of daily turbidity readings ≤ 1 NTU? ² <input checked="" type="radio"/> Yes / <input type="radio"/> No All daily turbidity readings ≤ 5 NTU? <input checked="" type="radio"/> Yes / <input type="radio"/> No	CT's met everyday? (see back) <input checked="" type="radio"/> Yes / <input type="radio"/> No	All Cl ₂ residual at entry point ≥ 0.2 mg/l? <input checked="" type="radio"/> Yes / <input type="radio"/> No
Notes:	PRINTED NAME: Fred Jensen	DATE: 4-1-2021
	SIGNATURE: [Signature]	CERT #: [Signature]
	PHONE #: (541) 832-2202	

¹Including continuous turbidity data, if applicable, for optimization recording purposes. Compliance values in columns "12 AM" through "8 PM" may not correspond to continuous readings' maximum. ²Filtered systems only.

Date / Time	Minimum Cl ₂ Residual at User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	CXT	[°C]		Use tables	Yes / No	[GPM]
1/	.47	210	98.7	9.3	7.41	45	yes	
2/			System off					
3/								
4/								
5/								
6/								
7/								
8/								
9/								
10/								
11/								
12/								
13/								
14/								
15/								
16/								
17/								
18/								
19/								
20/	.30	210	63	10.6	7.65	45	yes	
21/	.32	210	67.2	10.6	7.52	44	yes	
22/	.36	210	75.6	10.6	7.54	44	yes	
23/		System off						
24/								
25/								
26/								
27/								
28/								
29/	.67	210	140.7	11.5	7.56	42	yes	
30/	.67	210	140.7	12.3	7.56	39	yes	
31/	.62	210	130.2	12.2	7.56	39	yes	

RECEIVED
 APR 05 2021
 Data Mgmt & Compliance
 Drinking Water Program

³ If Cl₂ at entry point < 0.2 mg/l OR CT not met, notify DWS within 24 hours. Revised October 2013. Download form at: public.health.oregon.gov/HealthyEnvironments/DrinkingWater/Monitoring/Documents/turb-alt-unfiltered.pdf