



OHA - Drinking Water Services – Turbidity Monitoring Report Form County: Douglas Slow Sand, Membrane, Diatomaceous Earth Filtration or Unfiltered Systems

System Name: Fir Point Bible Conference ID #:OR4192108 WTP:-WTP-A Month/Year: 8-2021

DAY	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day ¹ [NTU]
1			SYSTEM off	off			
2	1	1	1	1	1	1	
3	off	off	.02	off	off	off	.02
4			SYSTEM off	off			
5	1	1	1	1	1	1	1
6	off	off	.02	off	off	off	.02
7	off	off	.02	off	off	off	.02
8	off	off	.02	off	off	off	.02
9			SYSTEM off	off			
10	off	off	.02	off	off	off	.02
11	off	off	.02	off	off	off	.02
12	off	off	.02	off	off	off	.02
13			SYSTEM off	off			
14	1	1	1	1	1	1	1
15	1	1	1	1	1	1	1
16	off	off	.02	off	off	off	.02
17	off	off	.02	off	off	off	.02
18	off	off	.02	off	off	off	.02
19			SYSTEM off	off			
20	1	1	1	1	1	1	1
21	1	1	1	1	1	1	1
22	off	off	.02	off	off	off	.02
23	off	off	.02	off	off	off	.02
24			SYSTEM off	off			
25	1	1	1	1	1	1	1
26	1	1	1	1	1	1	1
27	1	1	1	1	1	1	1
28	1	1	1	1	1	1	1
29	1	1	1	1	1	1	1
30	1	1	1	1	1	1	1
31	1	1	1	1	1	1	1

Slow Sand/Membrane/DE Filtration/Unfiltered		Monthly Summary (Answer Yes or No)	
95% of daily turbidity readings ≤ 1 NTU? ² <input checked="" type="radio"/> Yes / <input type="radio"/> No All daily turbidity readings ≤ 5 NTU? <input checked="" type="radio"/> Yes / <input type="radio"/> No		CT's met everyday? (see back) <input checked="" type="radio"/> Yes / <input type="radio"/> No	All Cl ₂ residual at entry point ≥ 0.2 mg/l? <input checked="" type="radio"/> Yes / <input type="radio"/> No
Notes: 		PRINTED NAME: Fred Jensen	
		SIGNATURE: 	
		DATE: 8-31-21	
		PHONE #: (541) 832-2202	CERT #: 0

¹Including continuous turbidity data, if applicable, for optimization recording purposes. Compliance values in columns "12 AM" through "8 PM" may not correspond to continuous readings' maximum. ²Filtered systems only.

Date / Time	Minimum Cl ₂ Residual at User (C)	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	CXT	[°C]		Use tables	Yes / No	[GPM]
1/			SYSTEM off					
2/	1	1	1	1	1	1	1	1
3/	.53	210	111.3	24.6	7.51	15	yes	
4/			SYSTEM off					
5/	1	1	1	1	1	1	1	
6/	.42	210	88.2	23.5	7.54	17	yes	
7/	.52	210	109.2	23.2	7.42	17	yes	
8/	.52	210	109.2	24.5	7.53	16	yes	
9/			SYSTEM off					
10/	.40	210	84	22.8	7.54	19	yes	
11/	.44	210	92.4	23.5	7.56	17	yes	
12/	.45	210	94.5	24.7	7.54	16	yes	
13/			SYSTEM off					
14/	↓	↓	↓	↓	↓	↓	↓	
15/	↓	↓	↓	↓	↓	↓	↓	
16/	.36	210	75.6	24.8	7.53	16	yes	
17/	.47	210	98.7	24.4	7.55	16	yes	
18/	.60	210	126.	23.9	7.51	18	yes	
19/			SYSTEM off					
20/	↓	↓	↓	↓	↓	↓	↓	
21/	↓	↓	↓	↓	↓	↓	↓	
22/	.43	210	90.3	23.1	7.55	17	yes	
23/	.44	210	92.4	23.3	7.57	17	yes	
24/			SYSTEM off					
25/	↓	↓	↓	↓	↓	↓	↓	
26/	↓	↓	↓	↓	↓	↓	↓	
27/	↓	↓	↓	↓	↓	↓	↓	
28/	↓	↓	↓	↓	↓	↓	↓	
29/	↓	↓	↓	↓	↓	↓	↓	
30/	↓	↓	↓	↓	↓	↓	↓	
31/	↓	↓	↓	↓	↓	↓	↓	

³ If Cl₂ at entry point < 0.2 mg/L (0.1 C), not met, notify DWS within 24 hours. Revised October 2013 Download form at: public.health.oregon.gov/HealthyEnvironments/DrinkingWater/Monitoring/Documents/turb-alt-unfiltered.pdf

RECEIVED
AUG 31 2021

Data Mgmt & Compliance
Drinking Water Program